

Request to Develop or Modify Reliability Rules (NYSRC Policy No. 1-3)

Submit request to raymond40@aol.com via the NYSRC site www.nysrc.org

Item	Response
1. Respondent	
Name	Reliability Rules Subcommittee
Organization	
Address	
Phone & Fax numbers	
Email address	
2. Title of proposed rule change	Requirements for reviewing NYISO fault duty assessments - Modification of Measurement E-M7 & related Compliance Elements (PRR #81)
3. New rule or modification of NYSRC RR?	
If a new rule is proposed, provide any relevant citation to existing standards	
If a modification to an existing rule is proposed, provide NYSRC RR reference	E-M7
4. Wording of proposed rule change	Reliability Rule E-R8, Fault Duty Assessment (no change)
5. Rationale for proposed rule change	
Identify advantages	This modification is required in order to implement a new NYSRC policy concerning NYISO responsibility for market participant compliance with the rules.
Identify disadvantages	
6. Measurement(s)	E-M7: After evaluating and considering the NYISO assessment concerning a location for which fault duty levels may exceed appropriate equipment ratings, the applicable equipment owner shall assess the condition and report its findings to the NYSIO in accordance with NYISO requirements (see Measurement M-6a).
	<u>Note:</u> The Compliance Elements below (lines 7 & 8) are intended to replace existing Compliance Elements related to E-M7.
7. Full Compliance Statement	The NYISO certified that all applicable equipment owners evaluated NYISO assessments concerning locations for which fault duty levels may exceed equipment ratings and reported their findings to the NYISO in accordance with NYISO requirements and Measurement E-M7.
8. Levels of Non-Compliance	
Level 1	Not applicable.
Level 2	The NYISO certified that one or two applicable equipment owners did not evaluate NYISO fault duty assessments as required and report their findings to the NYISO.
Level 3	The NYISO certified that three or more applicable equipment owners did not evaluate NYISO fault duty assessments as required and report their findings to the NYISO.
Level 4	Not applicable.
9. Responsible Entity	NYISO

10. Compliance Monitoring Entity	RCMS
11. Implementation Plan	<p>NYISO requirements for meeting modification of Measurement E-M7, in accordance with PRR #81, will be effective 30 days after adoption by the NYSRC Executive Committee.</p> <p>Compliance documentation must be submitted to the NYSRC in accordance with NYSRC 2006 Compliance Monitoring Program schedules.</p>
12. Comments	
13. Date of Submission	11/7/05