

Request to Develop or Modify Reliability Rules (NYSRC Policy No. 1-3)

Submit request to raymond40@aol.com via the NYSRC site www.nysrc.org

RR #77-05-01

Item	Response
1. Respondent	
Name	Edward Schrom
Organization	Department of Public Service
Address	3 Empire State Plaza
Phone & Fax numbers	518-486-2890 v 518-473-2420 f
Email address	Edward_schrom@dps.state.ny.us
2. Title of proposed rule change	Measurement F-M6: Voltage Reduction Testing (PRR #77) (Related to existing Reliability Rule F-R5.)
3. New rule or modification of NYSRC RR?	
If a new rule is proposed, provide any relevant citation to existing standards	This new measurement is related to Measurement F-M5, which requires the NYISO to monthly report to the NYSRC emergency actions that were initiated, including voltage reductions.
If a modification to an existing rule is proposed, provide NYSRC RR reference	
4. Wording of proposed rule change	None.
5. Rationale for proposed rule change	
Identify advantages	The NYISO needs to be able to predict with confidence the amount load reduction that can be accomplished with voltage reduction. The results will be needed to evaluate the annual NYCA installed reserve margin requirements in accordance with NYSRC Reliability Rule A-R1.
Identify disadvantages	
6. Measurement(s)	F-M6: The NYISO shall institute a statewide voltage reduction test during the summer capability period of each year if statewide voltage reduction has not been called for during the early portion of the summer. The results of the test or actual voltage reduction shall be recorded and provided to the NYSRC every year. (F-R5)
7. Full Compliance Statement (To be prepared by RCMS)	The NYISO shall annually provide the results of test or actual statewide voltage reduction within an appropriate time period to the NYSRC, in accordance with Measurement F-M6.
8. Levels of Non-Compliance (To be prepared by RCMS)	
Level 1	Not applicable.
Level 2	A statewide voltage reduction test was performed if required, but the results of this test or actual voltage reduction were not provided to the NYSRC within an appropriate time period.
Level 3	Not applicable.
Level 4	A statewide voltage reduction test, if required, was not performed.

9. Responsible Entity	NYISO
10. Compliance Monitoring Entity	NYSRC RCMS
11. Comments	
12. Date of Submission	11/16/04, 12/3/04