

Request to Develop or Modify Reliability Rules (NYSRC Policy No. 1-3)
 Submit request to raymond40@aol.com via the NYSRC site www.nysrc.org

Item	Response
1. Respondent	
Name	Reliability Compliance Monitoring Subcommittee
Organization	NYSRC
Address	
Phone & Fax numbers	
Email address	
2. Title of proposed rule change	Modification of Operation During Major Emergency Measurement F-M2 and Elimination of Reliability Assessment Measurement K-M2e (PRR #78)
3. New rule or modification of NYSRC RR?	
If a new rule is proposed, provide any relevant citation to existing standards	
If a modification to an existing rule is proposed, provide NYSRC RR reference	Operation During Major Emergencies F-M2 & Reliability Assessment K-M2e
4. Wording of proposed rule change	None
5. Rationale for proposed rule change	
Identify advantages	Reporting requirements following a major emergency were identified as part of two separate reliability rule measurements, but the requirements stated were not identical. To ensure uniformity, major emergency reporting requirements were modified and identified only under Measurement F-M2 and Measurement K-M2e was eliminated.
Identify disadvantages	
6. Measurement(s)	<p>F-M2. (<i>Changes shown in bold</i>): The NYISO shall report to the NYSRC on every instance of a major emergency. Included in this report shall be a description of the incident, a summary of conditions that warranted the change to a major emergency state, a summary of actions taken, and the effectiveness of those actions. A preliminary report shall be provided to the NYSRC within one week of the incident; and a final report, if requested by the NYSRC, shall be provided within one month following the incident. (F-R1 through F-R7)</p> <p>K-M2e. This measurement will be eliminated.</p>
7. Full Compliance Statement (For Measurement F-M2)	<p><i>Replaces existing Full Compliance Statement, as follows:</i></p> <p>The NYISO shall provide a preliminary report of major emergencies within one week of an incident. In addition, if requested by the NYSRC, a final report shall be provided within one month following the incident. These reports shall be prepared in accordance with Measurement F-M2 and shall demonstrate what NYISO actions were taken and their effectiveness for meeting NYSRC Reliability Rules.</p>

8. Levels of Non-Compliance	<i>Changes shown in bold.</i>
(To be prepared by RCMS)	
Level 1	Not applicable.
Level 2	The required reports were provided following a major emergency, but at least one report was incomplete in one or more areas.
Level 3	The required major emergency reports were provided, but a review indicated that the NYCA system was not operated in accordance with NYSRC Reliability Rules.
Level 4	At least one of the required major emergency reports was not provided following a reportable incident.
9. Responsible Entity	NYISO
10. Compliance Monitoring Entity	RCMS
11. Comments	
12. Date of Submission	5/31/05, 6/17/05, 7/9/05