

**AN ILLUSTRATION OF USING A SUITE OF RELIABILITY METRICS  
TO GET A GOOD PICTURE OF LOSS OF LOAD EVENTS\***

<b>Event Characteristic</b>	<b>Metric</b>	<b>California Aug 2020</b>	<b>Texas Feb 2021</b>
Number of Events	LOLEv	2 events	1 event
Number of Days	LOLE	2 days	3 days
Number of Hours	LOLH	6 hours	71 hours
Unserved Energy	EUE	2,700 MWh	990,000 MWh
Max Shortfall	-	1,072 MW	20,000+ MW

---

\*Based on a paper submitted to the 2021 NERC Probabilistic Analysis Forum, *New Metrics for Resource Adequacy*, by Derek Stenlik of Telos Energy.