Winter 2018 Capacity Assessment Winter Preparedness

Emilie Nelson


Vice President, Market Operations NYISO

New York State Reliability Council

December 8, 2017



Historic Winter Peaks





Winter 2018 Capacity Assessment

 For projected baseline forecast peak conditions and expected performance of the transmission system, generation, and pipeline infrastructure the NYISO expects to meet reliability criteria throughout Winter 2017-18

Winter 2017-18 Projected Capacity Margins (MW)					
Region	Base Condition		Loss of Interruptible Gas Condition		
	Normal Weather	90th Weather	Normal Weather	90th Weather	
NY State	11,648	10,024	7,511	5,887	
Lower Hudson Valley	8,231	7,556	5,779	5,104	



2016-17 & 2017-18 Winter Capacity Assessment & Comparison

		2016-17		2017-18	
Line	Item	Baseline Forecast	90th Percentile Forecast	Baseline Forecast	90th Percentile Forecast
1a	Winter Generation Capacity ¹	40,092	40,092	41,454	41,454
1b	SCR - ICAP Values	842	842	792	792
1c	Net Purchases & Sales	2,034	2,034	2,311	2,311
1	Total Capacity Resources	42,968	42,968	44,557	44,557
2	Assumed Unavailable Capacity (Gen + SCR)	-4,940	-4,940	-5,924	-5,924
3 = 1 + 2	Net Capacity Resources	38,028	38,028	38,633	38,633
4	Peak Load Forecast	24,445	26,049	24,365	25,989
5	Operating Reserve Requirement	2,620	2,620	2,620	2,620
6 = 4+5	Total Capacity Requirement	27,065	28,669	26,985	28,609
7 = 3 - 6	Capacity Margin	10,963	9,359	11,648	10,024

Line 1a: Reflects the 2017 Gold Book existing capacity with projected and actual deactivations, additions and DMNC updates during 2017

Line 2: Unavailable: 1145 MW Wind, 416 MW Hydro, 2,957 MW Thermal, 231 MW Demand Response, 1,152 Schedule Outages, 23 Other



2017-18 Winter Capacity Assessment - Loss of Gas

Line	ltem	Baseline Forecast	90th Percentile Forecast
1a	Installed Capacity Resources	41,454	41,454
1b	SCR - ICAP Values	792	792
1c	Net ICAP External Imports	2,311	2,311
1	NYCA Resource Capability	44,557	44,557
2	Total Projected Capacity Outages	-5,924	-5,924
3 = (1-2)	Net Installed Capacity Resources	38,633	38,633
4	Load Forecast	24,365	25,989
5	Operating Reserve Requirement	2,620	2,620
6 = (3-4-5)	Capacity Margin	11,648	10,024
7a	Subtract All Gas Only Units	6,901	6,901
7 = (6-7a)	Capacity Margin, Loss of Gas	4,747	3,123
8a	Add Back Units with Firm Gas Contracts	2,764	2,764
8 = (7-8a)	Expected Capacity, Loss of Gas Case	7,511	5,887



Capacity & Infrastructure Updates

- Generation (relative to fall 2016 projections)
 - Fitzpatrick not expected last winter
 - Greenidge Unit 4 in-service (return to market)
 - DMNC increases
 - + 0 MW (CPV possible oil-fired test generation)
 - Retirements of Stony Brook & Binghamton Cogen

Transmission


- Two Phase Angle Regulators (PARs) in-service at the Con Edison Ramapo Substation
- Expect HTP in-service this winter
- 345 kV Dolson Ave Substation complete Interconnection for CPV on the 345 kV Coopers Corners - Rock Tavern 42



Appendix Recent Prices, Preparedness Challenges




Historic Fuel Prices - Past 4 years





Historic Electric Prices: Past 4 Years



Recent Market Enhancements

November 2014	Established capability to allow generators to provide expected costs for
	day-ahead reference level development

- November 2015 Implemented enhancements to Shortage Pricing to incent generators to secure sufficient fuel to meet day-ahead schedules
- Increased the Total Operating Reserve Requirement from 1965 MW to 2620 MW November 2015
- FERC Order 809 NYISO market closes at 5 AM (EST/EDT) and posts day-ahead electric schedules around 9:30 AM
- **June 2016 Enhanced Scarcity Pricing for Demand Response activations deployed**
- **May 2017 Guide 19: Expectations of Generator Operation During Gas Restrictions**
- **Ongoing** Continuing discussions with Stakeholders on fuel assurance in the form of capacity market enhancements



Winter 2017-18 Preparedness

- Seasonal generator fuel surveys indicate oil-burning units have sufficient winter starting oil inventories along with arrangements for replacement fuel
- The NYISO has performed on-site visits of generating stations to discuss past winter operations and preparations for upcoming winter, including: Generation testing, coldweather preventative maintenance, fuel capabilities, and fuel switching capabilities
- Existing Minimum Oil Burn procedures defined by the New York State Reliability Council (NYSRC) establish fuel switching requirements at certain load thresholds to secure electric reliability for NYC and Long Island LDC gas pipeline contingencies
- Tariff changes to reflect new NYSRC dual fuel testing rules applicable to combine cycle units in New York City were approved by FERC in September



Situational Awareness

- Control Room gas-electric support
- Video Boards
 - Northeast interstate pipeline system is displayed
 - Operational Flow Orders are posted with enhanced brightness
- A web-based, fuel survey "portal" provides generator fuel information to the operators
 - Updated weekly by generators
 - Updated daily during cold weather conditions



Continued Winter Challenges

- Gas Availability | Firm Gas LDC retail load has gas transportation priority on the NY LDC's over electric power generation during cold weather conditions
- Extended Cold Weather Conditions | Burn rates of alternative fuels can exceed replacement rates of alternative fuels during extended cold weather or when oil costs are below gas costs for an extended period of time
- Emissions challenges to dual fuel capability | Burning oil may be further restricted by reduced NOx emission limits, less Northeast refinery capability, or potential for reduced carbon emissions targets
- New gas pipeline siting remains challenging



The Mission of the New York Independent System Operator, in collaboration with its stakeholders, is to serve the public interest and provide benefits to consumers by:

- Maintaining and enhancing regional reliability
- Operating open, fair and competitive wholesale electricity markets
- Planning the power system for the future
- Providing factual information to policy makers, stakeholders and investors in the power system



www.nyiso.com

