

February 23, 2021

Mr. Roger Clayton
Chairman, NYSRC Reliability Rules Subcommittee

Dear Roger,

Consolidated Edison has notified the NYSRC Executive Committee of Consolidated Edison's desire to remove Rule Exception 8, upon the removal from service of Indian Point Unit 3 on April 30, 2021. The NYISO's System & Resource Planning and Operations Departments have conducted a review to determine the impact of removing the exception. The NYISO has not identified any reliability criteria violations associated with removing the exception on May 1, 2021, as requested by Consolidated Edison. If for any reason Indian Point Unit 3 is not removed from service on April 30, 2021, as expected, the Exceptions should remain in place until Unit 3 is removed from service.

Sincerely,

Zach Smith
Vice President, System & Resource Planning