## NORTHEAST POWER COORDINATING COUNCIL

Status of Underfrequency Load Shedding Program
Conformance with Directory D-12, "Underfrequency Load Shedding Requirements"
MegaWatts shed are on peak for the year 2015 as of July 15, 2016
Reporting Entity: NYISO

Reporting Entity	Peak Load (MW)	First Step*			Second Step*			Third Step*			Fourth Step*			Fifth Step		
		Frequency (Hz)	Net MW Shed	% of Peak	Frequency (Hz)	Net MW Shed	% of Peak	Frequency (Hz)	Net MW Shed	% of Peak	Frequency (Hz)	Net MW Shed	% of Peak	Frequency (Hz)	Net MW Shed	% of Peak
O&R	1010	59.5	66.70	6.6%	59.3	74.20	7.3%	59.1	71.20	7.1%	58.9	74.50	7.4%	59.5 (10 s)	25.10	2.5%
CHG&E	1059	59.5	71.64	6.8%	59.3	73.67	7.0%	59.1	74.81	7.1%	58.9	72.62	6.9%	59.5 (10s)	25.76	2.4%
NYSEG	3049	59.5	210.32	6.9%	59.3	168.04	5.5%	59.1	231.90	7.6%	58.9	199.70	6.5%	59.5 (10 s)	5.00	0.2%
RG&E	1548	59.5	116.60	7.5%	59.3	105.56	6.8%	59.1	115.60	7.5%	58.9	111.00	7.2%	59.5 (10 s)	33.00	2.1%
LIPA	5241	59.5	368.20	7.0%	59.3	366.40	7.0%	59.1	367.70	7.0%	58.9	365.10	7.0%	59.5 (10 s)	105.70	2.0%
NYPA	292				59.3	20.00	6.8%									
National Grid	7036	59.5	465.00	6.6%	59.3	494.00	7.0%	59.1	480.00	6.8%	58.9	495.00	7.0%	59.5 (10s)	192.00	2.7%
ConEd	12031	59.5	853.00	7.1%	59.3	831.00	6.9%	59.1	851.00	7.1%	58.9	862.00	7.2%	59.5 (10 s)	280.00	2.3%
Total	31,266.00		2,151.46	6.9%		2,132.87	6.8%		2,192.21	7.0%		2,179.92	7.0%		666.56	2.1%

<sup>\*</sup>Total nominal operating time is 0.30 s.

Stages below are	not part of D-	12 Compliance									
Reporting Entity	Peak Load (MW)	Other Step				Other Step		Other Step			
		Frequency (Hz)	Net MW Shed	% of Peak	Frequency (Hz)	Net MW Shed	% of Peak	Frequency (Hz)	Net MW Shed	% of Peak	
ConEd	12,031	58.7	843	7.0%	58.5	853	7.1	58.3	834	6.9	
NYPA	292	58.8	210.00	71.9%							