

**November 28, 2017 NYSRC ICS Meeting Report**

Prepared for the December 8, 2017 NYSRC EC meeting

**Final IRM Report – Approval sought from EC**

The ICS reviewed and approved the IRM report. At the November 9<sup>th</sup> EC meeting, Ms. Emilie Nelson provided an overview on the activities surrounding the status of the CPV Valley Energy Center. The current base case includes CPV Valley Energy Center as being in service. Due to some uncertainty surrounding that assumption, the EC directed the ICS/NYISO to perform a sensitivity case with CPV Valley Energy Center not in service. A Tan 45 was performed for this case. The table below shows a comparison of the IRM requirements for the two cases.

<b>Comparison of IRM</b>	<b>NYCA</b>	<b>NYC</b>	<b>Long Island</b>
CPV Valley Energy Center in base case	18.2	80.7	103.2
CPV Valley Energy Center not in base case	18.3	81.5	103.7

**NYISO Alternative LCR Methodology**

The ICS reviewed and approved a report to the EC that discusses the ICS review on the NYISO’s Alternative LCR Methodology proposal. The ICS does not object to continued development and application of the alternative LCR method that was proposed and approved at the November 15<sup>th</sup> BIC, assuming this method is found to be compliant with NYSRC rules.

**Activities for January 2018**

- Lessons learned from the 2018 IRM process
- Direction on the continued development of IRM Study Guide
- Topics of interests for future development
- Con Edison to assume role of secretary/vice-chair