

November 4, 2020 ICS Meeting #239 and November 9, 2020 ICS Meeting #240
Prepared for the November 13, 2020 EC Meeting – Ruby Chan

1. 2021 Final Base Case IRM – For EC Approval
 - a. Parametric Result – see ICS Attachment #1
 - b. Tan 45 Result – see ICS Attachment #2

ICS recommends to EC: 2021 Final Base Case IRM of 21.3%.

2. Sensitivity case

There was much discussion on Energy Limited Resource (ELR) modeling and Con Ed's 345 kV series reactors (41, 42, Y49, M51, M52, 71 and 72). Several market participants expressed a high desire to perform a sensitivity for the series reactors to evaluate impact to IRM. The NYISO indicated that since the scenario of different operation mode of the series reactors does not impact this year's IRM, and with the amount of work that needs to be done by the end of the year (e.g., finish IRM study, determine LCRs), they would not be able to start the request until January (also depends on ICS's prioritized list of work).

3. Draft 2021 IRM Report – see ICS Attachment #3
4. Draft 2021 IRM Report Appendices – see ICS Attachment #4
5. Follow up to Executive Committee's request to ICS to annually track the amount of public appeals used in New York