

# NYCA IRM Requirement Study 2022- 2023 Preliminary Base Case (PBC) Model Assumptions Matrix

Draft V 6.0

NYSRC

**Installed Capacity Subcommittee Meeting #248**

June 29, 2021

# Load Forecast Uncertainty

#	Parameter	2021 Model Assumptions	2022 Model Assumptions	Basis for Recommendation	Model Change	Expected Date	Est. IRM Impact*
1	Peak Load Forecast (Preliminary Base Case – Parametric & Sensitivities)	2020 Gold Book NYCA: 32,129MW <sup>1</sup> NYC: 11,460 MW LI: 5,139 MW G-J: 15,660 MW (Attachment A1)	2021 Gold Book** NYCA: 32,178MW <sup>1</sup> NYC: 11,268 MW LI: 5,153 MW G-J: 15,435 MW (Attachment A1)	Most recent Gold Book Forecast is used for Preliminary Base Case parametric study and sensitivity cases	N	<b>Data Received</b>	Medium(-)
2	Peak Load Forecast (Final Base Case)	October 2020 Fcst. NYCA: 32,243 MW <sup>2</sup> NYC: 11,232 MW LI: 5,282.0 MW G-J: 15,385 MW	October 2021 Fcst. NYCA: xxxxx MW <sup>2</sup> NYC: yyyyy MW LI: zzzzz MW G-J: wwwww MW	Forecast based on examination of 2021 weather normalized peaks	N	October 2021	TBD
3	Load Shape (Multiple Load Shape)	Bin 1: 2006 Bin 2: 2002 Bins 3-7: 2007	Bin 1: 2006 Bin 2: 2002 Bins 3-7: 2007	ICS Recommendation	N	<b>Data Received</b>	None
4	Load Forecast Uncertainty (LFU)-	Zonal Model to reflect current data with input from Con Ed and LIPA. (Attachment A2)	Zonal Model to reflect current data with input from Con Ed and LIPA. (Attachment A2)	Based on TO and NYISO data analyses	N	<b>Data Received</b>	High (-)
5	LFU Winter	Attachment A3	Attachment A3	Based on TO and NYISO data analyses	N	<b>Data Received</b>	None

\*(-) indicates a reduction in IRM while (+) indicates an increase. Range: Low < 0.5%, Medium 0.5% - 1%, High > 1%, Minimal indicates there may be some movement but within 0 to +/- 0.1%.

New Capacity resources will continue to be tracked by the NYISO. The Final Base Case resource list is subject to change based on project status' by October 2020.

1 The loads associated with the BTM-NG program need to be added to these values.

2 BTM-NG loads have been incorporated into these numbers.

Draft

# Generation Parameters

#	Parameter	2021 Model Assumptions	2022 Model Assumptions	Basis for Recommendation	Model Change	Expected Date	Est. IRM Impact*
6	Existing Generating Unit Capacities	2020 Gold Book Values. Use min. (DMNC vs. CRIS) capacity value	2021 Gold Book Values. Use min. (DMNC vs. CRIS) capacity value	Latest Gold Book publication	N	<b>Data Received</b>	Minimal
7	Proposed New Units (Thermal) and re-ratings	0 MW of new Thermal resources, plus 56.6 MW of project related re-ratings. (Attachment B1)	23.7 MW of new Thermal resources,** (Attachment B1)	NYISO recommendation based on documented process that includes the latest Gold Book publication, NYISO interconnection queue, and generation notifications	N	<b>Data Received</b>	Minimal
8	Deactivations and Removals <sup>3</sup>	1,104 MW of unit deactivations and 192.7 MW of unit removals (Attachment B2)	19.1 MW of unit deactivations and (Attachment B2)	Latest Gold Book publications and generator notifications	N	<b>Data Received</b>	Minimal
9	Forced and Partial Outage Rates	Five-year (2015-2019) GADS data for each unit represented. Those units with less than five years - use representative data. (Attachment C)	Five-year (2016-2020) GADS data for each unit represented. Those units with less than five years - use representative data. (Attachment C)	Transition Rates representing the Equivalent Forced Outage Rates (EFORd) during demand periods over the most recent five-year period	N	<b>Data Received</b>	Low(-)
10	Planned Outages	Based on schedules received by the NYISO and adjusted for history	Based on schedules received by the NYISO and adjusted for history	Updated schedules	N	<b>Data Received</b>	TBD

<sup>3</sup>Units that did not participate in the Capacity Market have been removed from this year's study

# Generation Parameters

#	Parameter	2021 Model Assumptions	2022 Model Assumptions	Basis for Recommendation	Model Change	Expected Date	Est. IRM Impact*
11	Summer Maintenance	Nominal 50 MWs – divided equally between Zones J and K			TBD	August 2021	TBD
12	Combustion Turbine Derates	Derate based on temperature correction curves provided	Derate based on temperature correction curves provided	Operational history indicates the derates are inline with manufacturer’s provided curves	N	<b>Data Received</b>	None
13	Existing and Proposed New Wind Units <sup>4</sup>	126.5 MW of Wind Capacity additions totaling 1865.7 MW of qualifying wind (Attachment B3)	158.1 MW of Wind Capacity additions totaling 2017.5 MW of qualifying wind (Attachment B3)	ICAP units based on RPS agreements, interconnection queue and ICS input.	N	<b>Data Received</b>	Low(+)
14	Wind Shape	Actual hourly plant output over the period 2015-2019. New units will use zonal hourly averages or nearby units.	Actual hourly plant output over the period 2016-2020. New units will use zonal hourly averages or nearby units.	Program randomly selects a wind shape of hourly production from the most recent five-year period for each model iteration.	N	<b>Data Received</b>	Minimal
15	Existing and Proposed New Solar Resources <sup>4</sup>	0 MW of Solar Capacity additions totaling 31.5MW of qualifying Solar Capacity. (Attachment B3)	22.9 MW of Solar Capacity additions totaling 54.4 MW of qualifying Solar Capacity. (Attachment B3)	ICAP Resources connected to Bulk Electric System	N	<b>Data Received</b>	Minimal
16	Solar Shape	Actual hourly plant output over the period 2015-2019. New units will use zonal hourly averages or nearby units.	Actual hourly plant output over the period 2016-2020. New units will use zonal hourly averages or nearby units.	Program randomly selects a solar shape of hourly production from the most recent five-year period for each model iteration.	N	<b>Data Received</b>	Minimal

<sup>4</sup>Units that did not participate in the Capacity Market have been removed from this year’s study

# Generation Parameters

#	Parameter	2021 Model Assumptions	2022 Model Assumptions	Basis for Recommendation	Model Change	Expected Date	Est. IRM Impact*
17	BTM- NG Program	Two new BTM NG resource (Attachment B5)	One new BTM NG resource (Attachment B5)	Both the generation of the participating resources and the full host loads are modeled.	N	<b>Data Received</b>	Minimal
18	Small Hydro Resources	Actual hourly plant output over the period 2015-2019.	Actual hourly plant output over the period 2016-2020.	Program randomly selects a hydro shape of hourly production from the most recent five-year period for each model iteration.	N	<b>Data Received</b>	Minimal
19	Large Hydro	Probabilistic Model based on five years of GADS data (2015-2019)	Probabilistic Model based on five years of GADS data (2016-2020)	Transition Rates representing the Equivalent Forced Outage Rates (EFORd) during demand periods over the most recent five-year period.	N	<b>Data Received</b>	Minimal
20	Landfill Gas	Actual hourly plant output over the period 2015-2019.	Actual hourly plant output over the period 2016-2020.	Program randomly selects a LFG shape of hourly production from the most recent five-year period for each model iteration.	N	<b>Data Received</b>	Minimal
21	New ESR (Energy Storage Resources) <sup>4</sup>	0 MW of new battery storage scheduled. 0MW of total battery storage modeled (see attachment B4)	0 MW of new battery storage scheduled. 0 MW of total battery storage modeled (see attachment B4)	Sensitivities on simplified model and GE software enhancement	N	<b>Data Received</b>	None
22	Energy Limited Resources (ELR)	Based upon elections made by August 1 <sup>st</sup> 2020	Based upon elections made by August 1 <sup>st</sup> 2021	Existing elections are made by August 1st and will be incorporated into the model.	N	August 2021	Low(-)

Draft

# Transactions- Imports and Exports

#	Parameter	2021 Model Assumptions	2022 Model Assumptions	Basis for Recommendation	Model Change	Expected Date	Est. IRM Impact*
23	Capacity Purchases	Existing Rights: PJM - 1,080 MW HQ - 1,110 MW All contracts modeled as equivalent contracts	Existing Rights: PJM - 1,080 MW HQ - 1,190 MW All contracts modeled as equivalent contracts. New 80 MW addition	Grandfathered Rights, ETCNL, and other awarded long-term rights.	N	<b>Data Received</b>	None
24	Capacity Sales	Long Term firm sales  Summer 265.9 MW	Long Term firm sales  Summer 265.9 MW	These are long term FERC approved contracts.	N	<b>Data Received</b>	None
25	FCM Sales from a Locality <sup>5</sup>	No sales modeled within study period	No sales modeled within study period	NYISO recommendation	N	<b>Data Received</b>	None
26	Wheels through NYCA	300 MW HQ to NE equivalent contract	300 MW HQ to NE equivalent contract	HQ Wheel has an ISO-NE capacity supply obligation (CSO) for 2022-23	N	<b>Data Received</b>	None
27	New UDRs (Unforced capacity Deliverability Rights)	Projects with expired CRIS will be modeled as Emergency Assistance Only: HTP	Projects with expired CRIS will be modeled as Emergency Assistance Only: HTP	Existing UDR elections are made by August 1st and will be incorporated into the model	TBD	August 2021	TBD
28	New EDRs (External Deliverability Rights)	0 MWs for 2021 Study	80 MWs for 2022 Study	80 MWs from Cedars upgrade	Y	<b>Data Received</b>	Minimal

<sup>5</sup> Final FCM sales that will materialize are unknowable at the time of the IRM study. To reflect the impact these sales have on reliability, the NYISO applies a Locality Exchange Factor in the market.

# Topology

#	Parameter	2021 Model Assumptions	2022 Model Assumptions	Basis for Recommendation	Model Change	Expected Date	Est. IRM Impact*
29	Interface Limits	Removal of PJM-SENY Group Interface, PSEG-LI updates to increase Zone K Imports/Exports: Jamaica ties no longer dependent on Barrett Availability (Attachment E-E4)	Revisions to Western NY Public Policy impacts, Central East derate, Cedars upgrade	Based on the most recent NYISO studies and processes, such as Operating Study, Operations Engineering Voltage Studies, Comprehensive System Planning Process, and additional analysis including interregional planning initiatives.	Y	<b>Data Received</b>	None
30	New Transmission	None Identified	Cedars EDR from HQ	Based on TO provided models and NYISO's review	Y	<b>Data Received</b>	Minimal
31	AC Cable Forced Outage Rates	All existing Cable EFORDs for NYC and LI to reflect most recent five-year history (2015-2019)	All existing Cable EFORDs for NYC and LI to reflect most recent five-year history (2016-2020)	TO provided transition rates with NYISO review.	N	<b>Data Received</b>	TBD
32	UDR Line Unavailability	Five year history of forced outages (2015-2019)	Five year history of forced outages (2016-2020)	NYISO/TO Review	N	<b>Data Received</b>	TBD

Draft

# Emergency Operating Procedures

#	Parameter	2021 Model Assumptions	2022 Model Assumptions	Basis for Recommendation	Model Change	Expected Date	Est. IRM Impact*
33	Special Case Resources	July 2020 –1195 MW based on registrations and modeled as 822 MW of effective capacity. Monthly variation based on historical experience.	July 2021 –xxxx MW based on registrations and modeled as yyy MW of effective capacity. Monthly variation based on historical experience.	SCRs sold for the program discounted to historic availability. Summer values calculated from July 2021 registrations. Performance calculation updated per ICS presentations on SCR performance.	TBD	July 2021	TBD
34	Other EOPs	844.4 MW of non- SCR/non-EDRP resources (Attachment D)	Zzzz MW of non- SCR/non-EDRP resources (Attachment D)	Based on TO information, measured data, and NYISO forecasts	TBD	July 2021	TBD
35	EOP Structure	10 EOP steps modeled	10 EOP steps modeled	Based on agreement with ICS	N	<i>Data Received</i>	None



# External Control Areas

#	Parameter	2021 Model Assumptions	2022 Model Assumptions	Basis for Recommendation	Model Change	Expected Date	Est. IRM Impact*
36	PJM	Load and Capacity data will be provided by ISONE/NPCC CP-8 Data may be adjusted per NYSRC Policy 5 (Attachment E)	Load and Capacity data will be provided by ISONE/NPCC CP-8 Data may be adjusted per NYSRC Policy 5 (Attachment E)	Initial Review performed by the NPCC CP-8 WG prior to Policy 5 changes	N	<i>Data Received</i>	
37	ISONE, Quebec, IESO	Load and Capacity data will be provided by ISONE/NPCC CP-8 Data adjusted per NYSRC Policy 5 (Attachment E)	Load and Capacity data will be provided by ISONE/NPCC CP-8 Data adjusted per NYSRC Policy 5 (Attachment E)	Initial Review performed by the NPCC CP-8 WG prior to Policy 5 changes	N	<i>Data Received</i>	
38	External Adjustments per Policy 5	If needed, add load to externals proportional to existing excess capacity	If needed, add load to externals proportional to existing excess capacity	White paper on external Control Area adjustments	N	<i>Data Received</i>	
39	Reserve Sharing	All NPCC Control Areas indicate that they will initially share reserves equally among all members and then among non-members	All NPCC Control Areas indicate that they will initially share reserves equally among all members and then among non-members	Per NPCC CP-8 WG	N	<i>Data Received</i>	None
40	Emergency Assistance	Statewide Limit of 3,500 MW of emergency assistance allowed from neighbors.	Statewide Limit of 3,500 MW of emergency assistance allowed from neighbors.	White Paper on Modeling of Emergency Assistance for NYCA in IRM studies	N	<i>Data Received</i>	None

# Miscellaneous

#	Parameter	2021 Model Assumptions	2022 Model Assumptions	Basis for Recommendation	Model Change	Expected Date	Est. IRM Impact*
41	MARS Model Version	3.31.1546	4.2.1765	Per testing and ICS recommendation	Y	<i>Received</i>	None
42	Environmental Initiatives	No new rules for 2021 Capability Year				July 2021	

Draft

# Attachment A1

NYCA Summer Load Forecast Coincident and Non-Coincident Peak:  
2021 and 2022

2022 PBC													
Area	A	B	C	D	E	F	G	H	I	J	K	NYCA	G_J
NCP - Forecast	2799	2056.4	2847.8	692	1420	2385	2215	648	1400	11286.2	5191.6		
CP - Forecast	2644	1994.4	2781.8	676	1361	2347	2179	637	1379	11134.2	5174.6	32308	
G-J Peak - Forecast							2197	642	1390	11224.2			15453.2


2021 FBC													
Area	A	B	C	D	E	F	G	H	I	J	K	NYCA	G_J
NCP - Forecast	2806.3	2033.8	2972.4	653.4	1465.7	2442.8	2231.9	642.6	1394.1	11232.3	5282		
CP - Forecast	2626.8	1955.2	2850.2	617.6	1398.6	2365.9	2193.6	631.1	1369	11031	5204	32243	
G-J Peak - Forecast							2216.9	637.8	1383.5	11147.1			15385.3

Delta													
Area	A	B	C	D	E	F	G	H	I	J	K	NYCA	G_J
NCP - Forecast	-7.3	22.6	-124.6	38.6	-45.7	-57.8	-16.9	5.4	5.9	53.9	-90.4		
CP - Forecast	17.2	39.2	-68.4	58.4	-37.6	-18.9	-14.6	5.9	10	103.2	-29.4	65	
G-J Peak - Forecast							-19.9	4.2	6.5	77.1			67.9

# Attachment A2


## NYCA Summer Load Forecast Uncertainty Model: 2021 and 2022

Load Forecast 2022



Bin	Probability	A-E	F&G	H&I	J	K
B1	0.62%	114.78%	115.85%	112.55%	109.95%	115.63%
B2	6.06%	110.01%	110.53%	108.40%	106.49%	110.73%
B3	24.17%	105.06%	105.01%	103.36%	102.33%	105.30%
B4	38.30%	100.00%	99.36%	97.68%	97.67%	100.00%
B5	24.17%	94.88%	93.61%	91.50%	92.58%	92.96%
B6	6.06%	89.73%	87.77%	84.89%	87.13%	84.32%
B7	0.62%	84.63%	81.88%	77.98%	81.38%	76.60%
<b>Delta</b>		<b>A-E</b>	<b>F&amp;G</b>	<b>H&amp;I</b>	<b>J</b>	<b>K</b>
B1 - B4	14.78%	16.49%	14.87%	12.28%	15.63%	
B4 - B7	15.37%	17.48%	19.70%	16.29%	23.40%	
Total Range	30.15%	33.97%	34.57%	28.57%	39.03%	


Load Forecast 2021



Bin	Probability	A-E	F&G	H&I	J	K
B1	0.62%	116.02%	117.17%	113.56%	110.73%	116.38%
B2	6.06%	111.11%	111.70%	109.46%	107.33%	111.97%
B3	24.17%	105.70%	105.70%	104.06%	102.89%	105.98%
B4	38.30%	100.00%	99.36%	97.68%	97.67%	100.00%
B5	24.17%	94.22%	92.89%	90.66%	91.91%	91.88%
B6	6.06%	88.58%	86.48%	83.35%	85.86%	82.34%
B7	0.62%	83.28%	80.33%	76.06%	79.79%	75.52%
<b>Delta</b>		<b>A-E</b>	<b>F&amp;G</b>	<b>H&amp;I</b>	<b>J</b>	<b>K</b>
B1 - B4	16.02%	17.80%	15.88%	13.06%	16.38%	
B4 - B7	16.72%	19.04%	21.62%	17.88%	24.48%	
Total Range	32.74%	36.84%	37.50%	30.94%	40.87%	

# Attachment A3

NYCA Winter Load Forecast Uncertainty Model: 2021 and 2022



Bin	Probability	LFU (2022)	LFU (2021)
B1	0.62%	111.01%	112.22%
B2	6.06%	106.89%	107.77%
B3	24.17%	103.25%	103.69%
B4	38.30%	100.00%	100.00%
B5	24.17%	97.05%	96.69%
B6	6.06%	94.34%	93.76%
B7	0.62%	91.85%	91.22%

Draft

# Attachment B1

## New Thermal Units and Unit Re-Ratings<sup>7</sup>

New Thermal Units and Unit Re-ratings (summer ratings)					
Project or Generator Name	Zone	2021 Gold Book (MW) CRIS	2021 Gold Book (MW) DMNC	New or Incremental (MW)	2022 MARS Model (MW)
<b>New Units</b>					
King's Plaza	J	6.0	6.0	6	6
Fulton County Landfill*	F	3.2	3.2	3.2	3.2
Ontario Landfill*	B	11.2	11.2	3.6	11.2
Sithe Independence**	C	1013.0	995.0	10.9	1005.9
<b>Total New Units and Uprates (MW)</b>				23.7	

<sup>7</sup> Unit re-ratings are for generation facilities that have undergone uprate projects.

\*Existing LFG units with incremental DMNC and/or CRIS; modeled in MARS with shapes

\*\*1013 and 995 MW are 2021 Gold Book values prior to generator re-ratings

# Attachment B2

## Deactivations and Removals<sup>4</sup>

Unit Removal since 2021 IRM Study			
Generator Name	Type	Zone	CRIS(MW)
Gowanus 1-8	Gas Turbine	J	16.1
Sissons ville	Hydro	B	3
<b>Total Removals</b>			19.1

<sup>4</sup>Units that did not participate in the Capacity Market have been removed from this year's study

# Attachment B3

## New Intermittent Resources

Wind				
Resource	Zone	CRIS (MW)	Summer Capability (MW)	MARS Modeled Capacity
New Wind Units				
Arkwright Summit Wind Farm*	A	78.4	78.4	78.4
Roaring Brook	E	79.7	79.7	79.7
<b>Total</b>				158.1

Solar				
Resource	Zone	CRIS (MW)	Summer Capability (MW)	MARS Modeled Capacity
New Solar Units				
Calverton Solar Energy Center	K	22.9	22.9	22.9
<b>Total</b>				22.9

\*This is an existing resource that became an ICAP supplier

Draft



# Attachment B4

New Energy Storage Resources\*

Energy Storage				
Resource	Zone	CRIS (MW)	Summer Capability (MW)	Lesser of Summer Capability VS CRIS
New Battery Units				
<b>Total New Energy Storage</b>				

Draft

# Attachment B5

## Resources in the Behind the Meter Net Generation Program (BTM-NG)

Attachment B4 -Units in the Behind the Meter Net Generation Program*			
Generator Name	Zone	Resource Value (MW) <sup>9</sup>	Peak Load Adjustment (MW) <sup>10</sup>
<b>Existing:</b>			
Stony Brook	K	36.2	42.0
Greenidge 4	C	103.4	32.0
Lyons Falls Hydro	E	8.0	2.7
(CONFIDENTIAL)***	J		21.3
<b>New:</b>			
Red Rochester	B	74	51.4
<b>Total BTM-NG</b>			149.4

\*The IRM study independently models the generation and load components of BTM:NG Resources

<sup>9</sup>Based on adjusted Dependable Maximum Gross Capability (DMGC) value

<sup>10</sup>Based on Average Coincident Host Load (ACHL)

\*\*\* One existing resource in Zone J is expected to begin participating in the BTM:NG program prior to 6/1/2022

Draft

# Attachment C

NYCA Five Year Derating Factors

Draft

# Attachment D


## Emergency Operating Procedures

Step	Procedure	2021 MW Value	2022 MW Value
1	Special Case Resources –Load, Gen	1,195 MW Enrolled/ 822 MW modeled	
2	5% manual voltage Reduction	59.64 MW	
3	Thirty-minute reserve to zero	655 MW	
4	5% remote voltage reduction	445.42 MW	
5	Voluntary industrial curtailment	259.36 MW	
6	General Public Appeals	80 MW	
7	Emergency Purchases	Varies	
8	Ten-minute reserves to zero	1,310 MW	
9	Customer disconnections	As needed	
10	Adjustment used if IRM is lower than technical study margin	As needed	

Draft

# Attachment E

IRM Topology




- Notes**
1. PJM to NY emergency assistance (EA) assumption for calculating the PJM-NY Western ties, PJM-G Group, and ABC Line Group flow distribution limit: 1500MW
  2. NYCA EA simultaneous import limit: 3,500 MW
  3. External areas representation based upon information received from the NPCC CP-8 WG


**Legend**

Draft

# ISO-NE 14 Bubble Model



# PJM Bubble Model



# Attachment F

## SCR Determinations 2022 and 2021 IRM Studies

SCR Performance for 2022 IRM Study						
Super Zones	Enrollments (July 2020)	Forecast (2021) <sup>1</sup>	Performance Factor <sup>2</sup>	UCAP (2021)	Adjustment Factor <sup>3</sup>	Model Value
A-F						
G-I						
J						
K						
<b>Totals</b>						

SCR Performance for 2021 IRM Study						
Super Zones	Enrollments (July 2020)	Forecast (2021) <sup>1</sup>	Performance Factor <sup>2</sup>	UCAP (2021)	Adjustment Factor <sup>3</sup>	Model Value
A-F	622.8	622.8	0.862	537.2	0.949	509.5
G-I	102.0	102.0	0.747	76.2	0.851	64.9
J	427.3	427.3	0.693	296.2	0.752	222.7
K	43.0	43.0	0.706	30.3	0.821	24.9
<b>Totals</b>	<b>1195.1</b>	<b>1195.1</b>		<b>940.0</b>		<b>822.1</b>
					Overall Performance = 68.8%	

1. These values represent no growth from July 2020 ICAP based enrollments.
2. Performance Factor based on ACL methodology
3. The SCR Adjustment factor captures two different performance derates; 1) Calculated Translation Factor (TF) between ACL and CBL values, and the Fatigue Factor (FF=1.00)

Draft



# Attachment G

## Wind Units Modeled

Resource	Zone	Wind		
		CRIS (MW)	Summer Capability (MW)	MARS Modeled Capability**
Bliss Wind Power [WT]	A	100.5	100.5	100.5
Canandaigua Wind Power [WT]	C	125.0	125.0	125.0
High Sheldon Wind Farm [WT]	C	112.5	118.1	112.5
Howard Wind [WT]	C	57.4	55.4	55.4
Orangeville Wind Farm [WT]	C	94.4	93.9	93.9
Wethersfield Wind Power [WT]	C	126.0	126.0	126.0
Altona Wind Power [WT]	D	97.5	97.5	97.5
Chateaugay Wind Power [WT]	D	106.5	106.5	106.5
Clinton Wind Power [WT]	D	100.5	100.5	100.5
Ellenburg Wind Power [WT]	D	81.0	81.0	81.0
Jericho Rise Wind Farm [WT]	D	77.7	77.7	77.7
Marble River Wind [WT]	D	215.2	215.2	215.2
Hardscrabble Wind [WT]	E	74.0	74.0	74.0
Madison Wind Power [WT]	E	11.5	11.6	11.5
Maple Ridge Wind [WT01]	E	231.0	231.0	231.0
Maple Ridge Wind [WT02]	E	90.7	90.8	90.7
Munnsville Wind Power [WT]	E	34.5	34.5	34.5
Cassadaga Wind [WT]	A	126.0	126.5	126.0
Arkwright Summit Wind Farm [WT]*	A	78.4	78.4	78.4
Roaring Brook [WT]	E	79.7	79.7	79.7
<b>Total</b>		<b>2020.0</b>	<b>2023.8</b>	<b>2017.5</b>

\*This is an existing resource that became an ICAP supplier

Draft

# Attachment G1

## Wind Units Not Currently Participating in ICAP Market

Wind					
Resource	Zone	Nameplate (MW)	CRIS (MW)	Summer Capability (MW)	MARS Modeled Capacity
Erie Wind [WT]	A	15.0	0.0	0.0	0.0
Steel Wind [WT]	A	20.0	0.0	0.0	0.0
Western NY Wind Power [WT]	B	6.6	0.0	0.0	0.0
Marsh Hill Wind Farm [WT]	C	16.2	0.0	0.0	0.0
Copenhagen Wind [WT]	E	79.9	79.9	0.0	0.0
Fenner Wind [WT]	C	30.0	0.0	0.0	0.0
Total		<b>167.7</b>	<b>79.9</b>	<b>0.0</b>	<b>0.0</b>

Draft

# Attachment G2

## Solar Units Modeled

Solar				
Resource	Zone	CRIS (MW)	Summer Capability (MW)	Lesser of Summer Capability VS CRIS
Long Island Solar Farm [PV]	K	31.5	31.5	31.5
Calverton Solar Energy Center [PV]	K	22.9	22.9	22.9
Total		<b>54.4</b>	<b>54.4</b>	<b>54.4</b>

Draft

# Attachment G3

## Solar Units Not Modeled

Solar				
Resource	Zone	CRIS (MW)	Summer Capability (MW)	Lesser of Summer Capability VS CRIS
Shoreham Solar [PV]*	K	24.9	0.0	0.0
<b>Total</b>		<b>24.9</b>	<b>0.0</b>	<b>0.0</b>

\*Unit provides power on a distributed power system level

Draft

# Attachment G4

## LFG Units Modeled

LFG				
Resource	Zone	CRIS (MW)	Summer Capability (MW)	Lesser of Summer Capability VS CRIS
CHAFEE [IC]	A	6.4	6.4	6.4
Model City Energy LFGE [IC]	A	5.6	5.6	5.6
Modern LFGE [IC]	A	6.4	6.4	6.4
Hyland LFGE [IC]	B	4.8	4.8	4.8
Mill Seat [IC]	B	6.4	6.4	6.4
Broome 2 [IC]	C	2.0	2.0	2.0
Broome LFGE [IC]	C	2.1	2.1	2.1
High Acres Group [IC] (23767)	C	9.6	9.6	9.6
Ontario LFGE [IC]	C	11.2	11.2	11.2
Seneca Energy Group [IC] (23797)	C	17.6	17.6	17.6
Clinton LFGE [IC]	D	6.4	6.4	6.4
DANC LFGE [IC]	E	6.4	6.4	6.4
Madison County LFGE [IC]	E	1.6	1.6	1.6
Oneida-Herkimer LFGE [IC]	E	3.2	3.2	3.2
Colonie LFGTE [IC]	F	6.4	6.4	6.4
Fulton County Landfill [IC]	F	3.2	3.2	3.2
<b>Totals</b>		<b>99.3</b>	<b>99.3</b>	<b>99.3</b>

Draft

# Attachment G5

LFG Units Not Modeled

LFG				
Resource	Zone	CRIS (MW)	Summer Capability (MW)	Lesser of Summer Capability VS CRIS
Total				

Draft

# Assumption Matrix History

Date	Ver	Preliminary Base Case	Date	Ver	Final Base Case
1/28/21	V0.0	Preliminary assumptions without attachments.			
2/3/21	V1.0	Preliminary assumptions without attachments.			
3/3/21	V2.0	Preliminary assumptions without attachments.			
3/30/21	V3.0	Preliminary assumptions without attachments.			
5/5/21	V4.0	Added in LFU Models, Data from Draft of Gold Book A-B4 and E			
6/2/21	V5.0	Updated Attachments A-B5, D, E, and G-G5			
6/28/21	V6.0				

Draft