



NYCA IRM Requirement Study 2021-2022 Final Base Case (FBC) Model Assumptions Matrix

Maeve Conway

Resource Adequacy

ICS #238

September 29, 2020

Load Forecast Uncertainty

| # | Parameter | 2020 Model Assumptions | 2021 Model Assumptions | Basis for Recommendation | Model Change | Est. IRM Impact* |
|---|---|--|--|---|--------------|------------------|
| 1 | Peak Load Forecast (Preliminary Base Case – Parametric & Sensitivities) | 2019 Gold Book NYCA: 32,202MW ¹ NYC: 11,651 MW LI: 5,134 MW G-J: 15,911 MW | 2020 Gold Book NYCA: 32,129MW ¹ NYC: 11,460 MW LI: 5,139 MW G-J: 15,660 MW | Most recent Gold Book Forecast is used for Preliminary Base Case parametric study and sensitivity cases | N | Low (-) |
| 2 | Peak Load Forecast (Final Base Case) | October 2019 Fcst. NYCA: 32,170 MW ² NYC: 11,513 MW LI: 5,216 MW G-J: 15,776 MW | October 2020 Fcst. NYCA: 32,243 MW ² NYC: 11,103.3 MW LI: 5,282.0 MW G-J: 15,393.3 MW | Forecast based on examination of 2020 weather normalized peaks | N | TBD |
| 3 | Load Shape (Multiple Load Shape) | Bin 1: 2006 Bin 2: 2002 Bins 3-7: 2007 | Bin 1: 2006 Bin 2: 2002 Bins 3-7: 2007 | ICS Recommendation | N | None |
| 4 | Load Forecast Uncertainty (LFU)- | Zonal Model to reflect current data with input from Con Ed and LIPA. (Attachment A) | Zonal Model to reflect current data with input from Con Ed and LIPA. (Attachment A1) | Based on TO and NYISO data analyses | N | Medium (+) |
| 5 | LFU Winter | Attachment A1 | Attachment A2 | Based on TO and NYISO data analyses | N | None |

*(-) indicates a reduction in IRM while (+) indicates an increase. Range: Low < 0.5%, Medium 0.5% - 1%, High > 1%, Minimal indicates there may be some movement but within 0 to +/- 0.1%. New Capacity resources will continue to be tracked by the NYISO. The Final Base Case resource list is subject to change based on project status' by October 2020.

1 The loads associated with the BTM-NG program need to be added to these values.

2 BTM-NG loads have been incorporated into these numbers.

Generation Parameters

| # | Parameter | 2020 Model Assumptions | 2021 Model Assumptions | Basis for Recommendation | Model Change | Est. IRM Impact* |
|----|---|---|--|--|--------------|------------------|
| 6 | Existing Generating Unit Capacities | 2019 Gold Book values. Use min. (DMNC vs. CRIS) capacity value | 2020 Gold Book Values. Use min. (DMNC vs. CRIS) capacity value | Latest Gold Book publication | N | Minimal (+) |
| 7 | Proposed New Units (Thermal) and re-ratings | 1,020 MW of new Thermal resources, plus 0 MW of project related re-ratings. (Attachment B1) | 0 MW of new Thermal resources ³ , plus 56.6 MW of project related re-ratings. (Attachment B1) | Latest Gold Book publication, NYISO interconnection queue and generation notifications | N | Minimal (-) |
| 8 | Deactivations and Removals* | 1,205.9 MW of unit deactivations (Attachment B2) | 1,104 MW of unit deactivations and 192.7 MW of unit removals (Attachment B2) | Latest Gold Book publications and generator notifications | N | Low (-) |
| 9 | Forced and Partial Outage Rates | Five-years (2014-2018) GADS data for each unit represented. Those units with less than five years – use representative data. (Attachment C) | Five-year (2015-2019) GADS data for each unit represented. Those units with less than five years – use representative data. (Attachment C) | Transition Rates representing the Equivalent Forced Outage Rates (EFORd) during demand periods over the most recent five-year period | N | Minimal (-) |
| 10 | Planned Outages | Based on schedules received by the NYISO and adjusted for history | Based on schedules received by the NYISO and adjusted for history | Updated schedules | N | Low (+) |

³ Hudson Ave GT 3 is returning from IIFO. This unit was not removed from the Preliminary Base Case while in IIFO and will continue to be modeled in the Final Base Case.

*Units that did not participate in the Capacity Market have been removed from this year's study

Generation Parameters

| # | Parameter | 2020 Model Assumptions | 2021 Model Assumptions | Basis for Recommendation | Model Change | Est. IRM Impact* |
|----|--|---|---|---|--------------|------------------|
| 11 | Summer Maintenance | Nominal 50 MWs – divided equally between Zones J and K | Nominal 50 MWs – divided equally between Zones J and K | Review of most recent data | N | None |
| 12 | Combustion Turbine Derates | Derate based on temperature correction curves provided | Derate based on temperature correction curves provided | Operational history indicates the derates are in-line with manufacturer’s curves | N | None |
| 13 | Existing and Proposed New Wind Units ⁴ | 0 MW of Wind Capacity additions totaling 1,891.7 MW of qualifying wind (Attachment B3) | 126.5 MW of Wind Capacity additions totaling 1865.7 MW of qualifying wind (Attachment B3) | ICAP units based on RPS agreements, interconnection queue and ICS input. | N | Low (+) |
| 14 | Wind Shape | Actual hourly plant output over the period 2014-2018. New units will use zonal hourly averages or nearby units. | Actual hourly plant output over the period 2015-2019. New units will use zonal hourly averages or nearby units. | Program randomly selects a wind shape of hourly production from the most recent five- year period for each model iteration. | N | Low (+) |
| 15 | Existing and Proposed New Solar Resources ⁴ | Total of 51.5 MW of qualifying Solar Capacity. (Attachment B3) | 0 MW of Solar Capacity additions totaling 31.5MW of qualifying Solar Capacity. (Attachment B3) | ICAP Resources connected to Bulk Electric System | N | None |
| 16 | Solar Shape | Actual hourly plant output over the period 2014-2018. New units will use zonal hourly averages or nearby units. | Actual hourly plant output over the period 2015-2019. New units will use zonal hourly averages or nearby units. | Program randomly selects a solar shape of hourly production from the most recent five-year period for each model iteration. | N | None |

⁴Units that did not participate in the Capacity Market have been removed from this year’s study

Generation Parameters

| # | Parameter | 2020 Model Assumptions | 2021 Model Assumptions | Basis for Recommendation | Model Change | Est. IRM Impact* |
|----|---|--|--|---|--------------|------------------|
| 17 | BTM- NG Program | No new BTM NG resources (Attachment B4) | Two new BTM NG resource (Attachment B5) | Both the generation of the participating resources and the full host loads are modeled. | N | Low (-) |
| 18 | Small Hydro Resources | Actual hourly plant output over the period 2014-2018. | Actual hourly plant output over the period 2015-2019. | Program randomly selects a hydro shape of hourly production from the most recent five-year period for each model iteration. | N | Low (+) |
| 19 | Large Hydro | Probabilistic Model based on five years of GADS data (2014-2018) | Probabilistic Model based on five years of GADS data (2015-2019) | Transition Rates representing the Equivalent Forced Outage Rates (EFORd) during demand periods over the most recent five-year period. | N | Low (-) |
| 20 | Landfill Gas | Actual hourly plant output over the period 2014-2018. | Actual hourly plant output over the period 2015-2019. | Program randomly selects a LFG shape of hourly production from the most recent five-year period for each model iteration. | N | None |
| 21 | New ESR (Energy Storage Resources) ⁴ | 0 MW of new battery storage resource scheduled (see attachment B3) | 0 MW of new battery storage scheduled. 0MW of total battery storage modeled (see attachment B4) | Sensitivities on simplified model and GE software enhancement | N | None |
| 22 | Energy Limited Resources (ELR) | ELR not modeled with any duration limitation | Based upon elections made by August 1 st 2020 | Existing elections are made by August 1 st and will be incorporated into the model. | | TBD |

⁴Units that did not participate in the Capacity Market have been removed from this year's study

Transactions- Imports and Exports

| # | Parameter | 2020 Model Assumptions | 2021 Model Assumptions | Basis for Recommendation | Model Change | Est. IRM Impact* |
|----|--|--|--|--|--------------|------------------|
| 23 | Capacity Purchases | Existing Rights: PJM – 1,080 MW HQ – 1,110 MW All contracts modeled as equivalent contracts | Existing Rights: PJM – 1,080 MW HQ – 1,110 MW All contracts modeled as equivalent contracts | Grandfathered Rights, ETCNL, and other awarded long-term rights. | N | None |
| 24 | Capacity Sales | Long Term firm sales Summer 281.1 MW | Long Term firm sales Summer 265.9 MW | These are long term FERC-approved contracts. | N | Minimal (+) |
| 25 | FCM Sales from a Locality ⁵ | No sales modeled within study period | No sales modeled within study period | White paper, NYISO recommendation | N | None |
| 26 | Wheels through NYCA | 300 MW HQ to NE equivalent contract | 300 MW HQ to NE equivalent contract | Developed Model per ICS presentations | N | None |
| 27 | New UDRs (Unforced capacity Deliverability Rights) | No new UDR projects | Projects with expired CRIS will be modeled as Emergency Assistance Only: HTP | Updated to reflect modified elections for 2021 received by August 1 st 2020 | N | Minimal |
| 28 | New EDRs (External Deliverability Rights) | 0 MWs for 2020 Study | 0 MWs for 2021 Study | No new External Deliverability Rights scheduled for 2021 Study | N | None |

⁵ Final FCM sales that will materialize are unknowable at the time of the IRM study. To reflect the impact these sales have on reliability, the NYISO applies a Locality Exchange Factor in the market.

Topology

| # | Parameter | 2020 Model Assumptions | 2021 Model Assumptions | Basis for Recommendation | Model Change | Est. IRM Impact* |
|----|------------------------------|--|--|---|--------------|------------------|
| 29 | Interface Limits | Updated UPNY-SENY interface group, Jamaica ties (from J to K), and UPNY- ConEd interface. The Cedars bubble merged into the HQ bubble (Attachment E) | Removal of PJM-SENY Group Interface, PSEG-LI updates to increase Zone K Imports/Exports: Jamaica ties no longer dependent on Barrett Availability (Attachment E-E4) | Based on the most recent NYISO studies and processes, such as Operating Study, Operations Engineering Voltage Studies, Comprehensive System Planning Process, and additional analysis including interregional planning initiatives. | N | Minimal (-) |
| 30 | New Transmission | None Identified | None Identified | Based on TO provided models and NYISO's review | N | None |
| 31 | AC Cable Forced Outage Rates | All existing Cable EFORDs for NYC and LI to reflect most recent five-year history (2014-2018) | All existing Cable EFORDs for NYC and LI to reflect most recent five-year history (2015-2019) | TO provided transition rates with NYISO review. | N | Low (-) |
| 32 | UDR Line Unavailability | Five year history of forced outages (2014-2018) | Five year history of forced outages (2015-2019) | NYISO/TO Review | N | Low (-) |

Emergency Operating Procedures

| # | Parameter | 2020 Model Assumptions | 2021 Model Assumptions | Basis for Recommendation | Model Change | Est. IRM Impact* |
|----|------------------------|---|--|--|--------------|------------------|
| 33 | Special Case Resources | July 2019 –1,282 MW based on registrations and modeled as 873 MW of effective capacity. Monthly variation based on historical experience. | July 2020 –1195 MW based on registrations and modeled as 822 MW of effective capacity. Monthly variation based on historical experience. | SCRs sold for the program discounted to historic availability. Summer values calculated from July 2020 registrations. Performance calculation updated per ICS presentations on SCR performance. (Attachment F) | N | Low (-) |
| 34 | Other EOPs | 692 MW of non-SCR/non-EDRP resources (Attachment D) | 844.4 MW of non-SCR/non-EDRP resources ⁶ (Attachment D) | Based on TO information, measured data, and NYISO forecasts | N | Low (-) |
| 35 | EOP Structure | 12 EOP Steps Modeled | 10 EOP steps modeled | Based on agreement with ICS, step 1 and 2 separated, step 3 removed | Y | Minimal (-) |

⁶NYISO proposes to model “General Public Appeals” MW using the same value as the 2020 IRM study unless a Transmission Owner presents analysis supporting an alternate MW value.

External Control Areas

| # | Parameter | 2020 Model Assumptions | 2021 Model Assumptions | Basis for Recommendation | Model Change | Est. IRM Impact* |
|----|-----------------------------------|--|--|---|--------------|------------------|
| 36 | PJM | Load and Capacity data provided by ISONE/NPCC CP-8 Data may be adjusted per NYSRC Policy 5 (Attachment E) | Load and Capacity data will be provided by ISONE/NPCC CP-8 Data may be adjusted per NYSRC Policy 5 (Attachment E) | Initial Review performed by the NPCC CP-8 WG prior to Policy 5 changes | N | Low (-) |
| 37 | ISONE, Quebec, IESO | Load and Capacity data provided by ISONE/NPCC CP-8 Data adjusted per NYSRC Policy 5 (Attachment E) | Load and Capacity data will be provided by ISONE/NPCC CP-8 Data adjusted per NYSRC Policy 5 (Attachment E) | Initial Review performed by the NPCC CP-8 WG prior to Policy 5 changes | N | Low (-) |
| 38 | External Adjustments per Policy 5 | If needed, add load to externals proportional to existing excess capacity | If needed, add load to externals proportional to existing excess capacity | White paper on external Control Area adjustments | N | Low (-) |
| 39 | Reserve Sharing | All NPCC Control Areas indicate that they will initially share reserves equally among all members and then among non-members | All NPCC Control Areas indicate that they will initially share reserves equally among all members and then among non-members | Per NPCC CP-8 WG | N | None |
| 40 | Emergency Assistance | Statewide Limit of 3,500 MW of emergency assistance allowed from neighbors. | Statewide Limit of 3,500 MW of emergency assistance allowed from neighbors. | White Paper on Modeling of Emergency Assistance for NYCA in IRM studies | N | None |

Miscellaneous


| # | Parameter | 2020 Model Assumptions | 2021 Model Assumptions | Basis for Recommendation | Model Change | Est. IRM Impact* |
|----|---------------------------|---|---------------------------------------|--|--------------|------------------|
| 41 | MARS Model Version | Version 3.22.6 | 3.31.1546 | Per testing and ICS recommendation | Y | None |
| 42 | Environmental Initiatives | Proposed rules would not take effect until after the summer of 2020 | No new rules for 2021 Capability Year | Review of existing regulations and rules | N | None |

Attachments

Attachment A1


NYCA Summer Load Forecast Uncertainty Model: 2021 and 2020

Load Forecast 2021



| Bin | Probability | A-E | F&G | H&I | J | K |
|-------------|-------------|---------|---------|---------|---------|---------|
| B1 | 0.62% | 116.02% | 117.17% | 113.56% | 110.73% | 116.38% |
| B2 | 6.06% | 111.11% | 111.70% | 109.46% | 107.33% | 111.97% |
| B3 | 24.17% | 105.70% | 105.70% | 104.06% | 102.89% | 105.98% |
| B4 | 38.30% | 100.00% | 99.36% | 97.68% | 97.67% | 100.00% |
| B5 | 24.17% | 94.22% | 92.89% | 90.66% | 91.91% | 91.88% |
| B6 | 6.06% | 88.58% | 86.48% | 83.35% | 85.86% | 82.34% |
| B7 | 0.62% | 83.28% | 80.33% | 76.06% | 79.79% | 75.52% |
| Delta | | A-E | F&G | H&I | J | K |
| B1 - B4 | 16.02% | 17.80% | 15.88% | 13.06% | 16.38% | |
| B4 - B7 | 16.72% | 19.04% | 21.62% | 17.88% | 24.48% | |
| Total Range | 32.74% | 36.84% | 37.50% | 30.94% | 40.87% | |


Load Forecast 2020



| Bin | Probability | A-E | F&G | H&I | J | K |
|-------------|-------------|---------|---------|---------|---------|---------|
| B1 | 0.62% | 115.39% | 116.28% | 113.11% | 109.38% | 118.09% |
| B2 | 6.06% | 110.57% | 111.25% | 108.90% | 106.28% | 112.92% |
| B3 | 24.17% | 105.39% | 105.52% | 103.72% | 102.45% | 106.93% |
| B4 | 38.30% | 100.00% | 99.31% | 97.82% | 98.04% | 100.00% |
| B5 | 24.17% | 94.58% | 92.86% | 91.43% | 93.24% | 92.36% |
| B6 | 6.06% | 89.29% | 86.39% | 84.79% | 88.19% | 84.73% |
| B7 | 0.62% | 84.30% | 80.12% | 78.15% | 83.07% | 78.16% |
| Delta | | A-E | F&G | H&I | J | K |
| B1 - B4 | 15.39% | 16.97% | 15.30% | 11.34% | 18.09% | |
| B4 - B7 | 15.70% | 19.19% | 19.66% | 14.97% | 21.84% | |
| Total Range | 31.09% | 36.16% | 34.96% | 26.31% | 39.93% | |

Attachment A2

NYCA Winter Load Forecast Uncertainty Model: 2020 and 2021



| Zones(s): NYCA (Winter) | | | | | |
|-------------------------|-------------|-------|--------|------------|------------|
| Bin | Probability | Wthr | MW | LFU (2021) | LFU (2020) |
| B1 | 0.62% | 53.75 | 25,593 | 112.22% | 111.80% |
| B2 | 6.06% | 47.98 | 24,577 | 107.77% | 107.52% |
| B3 | 24.17% | 42.20 | 23,648 | 103.69% | 103.59% |
| B4 | 38.30% | 36.43 | 22,806 | 100.00% | 100.00% |
| B5 | 24.17% | 30.66 | 22,051 | 96.69% | 96.75% |
| B6 | 6.06% | 24.89 | 21,383 | 93.76% | 93.85% |
| B7 | 0.62% | 19.12 | 20,802 | 91.22% | 91.28% |
| Design | | 36.43 | 22,806 | | |

Attachment B1

New Thermal Units and Unit Re-Ratings⁷

| Proposed New Thermal Units and Unit Re-ratings (summer ratings) | | | | | |
|---|------|----------------------|---------------------|-------------------------|----------------------|
| Project or Generator Name | Zone | 2020 MARS Model (MW) | 2020 Gold Book (MW) | New or Incremental (MW) | 2021 MARS Model (MW) |
| New Units | | | | | |
| Sithe Independence | C | 956.4 | 956.4 | 56.6 | 1013.0 |
| Total New Units | | 956.4 | 956.4 | 56.6 | 1013.0 |

⁷ Unit re-ratings are for generation facilities that have undergone uprate projects.

Attachment B2

Deactivations and Removals

| Announced Unit Deactivations since 2020 IRM Study | | |
|---|------|--------------|
| Generator Name | Zone | CRIS (MW) |
| West Babylon 4 | K | 49.0 |
| Indian Point 3 | H | 1,040.4 |
| Glenwood GT1 | K | 14.6 |
| Total Deactivations | | 1,104 |

Attachment B2

Deactivations and Removals⁴

| Unit Removal since 2020 IRM Study | | | |
|-----------------------------------|----------------|------|----------|
| Generator Name | Type | Zone | CRIS(MW) |
| Arkwright Summit Wind Farm | Wind | A | 78.4 |
| Copenhagen Wind | Wind | E | 79.9 |
| Shoreham Solar | Solar | K | 24.9 |
| Montauk Battery Storage | Energy Storage | K | 5.0 |
| Albany LFGE ⁸ | Land Fill Gas | F | 4.5 |
| Total Removals | | | 192.7 |

⁴Units that did not participate in the Capacity Market have been removed from this year's study

⁸Albany LFGE unit removed from 2021 IRM Model Assumptions due to IIFO status

Attachment B3

New Intermittent Resources

| Wind | | | | |
|---------------------|------|-----------|------------------------|-------------------------------------|
| Resource | Zone | CRIS (MW) | Summer Capability (MW) | Lesser of Summer Capability VS Cris |
| New Wind Units | | | | |
| Cassadaga Wind, LLC | A | 126.0 | 126.5 | 126.0 |
| Total | | 126.0 | 126.5 | 126.0 |

Attachment B3

New Intermittent Resources

| Solar | | | | |
|------------------------|------|-----------|------------------------|-------------------------------------|
| Resource | Zone | CRIS (MW) | Summer Capability (MW) | Lesser of Summer Capability VS Cris |
| New Solar Units | | | | |
| TotalNewSolar | N/A | N/A | N/A | N/A |
| Total New Intermittent | | 126.0 | 126.5 | 126.0 |

Attachment B4

New Energy Storage Resources

| Energy Storage | | | | |
|---------------------------------|------|-----------|------------------------|-------------------------------------|
| Resource | Zone | CRIS (MW) | Summer Capability (MW) | Lesser of Summer Capability VS CRIS |
| New Battery Units | | | | |
| | | | | |
| | | | | |
| Total New Energy Storage | N/A | N/A | N/A | N/A |

Attachment B5

Resources in the Behind the Meter Net Generation Program (BTM-NG)

| Attachment B4 -Units in the Behind the Meter Net Generation Program* | | | |
|--|------|----------------------------------|---|
| Generator Name | Zone | Resource Value (MW) ⁹ | Peak Load Adjustment (MW) ¹⁰ |
| Existing: | | | |
| Stony Brook | K | 36.2 | 42.0 |
| Greenidge 4 | C | 103.4 | 32.0 |
| New: | | | |
| Lyons Falls Hydro | E | 8.0 | 2.7 |
| | J | | 21.3 |
| Total BTM-NG | | | 98.0 |


*The IRM study independently models the generation and load components of BTM:NG Resources

⁹Based on adjusted Dependable Maximum Gross Capability (DMGC) value

¹⁰Based on Average Coincident Host Load (ACHL)

Attachment C

NYCA Five Year Derating Factors



Attachment D


Emergency Operating Procedures

| Step | Procedure | 2020 MW Value | 2021 MW Value |
|------|---|--|---|
| 1 | Special Case Resources –Load, Gen | 1,282 MW Enrolled/ 873 MW modeled | 1,195 MW Enrolled/ 822 MW modeled |
| 2 | 5% manual voltage Reduction | 57 MW | 59.64 MW |
| 3 | Thirty-minute reserve to zero | 655 MW | 655 MW |
| 4 | 5% remote voltage reduction | 347 MW | 445.42 MW |
| 5 | Voluntary industrial curtailment | 207 MW | 259.36 MW |
| 6 | General Public Appeals | 80 MW | 80 MW |
| 7 | Emergency Purchases | Varies | Varies |
| 8 | Ten-minute reserves to zero | 1,310 MW | 1,310 MW |
| 9 | Customer disconnections | As needed | As needed |
| 10 | Adjustment used if IRM is lower than technical study margin | As needed | As needed |

Attachment E

IRM Topology

Draft Topology for 2021 IRM Study



For Internal Discussions Only

Notes


1. PJM to NY emergency assistance (EA) assumption for calculating the PJM-NY Western ties, PJM-G Group, and ABC Line Group flow distribution limit: 1500MW
2. NYCA EA simultaneous import limit: 3,500 MW
3. External areas representation based upon information received from the NPCC CP-8 WG

Legend

- Interface
 - Unidirectional Interface
 - Interface w/ Dynamic Ratings
 - Interface Group
 - Interface Group w/ Dynamic Ratings
 - Monitoring Interface Group
 - NYCA EA Interface Group Marker
 - 'Dummy Bubble' i.e. no load
- NOTE: An Interface is considered to not have a MW limitation if no number is specified

Attachment E1

ISO-NE 14 Bubble Model



Attachment E2

Group Limits

| NYCA Group Interfaces | | | | |
|-----------------------|----------|---------|----------|---------|
| | 2021 IRM | | 2020 IRM | |
| | Forward | Reverse | Forward | Reverse |
| UPNYSENY | 5250 | 99999 | 5600 | 99999 |
| UPNYSNY2 | N/A | N/A | 6950 | 99999 |
| CE_GRP | N/A | N/A | 5000 | 3400 |
| CPV&E_G | N/A | N/A | 2275 | 99999 |
| LI_SUM | 1593 | 104 | 1593 | 104 |
| LI_WEST | 99999 | 134 | 99999 | 18 |
| DSY49Y50 | 5643 | 1999 | 5600 | 1999 |
| A_EAST | 1850 | 99999 | 1850 | 99999 |

Attachment E3

Interface Limits

| NYCA Interface Limits | | | | |
|-----------------------|----------|---------|----------|---------|
| | 2021 IRM | | 2020 IRM | |
| | Forward | Reverse | Forward | Reverse |
| DYSINGER EAST | 1700 | 1999 | 1700 | 1999 |
| WEST CENTRAL | 1300 | 1600 | 1300 | 1600 |
| VOLNEY EAST | 5650 | 1999 | 5650 | 1999 |
| MOSES_SOUTH | 2650 | 1600 | 2650 | 1600 |
| CENTRAL EAST | 3100 | 1999 | 3100 | 1999 |
| MARCY SOUTH | 2250 | 1600 | 2275 | 1600 |
| CAPITAL HUDSON VALLEY | 3475 | 1999 | 3475 | 1999 |
| UPNY - CONED | 7000 | 1999 | 6000 | 1999 |
| MILLWOOD SOUTH | 8450 | 1999 | 8450 | 1999 |
| DUNWOODIE SOUTH | 4350 | 1999 | 4400 | 1999 |
| CONED LILCO | 320 | 505 | 320 | 505 |
| AREA I TO AREA K | 1293 | 515 | 1293 | 342 |

Attachment E4

Dynamic Limits

| Central East Voltage Limits, Oswego Complex Units | | | | | | | | |
|---|--|---------|---------|---------|--|---------|---------|---------|
| Dependency | IRM2021 | | | | IRM2020 | | | |
| | 9MILP1, 9MILP2, FPNUC1, STHIND, OS05, OS06 | | | | 9MILP1, 9MILP2, FPNUC1, STHIND, OS05, OS06 | | | |
| Units Available | E_TO_F | | E_TO_FG | | E_TO_F | | E_TO_FG | |
| | Forward | Reverse | Forward | Reverse | Forward | Reverse | Forward | Reverse |
| 6 | 3100 | 1999 | 5000 | 3400 | 3100 | 1999 | 5000 | 3400 |
| 5 | 3050 | 1999 | 4925 | 3400 | 3050 | 1999 | 4925 | 3400 |
| 4 | 2990 | 1999 | 4840 | 3400 | 2990 | 1999 | 4840 | 3400 |
| 3 | 2885 | 1999 | 4685 | 3400 | 2885 | 1999 | 4685 | 3400 |
| 2 | 2770 | 1999 | 4510 | 3400 | 2770 | 1999 | 4510 | 3400 |
| All Other Conditions | 2645 | 1999 | 4310 | 3400 | 2645 | 1999 | 4310 | 3400 |

| LI_NE: Northport Units 1-4 | | | | |
|----------------------------|--------------|--------------|--------------|--------------|
| Units Available | IRM2021 | | IRM2020 | |
| | Norwalk to K | K to Norwalk | Norwalk to K | K to Norwalk |
| 4 | 260 | 414 | 260 | 414 |
| All Other Conditions | 404 | 414 | 404 | 414 |

Dynamic Limits Continued

| ConEd-LIPA: Barrett Units 1 & 2 | | | | |
|---------------------------------|---------|---------|---------|---------|
| Units Available | IRM2021 | | IRM2020 | |
| | IJ to K | K to IJ | IJ to K | K to IJ |
| 2 | 1613 | 220 | 1593 | 104 |
| 1 | 1613 | 200 | 1593 | 74 |
| 0 | 1613 | 130 | 1593 | 0 |

| Staten Island Import Limits, AK and Linden CoGen Units | | | | | | | |
|--|------|---------|---------|---------|---------|---------|---------|
| | | | | IRM2021 | | IRM2020 | |
| Unit Availability | | | | J_TO_J3 | | J_TO_J3 | |
| AK02 | AK03 | LINCOG1 | LINCOG2 | Forward | Reverse | Forward | Reverse |
| A | A | A | A | 315 | 200 | 315 | 200 |
| U | A | A | A | 315 | 500 | 315 | 500 |
| A | U | A | A | 315 | 700 | 315 | 700 |
| A | A | U | A | 315 | 500 | 315 | 500 |
| A | A | A | U | 315 | 500 | 315 | 500 |
| All Other Conditions | | | | 315 | 815 | 315 | 815 |

Dynamic Limits Continued

| UPNYSENY | | | | | |
|----------------------|---------|--------|---------|-------------------------|---------|
| Units Available | | | | | |
| CPV | Cricket | Athens | IRM2021 | IRM2021 (2020 Topology) | IRM2020 |
| 2 | 3 | 3 | 5250 | 5260 | 6950 |
| 2 | 3 | 2 | 5100 | 5060 | 6750 |
| 1 | 3 | 3 | 5350 | 5345 | 6700 |
| 2 | 2 | 3 | 5200 | 5200 | 6550 |
| 2 | 1 | 3 | 5150 | 5140 | 6150 |
| 1 | 1 | 3 | 5250 | 5275 | 5950 |
| 2 | 0 | 3 | 5100 | 5130 | 5800 |
| All Other Conditions | | | 5350 | | 6600 |

| E to G | | |
|-----------------|---------|---------|
| Units Available | | |
| CPV | IRM2021 | IRM2020 |
| 2 | 1750 | N/A |
| 1 | 2000 | N/A |
| 0 | 2250 | N/A |

Attachment F

SCR Determinations 2021 and 2020 IRM Studies

| SCR Performance for 2021 IRM Study | | | | | | |
|------------------------------------|-------------------------|------------------------------|---------------------------------|---------------|--------------------------------|--------------|
| Super Zones | Enrollments (July 2020) | Forecast (2021) ¹ | Performance Factor ² | UCAP (2021) | Adjustment Factor ³ | Model Value |
| A-F | 622.8 | 622.8 | 0.862 | 537.2 | 0.949 | 509.5 |
| G-I | 102.0 | 102.0 | 0.747 | 76.2 | 0.851 | 64.9 |
| J | 427.3 | 427.3 | 0.693 | 296.2 | 0.752 | 222.7 |
| K | 43.0 | 43.0 | 0.706 | 30.3 | 0.821 | 24.9 |
| Totals | 1195.1 | 1195.1 | | 940.0 | | 822.1 |
| | | | | | Overall Performance = 68.8% | |
| SCR Performance for 2020 IRM Study | | | | | | |
| Super Zones | Enrollments (July 2019) | Forecast (2020) | Performance Factor | UCAP (2020) | Adjustment Factor | Model Value |
| A-F | 629.3 | 629.3 | 0.867 | 545.9 | 0.942 | 514.3 |
| G-I | 125.5 | 125.5 | 0.756 | 94.9 | 0.851 | 80.8 |
| J | 478.9 | 478.9 | 0.691 | 330.8 | 0.753 | 249.0 |
| K | 48.2 | 48.2 | 0.718 | 34.6 | 0.823 | 28.5 |
| Totals | 1281.9 | 1281.9 | | 1006.1 | | 872.5 |
| | | | | | Overall Performance = 68.1% | |

1. These values represent no growth from July 2020 ICAP based enrollments.

2. Performance Factor based on ACL methodology

3. The SCR Adjustment factor captures two different performance derates; 1) Calculated Translation Factor (TF) between ACL and CBL values, and the Fatigue Factor (FF=1.00)

Attachment G

Wind Units Modeled

| Wind | | | | |
|------------------------------|------|----------------|------------------------|-------------------------------------|
| Resource | Zone | CRIS (MW) | Summer Capability (MW) | Lesser of Summer Capability VS CRIS |
| Bliss Wind Power [WT] | A | 100.5 | 100.5 | 100.5 |
| Canandaigua Wind Power [WT] | C | 125.0 | 125.0 | 125.0 |
| High Sheldon Wind Farm [WT] | C | 112.5 | 118.1 | 112.5 |
| Howard Wind [WT] | C | 57.4 | 55.4 | 55.4 |
| Orangeville Wind Farm [WT] | C | 94.4 | 93.9 | 93.9 |
| Wethersfield Wind Power [WT] | C | 126.0 | 126.0 | 126.0 |
| Altona Wind Power [WT] | D | 97.5 | 97.5 | 97.5 |
| Chateaugay Wind Power [WT] | D | 106.5 | 106.5 | 106.5 |
| Clinton Wind Power [WT] | D | 100.5 | 100.5 | 100.5 |
| Ellenburg Wind Power [WT] | D | 81.0 | 81.0 | 81.0 |
| Jericho Rise Wind Farm [WT] | D | 77.7 | 77.7 | 77.7 |
| Marble River Wind [WT] | D | 215.2 | 215.2 | 215.2 |
| Hardscrabble Wind [WT] | E | 74.0 | 74.0 | 74.0 |
| Madison Wind Power [WT] | E | 11.5 | 11.6 | 11.5 |
| Maple Ridge Wind [WT01] | E | 231.0 | 231.0 | 231.0 |
| Maple Ridge Wind [WT02] | E | 90.7 | 90.8 | 90.7 |
| Munnsville Wind Power [WT] | E | 34.5 | 34.5 | 34.5 |
| Cassadaga Wind [WT] | A | 126.0 | 126.5 | 126.0 |
| Total | | 1,861.9 | 1,865.7 | 1,859.4 |

Attachment G1

Wind Units Not Modeled

| Wind | | | | |
|---------------------------------|------|--------------|------------------------|-------------------------------------|
| Resource | Zone | CRIS (MW) | Summer Capability (MW) | Lesser of Summer Capability VS CRIS |
| Erie Wind [WT] | A | 0.0 | 0.0 | 0.0 |
| Steel Wind [WT] | A | 0.0 | 0.0 | 0.0 |
| Arkwright Summit Wind Farm [WT] | A | 78.4 | 0.0 | 0.0 |
| Western NY Wind Power [WT] | B | 0.0 | 0.0 | 0.0 |
| Fenner Wind Power [WT] | C | 0.0 | 0.0 | 0.0 |
| Marsh Hill Wind Farm [WT] | C | 0.0 | 0.0 | 0.0 |
| Copenhagen Wind [WT] | E | 79.9 | 0.0 | 0.0 |
| Total | | 158.3 | 0.0 | 0.0 |

Attachment G2

Solar Units Modeled

| Solar | | | | |
|-----------------------------|------|-------------|------------------------|-------------------------------------|
| Resource | Zone | CRIS (MW) | Summer Capability (MW) | Lesser of Summer Capability VS CRIS |
| Long Island Solar Farm [PV] | K | 31.5 | 31.5 | 31.5 |
| Total | | 31.5 | 31.5 | 31.5 |

Attachment G3

Solar Units Not Modeled

| Solar | | | | |
|---------------------|------|-------------|------------------------|-------------------------------------|
| Resource | Zone | CRIS (MW) | Summer Capability (MW) | Lesser of Summer Capability VS CRIS |
| Shoreham Solar [PV] | K | 24.9 | 0.0 | 0.0 |
| Total | | 24.9 | 0.0 | 0.0 |

Attachment G4

LFG Units Modeled

| LFG | | | | |
|----------------------------------|------|-------------|------------------------|-------------------------------------|
| Resource | Zone | CRIS (MW) | Summer Capability (MW) | Lesser of Summer Capability VS CRIS |
| CHAFEE [IC] | A | 6.4 | 6.4 | 6.4 |
| Model City Energy LFG [IC] | A | 5.6 | 5.6 | 5.6 |
| Modern LFG [IC] | A | 6.4 | 6.4 | 6.4 |
| Hyland LFG [IC] | B | 4.8 | 4.8 | 4.8 |
| Mill Seat [IC] | B | 6.4 | 6.4 | 6.4 |
| Broome 2 [IC] | C | 2.0 | 2.0 | 2.0 |
| Broome LFG [IC] | C | 2.1 | 2.1 | 2.1 |
| High Acres Group [IC] (23767) | C | 9.6 | 9.6 | 9.6 |
| Ontario LFG [IC] | C | 7.6 | 11.2 | 7.6 |
| Seneca Energy Group [IC] (23797) | C | 17.6 | 17.6 | 17.6 |
| Clinton LFG [IC] | D | 6.4 | 6.4 | 6.4 |
| DANC LFG [IC] | E | 6.4 | 6.4 | 6.4 |
| Madison County LFG [IC] | E | 1.6 | 1.6 | 1.6 |
| Oneida-Herkimer LFG [IC] | E | 3.2 | 3.2 | 3.2 |
| Colonie LFGTE [IC] | F | 6.4 | 6.4 | 6.4 |
| Totals | | 92.5 | 96.1 | 92.5 |

Attachment G5

LFG Units Not Modeled

| LFG | | | | |
|--------------------------|------|-------------|------------------------|-------------------------------------|
| Resource | Zone | CRIS (MW) | Summer Capability (MW) | Lesser of Summer Capability VS CRIS |
| Monroe Livingston [IC] | B | 2.4 | 0.0 | 0.0 |
| Steuben County LFGE [IC] | C | 3.2 | 0.0 | 0.0 |
| Albany LFGE [IC] | F | 4.5 | 5.6 | 4.5 |
| Total | | 10.1 | 5.6 | 4.5 |

Assumption Matrix History

| Date | Ver | Preliminary Base Case | Date | Ver | Final Base Case |
|---------|------|--|---------|-------|---|
| 1/17/19 | V0.0 | Preliminary assumptions without attachments. | 9/2/20 | V9.0 | Hudson Ave GT3 added, ELR line added |
| 2/21/20 | V1.0 | Preliminary assumptions without attachments. | | | |
| 3/19/20 | V2.0 | Preliminary assumptions without attachments. | | | |
| 4/15/20 | V3.0 | Added in LFU Models, Data from Draft of Gold Book A-B4 and E | 9/16/20 | V10.0 | Hudson Ave GT3 modified |
| 5/27/20 | V4.0 | Final Gold Book Data Update, Update Units, Update Topology | 9/29/20 | V11.0 | Albany LFG IIFO removed, Fall Load Forecast applied |
| 6/23/20 | V5.0 | Change G-J Load forecast number, add ISO NE topology diagram, add Sithe Independence to rerate | | | |
| 6/29/20 | V6.0 | Update to EOP steps from 9 to 10, table added for removed units, Wind units total MW adjusted | | | |
| 8/5/20 | V7.0 | Update SCRs, EOPs, Unit Table, IRM impact value per change | | | |
| 8/17/20 | V8.0 | Update to SCR table, update to IRM impact for externals | | | |

Our mission, in collaboration with our stakeholders, is to serve the public interest and provide benefit to consumers by:

- Maintaining and enhancing regional reliability
- Operating open, fair and competitive wholesale electricity markets
- Planning the power system for the future
- Providing factual information to policymakers, stakeholders and investors in the power system



Questions?