

# Alternative Methods for Determining LCRs

**Rana Mukerji**

Senior Vice President, Market Structures

**Zachary Stines**

Associate Market Design Specialist, ICAP Market Design

**NYSRC – Executive Committee**

August 11, 2017



**DRAFT – FOR DISCUSSION PURPOSES ONLY**

©COPYRIGHT NYISO 2017. ALL RIGHTS RESERVED

# Agenda

- **Methodology**
- **Initial Sensitivities**
  - Stability
  - Reliability Metrics for Individual Zones
- **Next Steps**
  - Phase 2: Final Refined Methodology
  - Phase 3: Market Simulations
- **Questions**

# Alternative Method for Determining LCRs: Economic Optimization

DRAFT – FOR DISCUSSION PURPOSES ONLY  
© COPYRIGHT NYISO 2017. ALL RIGHTS RESERVED.



# Least Cost Optimization

*minimize* Total Cost of Capacity in NYCA

*subject to:*

$LOLE \leq 0.1$

**IRM = 18.0% (NYSRC Approved IRM)**

- Optimizes the LCRs of the localities while maintaining the NYSRC approved IRM
- Cost defined by Unit Net CONE used to develop each ICAP Demand Curves
- Optimization uses a Linear Approximation as computational method
  - Iterative process between Linear Program wrapper and MARS

# Objective Function

$$\text{Cost of Capacity Procurement} = \sum_x Q_x \cdot P_x(Q_x) + \sum_y Q_y \cdot P_y \left( Q_y + \sum_z Q_z \right) + \left[ (\text{Reserve Margin} \cdot \text{Pool Coincident Peak}) - \left( \sum_x Q_x + \sum_y Q_y \right) \right] \cdot P_{ROP}(Q_{Pool})$$

X = Single Load Zone that is a Locality (i.e., Zone J and Zone K)

Y = Locality minus any Single Load Zone Locality located within it (i.e., GHI)

Z = Single Locality located within a larger Locality (i.e., Zone J)

ROP = Rest of Pool (i.e., Rest of State)

# Base Case

**DRAFT – FOR DISCUSSION PURPOSES ONLY**  
© COPYRIGHT NYISO 2017. ALL RIGHTS RESERVED.



# Optimized Preliminary Base Case

Scenario	Zone J LCR (%)	Zone K LCR (%)	G-J LCR (%)	Cost (million)
Base Case (Current LCR)	81.4	103.2	91.3	\$4,407.7
Optimized Preliminary Base Case (May 11, 2017)	77.5	107.0	91.0	\$4,366.4
Final Optimized Base Case	~78.5	~105.5	~91.0	
Final Optimized Base Case with Transmission Security				

# Case Descriptions

- **Current LCR Methodology Base Case**
  - The NYISO final 2017-2018 Capability Year LCR base case was solved to a LOLE of 0.1 days/year with the NYSRC approved IRM of 18.0%
  - The resulting base case will allow for a direct comparison with the optimized methodology and the simplified current LCR methodology
- **Optimized Preliminary Base Case**
  - Optimized preliminary base case uses the final 2017-2018 Capability Year LCR base case solved to a LOLE Of 0.1 days/year with the NYSRC approved IRM of 18.0%
- **Final Optimized Base Case**
  - Final base case is currently being developed and incorporates small refinements to the optimization
- **Final Optimized Base Case with Transmission Security**
  - Final base case with transmission security limits applied to the LCRs



# Initial Sensitivities


**DRAFT – FOR DISCUSSION PURPOSES ONLY**  
© COPYRIGHT NYISO 2017. ALL RIGHTS RESERVED.




# Initial Sensitivities

- **Entry/exit of Capacity**
  - Evaluate stability as generation enters and exits
- **Changes in Net CONE**
  - Evaluate impact of changes in cost
- **Changes in Transmission Capability**
  - Evaluate impact of an increase in transmission


# Changes to Capacity in GHJ: Zone J LCR



# Changes to Capacity in GHIJ: Zone K LCR



# Changes to Capacity in GHIJ: GHIJ LCR





## **Changes in Capacity: Conclusions**

- **The optimized methodology reduces volatility in comparison to the current LCR methodology when there are changes in capacity**

## Changes in Net CONE: Conclusions

- The sensitivities tested extreme changes (i.e., between 30% and 55% change in Net CONE)
- The optimized LCR responded intuitively to the changes in Net CONE (i.e., increase in Net CONE in most instances causes a reduction in LCR)

# Changes in Transmission: Conclusions

- **The conclusions based on the analysis presently are:**
  - UPNY-SENY reduces amount of optimal capacity required in the G-J Locality, but does not impact the amount required in Zone J (stand alone)
  - The Zone J LCR is minimized to its optimal level in the Base Case (as a result of constraints south of UPNY-SENY)



# Reliability Analysis


**DRAFT – FOR DISCUSSION PURPOSES ONLY**  
© COPYRIGHT NYISO 2017. ALL RIGHTS RESERVED.




## Reliability Metrics

- NYSRC – ICS requested the NYISO provide the LOLE and loss of energy expectation results at the zonal level for the optimized preliminary base case
- It was also requested that the NYISO indicate the frequency of EOP steps in the preliminary optimization base case


## Zonal Loss of Load Expectation (Days/Year)




## Zonal Loss of Load Expectation (Hours/Year)



## Zonal Loss of Energy Expectation (MWh/Year)



Number of Days per Year at Each EOP Step for NYCA



# Transmission Security

**DRAFT – FOR DISCUSSION PURPOSES ONLY**  
© COPYRIGHT NYISO 2017. ALL RIGHTS RESERVED.



# Transmission Security

- NYISO is working to develop transmission security limits for the Localities
- Transmission security limits would be incorporated as a constraint within the optimization and would ensure the optimized LCRs would not violate any transmission security floor
- Evaluation of the impact of the transmission security limits on the optimization and discussion on this process and analysis will be provided at future meetings



# Next Steps

DRAFT – FOR DISCUSSION PURPOSES ONLY  
© COPYRIGHT NYISO 2017. ALL RIGHTS RESERVED.





## **Stage 2: Refine Methodology**

- Final methodology is currently being completed
- Present evaluation of transmission security

## Stage 3: Market Simulations

- **Goal: Simulate additional market scenarios to demonstrate performance of methodology**
  - Perform sensitivities with multiple changes to the system
  - Evaluate how the process would be performed with full Tan45 followed by optimization

## Other Next Steps

- The NYISO will consider input received during today's NYSRC-EC meeting
- Additional comments sent to [zstines@nyiso.com](mailto:zstines@nyiso.com) will be considered

# 2017 Project Development

<u>Stage</u>	<u>Objective</u>	<u>Specific Topics:</u>
<b>Proof of Concept</b>	Demonstrate alternative methodology in relation to guiding principles ( <i>i.e.</i> , least cost, stability, robust, predictability)	Generation +/- Unit net CONE +/- Transmission +/-
<b>Refine Methodology</b>	Modify the alternative method to ensure that all aspects have a purpose and are being performed as a result of sound market and engineering principles	Unit net CONE curves Potential Bounds Modeling methodology
<b>Market Simulations</b>	Simulate realistic market situations to demonstrate performance of methodology	Changes in resources Topological changes Locality configurations
<b>Defining Process</b>	Develop a process for the methodology that ensures guiding principles are being achieved over time	Develop process of method Process timeline Transition methods
<b>Demonstrating Market Benefits</b>	Demonstrate the methodology results in market benefits and resolve any issues that arise from its implementation	Consumer impact Multiyear simulation Cost allocation
<b>Final Market Design</b>	Summarize all findings and develop a final market design for implementation	Develop final market design

# Questions?

**DRAFT – FOR DISCUSSION PURPOSES ONLY**  
© COPYRIGHT NYISO 2017. ALL RIGHTS RESERVED.



## The Mission of the New York Independent System Operator, in collaboration with its stakeholders, is to serve the public interest and provide benefits to consumers by:

- Maintaining and enhancing regional reliability
- Operating open, fair and competitive wholesale electricity markets
- Planning the power system for the future
- Providing factual information to policy makers, stakeholders and investors in the power system



[www.nyiso.com](http://www.nyiso.com)



DRAFT - FOR DISCUSSION PURPOSES ONLY

©COPYRIGHT NYISO 2017. ALL RIGHTS RESERVED


# Appendix

**DRAFT – FOR DISCUSSION PURPOSES ONLY**  
© COPYRIGHT NYISO 2017. ALL RIGHTS RESERVED.






# Changes to Capacity in J: Zone J LCR




# Changes to Capacity in J: Zone K LCR


Capacity Added and Removed from Zone J




# Changes to Capacity in J: GHIJ LCR



# Changes to Capacity in K: Zone J LCR



# Changes to Capacity in K: Zone K LCR



# Changes to Capacity in K: GHIJ LCR

