

NEW YORK STATE RELIABILITY COUNCIL
RRS #215 Status Report for EC #219 - Friday July 14, 2017

- **PRRs under development**
 - PRR 128 - Definition of Bulk Power System
 - Discussed treatment of radial elements
 - Tabled pending NPCC A-10 revision
- **PRRs Posted for Comment**
 - PRR 137 D.2 (R1, R2, R3) Under-Frequency Load Shedding
 - Revision to conform with NERC & NPCC
 - Recommend retirement since NERC & NPCC are more stringent/specific
 - Recommend EC approval to post for comments
- **PRRs for Final Approval**
 - None
- **Other RRS matters**
 - Reviewed ConEd's lessons learned from Black Start testing per new G.4 - System Restoration procedures (Executive Session).
 - Action: Continue monitoring
 - Reviewed NYC Council's proposed schedule change banning #4 oil by 2025 instead of 2030. Discussed potential LOGMOB impact.
 - Action: Await EC direction
 - Discussed ISO-NE's proposal to review NPCC regional criteria to determine if NERC Standards are more stringent/specific.
 - Action: Continue monitoring