

**NEW YORK STATE RELIABILITY COUNCIL**  
**RRS #216 Status Report for EC #220 - Friday August 11, 2017**

- **PRRs under development**
  - PRR 128 - Definition of Bulk Power System
    - Discussed treatment of radial elements
    - Tabled pending NPCC A-10 revision
  - PRR 138 – G.3 (R1, R2) Loss of Long Island Gas Supply
    - Clarification of LIPA & NYISO’s reporting requirements
    - Action: Under development
- **PRRs Posted for Comment**
  - PRR 137 D.2 (R1, R2, R3) Under-Frequency Load Shedding
    - Revision to conform with NERC & NPCC
    - Recommend retirement since NERC & NPCC are more stringent/specific
    - EC approved posting for comments on 7/14/17
- **PRRs for Final Approval**
  - None
- **Other RRS matters**
  - Discussed NYPA’s presentation “Request to Modify NYSRC Exception #12 with ASEA Spare Phase Transformer in Marcy AT-2”
    - RRS discussed the technical merits & required procedures of request per Policy 1 guidelines
    - NYISO recommended that the request be granted
    - RRS concluded that the request would not have an adverse reliability impact on the NYCA transmission system
    - ConEdison withheld their approval
    - Action: RRS recommends that the EC approves NYPA’s request
  - Discussed ConEdison’s lessons learned from Black Start testing per new G.4 - System Restoration procedures (Executive Session).
    - Action: Continue monitoring
  - Discussed NYISO’s presentations addressing potential remediation of the number of Emergency Transfer declarations in NYISO’s monthly operations reports.
    - “Western NY Public Policy Transmission Report” & “Securing the 100+kV Transmission Facilities in the Market Model” presentations were reviewed.
    - Action: Continue monitoring