

NEW YORK STATE RELIABILITY COUNCIL
RRS #217 Status Report for EC #221 - Friday September 8, 2017

- **PRRs under development**
 - PRR 128 - Definition of Bulk Power System
 - Discussed treatment of radial elements
 - **Action:** Tabled pending NPCC A-10 revision
 - PRR 138 – G.3 (R1, R2) Loss of Long Island Gas Supply
 - Clarification of LIPA & NYISO’s reporting requirements
 - **Action:** Under development
- **PRRs Posted for Comment**
 - None
- **PRRs for Final Approval**
 - PRR 137 D.2 (R1, R2, R3) Under-Frequency Load Shedding
 - Revision to conform with NERC & NPCC
 - Recommend retirement since NERC & NPCC are more stringent/specific
 - EC approved posting for comments on 7/17/17, no comments received
 - **Action:** RRS recommends EC final approval
- **Other RRS matters**
 - RR&C Manual V41 revision to include:
 - PRR 137 (assuming EC approval)
 - Revision of radial definition to conform with NPCC/NERC
 - Revision of NERC/NPCC references
 - **Action:** In preparation