

**NEW YORK STATE RELIABILITY COUNCIL
EC #231 - Friday July 13, 2018**

Status Report - RRS June 28, 2018 Meeting #227

- **PRRs under development**
 - PRR 128 - Definition of Bulk Power System
 - Discussed treatment of radial elements
 - **Action:** Tabled pending NPCC A-10 revision
- **PRRs Posted for Comment**
 - None
- **PRRs for Final Approval**
 - None
- **PRRs for Discussion**
 - NYISO presentation on “Inverter Technology Providing Reserves” regarding:
 - The technical equivalency of inverter based resources as *synchronized resource capacity*.
 - The need to clarify NYSRC RR E.1 (R3.1) – “Establishing the Minimum Level of Operating Reserve” to conform with NYISO’s “Proposed Tariff Revisions Addressing Provision of Synchronized Reserves by Inverter-Based Energy Storage Resources; Docket No. ER18-__-000”, 3/29/18 to account for inverter based resources.
 - RRS confirmed NPCC TFCO’s opinion regarding the technical equivalency of inverter based resources based upon test requirements & procedures. RRS tabled action on clarification of NYSRC Rule E.1 (R3.1) pending FERC approval of NYISO’s tariff revisions.
- **Other RRS Matters**
 - Continuing discussion of proposed workshop on DER impact on NYCA reliability
 - DER Workshop Scope_Rev3
 - DPS SIR PV inventory list