

**Request to Develop or Modify Reliability Rules and Requirements (NYSRC Policy No. 1-11)**

Submit request to [herb@poweradvisorsllc.com](mailto:herb@poweradvisorsllc.com) via the NYSRC site [www.nysrc.org](http://www.nysrc.org)

Item	Information
<b>1. PRR No. &amp; Title of Reliability Rule or Requirement change</b>	PRR 140 Modification of A.1: Establishing NYCA Installed Reserve Margin Requirements
<b>2. Rule Change Requester Information</b>	
Name	RRS
Organization	
<b>3. New rule or revision to existing rule?</b>	Revision
<b>4. Need for rule change, including advantages and disadvantages</b>	To clarify A.1 requirements and to revise to be consistent with NPCC Directory 1 resource adequacy requirements.
<b>5. Related NYSRC rules</b>	A.2
<b>6. Section A – Reliability Rule Elements</b>	
1. Reliability Rule	<b>An Installed Reserve Margin (IRM) requirement for the NYCA for each Capability Year shall be established.</b> (No changes)
2. Associated NERC & NPCC Standards and Criteria	NPCC Directory 1
3. Applicability	NYSRC, NYISO, LSEs
<b>7. Section B – Requirements</b>	
Requirements	<p><b>R1.2.</b> The NYSRC shall <u>annually perform and document an analysis periodically perform resource adequacy studies to calculate the NYCA Installed Reserve Margin (IRM) requirement for the following Capability Year. The IRM analysis shall update the required statewide IRM. A report shall be prepared providing the assumptions, procedures, and results of the study.</u></p> <p><b>R1.1</b> <u>The NYSRC shall Probabilistically</u> establish the <i>IRM</i> requirement for the NYCA <u>such that the probability (or risk) of disconnecting any firm load due to resource deficiencies shall be, on average, not more than once in ten years. Compliance with this criterion shall be evaluated probabilistically,</u> such that the loss of load expectation (LOLE) of disconnecting <i>firm load</i> due to <i>resource</i> deficiencies shall be, on average, no more than 0.1 days per year. This evaluation shall make due allowance for <i>demand</i> uncertainty, scheduled outages and deratings, forced outages and deratings, assistance over interconnections with neighboring <i>control areas</i>, <i>NYS Transmission System emergency transfer capability</i>, and <i>capacity</i> and/or <i>load relief</i> from available operating procedures.</p> <p><b>R1.2</b> <u>Utilize the methodology and modeling parameters for establishing NYCA IRM requirements, and a timeline for the study process, as described in NYSRC Policy 5, "Procedure for Establishing NYCA</u></p>

Formatted: Hyperlink, Font: 11 pt, Bold, No underline, Font color: Auto

Formatted: Font: Bold

Field Code Changed

Formatted: Normal, Left, Indent: Left: 0", Hanging: 0.38", Line spacing: single, Tab stops: Not at 1"

Formatted: Font: 10 pt

Formatted: Indent: Left: 0"

Formatted: Font: (Default) +Body (Calibri)

	<p><a href="#">Installed Capacity Requirements.”</a></p> <p><a href="#">R1.3 Prepare a technical report documenting the assumptions, models, methodology, and results of the IRM study.</a></p>
<b>8. Section C – Compliance Elements</b>	
1. Measures	<p>M1. The NYSRC Installed Capacity Subcommittee conducted the annual <a href="#">NYCA IRM resource adequacy</a> study for the following Capability Year <a href="#">Period in accordance with R1.1 and R1.2</a>, and <a href="#">prepared a technical report reported the results of the study</a> in accordance with <a href="#">R1.3 and R2</a>.</p>
2. Levels of Non-Compliance	<p>(No changes)</p> <p><u>For Measure 1</u></p> <p>Level 1: Not applicable.  Level 2: A report was submitted, but was incomplete in one or more areas.  Level 3: Not applicable.  Level 4: A report was not submitted.</p>
3. Compliance Monitoring Process (See Policy 4):	(No changes)
3.1 Compliance Monitoring Responsibility	RCMS
3.2 Reporting Frequency	In accordance with NYSRC Compliance Monitoring Program schedules.
3.3 Compliance Reporting Requirements	IRM Report and other documentation requested by RCMS.
<b>9. Implementation Plan</b>	Policy 5 shall be revised by ICS to reflect PRR 140 rule changes.
<b>10. Comments</b>	<p>NYISO staff will request NPCC CP-8 to explain the need for the phrase “on average” as presently included the NPCC LOLE criterion in NPCC Directory 1 and in NYSRC A.1 (R1). If NPCC agrees that this phrase is no longer needed, NYISO staff will request that it be removed the next time that Directory 1 is revised. The phrase “on average” would then be removed from A.1 (R1).</p> <p>After PRRs 140 and 141 are approved RRS will revise, if necessary, the Introduction to the Resource Adequacy Reliability Rules section.</p>
<b>11. Date Rule Adopted</b>	
<b>12. PRR Revision Dates</b>	12/19/17, 1/4/18, 2/8/18

Formatted: Font: 10 pt

Formatted: Font: Not Bold

Formatted: Font: Not Bold

Formatted: Font: Not Bold

Formatted: Font: Not Bold