NYISO OPERATIONS REPORT FOR the Month of April 2020

Peak Load

The peak load for the month was16,595MW, which occurred onThursday ,April 16, 2020, for hour beginning20:00. At that time the Operating Reserverequirement was1,965MW. This resulted in a minimum total Operating Capacityrequirement of18,560MW for that hour.

Reserve Requirements:

Reserve	10 sync	Non sync	30 min
Requirement	655	1,310	1,965
For Hour	1,206	2,509	6,070
DSASP Cont.	65	0	65

The NYCA all time winter peak load of 25,738 MW, which occurred on Tuesday, January 7, 2014 for hour beginning 18:00.

Major Emergencies

None

The Major Emergency state was declared **0** times during April of 2019

Alert States

- ON **5** OCCASIONS AN ALERT STATE WAS DECLARED:
 - 0 SYSTEM FREQUENCY 0 LOW 0 HIGH
 - 0 ACE GREATER THAN (+OR-) 500MW
 - 0 SHORTAGE OF 10 MIN SYNCHRONIZED RESERVE
 - 0 SHORTAGE OF 10 MIN TOTAL RESERVE
 - 0 ACTUAL FLOW EXCEEDING LTE FOR LESS THAN 5 MIN
 - 0 ACTUAL VOLTAGE BELOW PRE-CONTIGENCY LOW LIMIT
 - 3 EXCEEDING CENTRAL EAST VOLTAGE CONTINGENCY LIMIT
 - 0 EXCEEDING TRANSIENT STABILITY LIMIT
 - 0 NYISO COMPUTER PROBLEM
 - 0 NEIGHBORING SYSTEM 5% VOLTAGE REDUCTION
 - 2 EMERGENCY TRANSFER DECLARED
 - 0 GIC (SMD) ACTIVITY
 - **0** SEVERE WEATHER
 - 0 OTHER

The Alert state was declared 14 times during April of 2019

Thunder Storm Alerts

1 Thunder Storm Alerts were declared for the month of April for a total of 0.53 hours

Reserve Activations

- ON 6 OCCASIONS RESERVES WERE ACTIVATED DURING THE MONTH:
 - 0 LOSS OF NEW YORK CONTROL AREA GENERATORS
 - 0 MAINTENANCE OF SYNCHRONIZED RESERVES
 - 4 SIMULTANEOUS ACTIVATION OF RESERVES
 - 3 FOR ISO-NE
 - 1 FOR IESO
 - **0** FOR PJM
 - 0 FOR NYISO
 - 0 FOR NB
 - 2 LARGE CONTROL ERRORS (ABOVE 200MW)
 - 0 LOAD PICKUP
 - 0 SCHEDULE CHANGE & LOAD PICKUP
 - 1 SCHEDULE CHANGE
 - 0 SCHEDULE CHANGE DUE TO TLR
 - 1 OTHER (FIXED GEN CHANGES / COMPUTER PROBLEMS
- 0 OF THESE RESERVE ACTIVATION'S DID NOT RESULT IN THE ACE-CROSSING ZERO
- 0 OF THE NON-ZERO CROSSINGS REQUIRED ANOTHER RESERVE PICKUP TO BE INITIATED
- 0 NON-ZERO CROSSINGS WERE ASSOCIATED WITH A UNIT LOSS

ON 11 OCCASIONS RESERVES WERE ACTIVATED DURING THE MONTH OF April 2019 2 OF THESE PICKUPS WHERE FOR ACE.

Emergency Actions

Special Case Resources:	None
Emergency Demand Response Program:	None
Purchases:	None
Sales:	None

TLR 3 Declared

0 TLR Level 3's were declared for the month of April for a total of 0.00 hours

Inadvertent Accumulations for March-2020

	Monthly		End of Month	
	Accumulation		Balance	
On-Peak:	747	MWh	10,671	MWh
Off-Peak:	-169	MWh	-14,026	MWh

NERC Control Performance

CPS1:	159.82 %
BAAL Violations:	0

NERC/NPCC Reportable DCS Events

None.