NYISO OPERATIONS REPORT FOR the Month of January 2023

Peak Load

The peak load for the month was20,641MW, which occurred onTuesday ,January 31, 2023, for hour beginning18:00. At that time the Operating Reserverequirement was1,965MW. This resulted in a minimum total Operating Capacityrequirement of22,606MW for that hour.

Reserve Requirements:

| Reserve | 10 sync | Non sync | 30 min |
|-------------|---------|----------|--------|
| Requirement | 655 | 1,310 | 1,965 |
| For Hour | 1,200 | 3,113 | 4,787 |
| DSASP Cont. | 73 | 0 | 80 |

The NYCA all time winter peak load of25,738MW, which occurred onTuesday, January 7, 2014for hour beginning18:00

Major Emergencies

None

The Major Emergency state was declared 0 times during January of 2022

Alert States

- ON 5 OCCASIONS AN ALERT STATE WAS DECLARED:
 - 2 SYSTEM FREQUENCY 2 LOW 0 HIGH
 - 0 ACE GREATER THAN (+OR-) 500MW
 - 2 SHORTAGE OF 10 MIN SYNCHRONIZED RESERVE
 - 0 SHORTAGE OF 10 MIN TOTAL RESERVE
 - 0 ACTUAL FLOW EXCEEDING LTE FOR LESS THAN 5 MIN
 - 0 ACTUAL VOLTAGE BELOW PRE-CONTIGENCY LOW LIMIT
 - 0 EXCEEDING CENTRAL EAST VOLTAGE CONTINGENCY LIMIT
 - 0 EXCEEDING TRANSIENT STABILITY LIMIT
 - 0 NYISO COMPUTER PROBLEM
 - 0 NEIGHBORING SYSTEM 5% VOLTAGE REDUCTION
 - 1 EMERGENCY TRANSFER DECLARED
 - 0 GIC (SMD) ACTIVITY
 - 0 SEVERE WEATHER
 - 0 OTHER

The Alert state was declared 8 times during January of 2022

Thunder Storm Alerts

0 Thunder Storm Alerts were declared for the month of January for a total of

Reserve Activations

- ON 5 OCCASIONS RESERVES WERE ACTIVATED DURING THE MONTH:
 - 1 LOSS OF NEW YORK CONTROL AREA GENERATORS
 - 1 MAINTENANCE OF SYNCHRONIZED RESERVES
 - 2 SIMULTANEOUS ACTIVATION OF RESERVES
 - 0 FOR ISO-NE
 - 1 FOR IESO
 - 1 FOR PJM
 - 0 FOR NYISO
 - 0 FOR NB
 - 1 LARGE CONTROL ERRORS (ABOVE 200MW)
 - 0 LOAD PICKUP
 - 0 SCHEDULE CHANGE & LOAD PICKUP
 - 0 SCHEDULE CHANGE
 - 0 SCHEDULE CHANGE DUE TO TLR
 - 1 OTHER (FIXED GEN CHANGES / COMPUTER PROBLEMS
- 0 OF THESE RESERVE ACTIVATION'S DID NOT RESULT IN THE ACE-CROSSING ZERO
- 0 OF THE NON-ZERO CROSSINGS REQUIRED ANOTHER RESERVE PICKUP TO BE INITIATED
- 0 NON-ZERO CROSSINGS WERE ASSOCIATED WITH A UNIT LOSS

ON 4 OCCASIONS RESERVES WERE ACTIVATED DURING THE MONTH OF January 2022 3 OF THESE PICKUPS WHERE FOR ACE.

Emergency Actions

| Special Case Resources: | None |
|------------------------------------|------|
| Emergency Demand Response Program: | None |
| Purchases: | None |
| Sales: | None |

TLR 3 Declared

5 TLR Level 3's were declared for the month of January for a total of 76 hours

Inadvertent Accumulations for December-2022

| | Monthly | | End of Month | |
|-----------|------------|-----|----------------|-----|
| | Accumulati | on | Balance | |
| On-Peak: | 5,324 | MWh | 21,591 | MWh |
| Off-Peak: | -2,331 | MWh | -18,458 | MWh |

NERC Control Performance

| CPS1: | 163.66 | % |
|------------------|--------|---|
| BAAL Violations: | 0 | |

0 hours

NERC/NPCC Reportable DCS Events

None