

NYISO OPERATIONS REPORT FOR the Month of July 2021

Peak Load

The peak load for the month was 28,359 MW, which occurred on Thursday, July 15, 2021, for hour beginning 17:00. At that time the Operating Reserve requirement was 1,965 MW. This resulted in a minimum total Operating Capacity requirement of 30,324 MW for that hour.

Reserve Requirements:

Reserve	10 sync	Non sync	30 min
Requirement	655	1,310	1,965
For Hour	1,593	2,602	3,964
DSASP Cont.	153	0	153

The NYCA all time summer peak load of 33,956 MW, which occurred on Friday, July 19, 2013 for hour beginning 16:00.

Major Emergencies

None

The Major Emergency state was declared 0 times during July of 2020

Alert States

ON 5 OCCASIONS AN ALERT STATE WAS DECLARED:

1 SYSTEM FREQUENCY 0 LOW 1 HIGH
 3 ACE GREATER THAN (+OR-) 500MW
 0 SHORTAGE OF 10 MIN SYNCHRONIZED RESERVE
 0 SHORTAGE OF 10 MIN TOTAL RESERVE
 0 ACTUAL FLOW EXCEEDING LTE FOR LESS THAN 5 MIN
 0 ACTUAL VOLTAGE BELOW PRE-CONTINGENCY LOW LIMIT
 0 EXCEEDING CENTRAL EAST VOLTAGE CONTINGENCY LIMIT
 0 EXCEEDING TRANSIENT STABILITY LIMIT
 0 NYISO COMPUTER PROBLEM
 0 NEIGHBORING SYSTEM 5% VOLTAGE REDUCTION
 1 EMERGENCY TRANSFER DECLARED
 0 GIC (SMD) ACTIVITY
 0 SEVERE WEATHER
 0 OTHER

The Alert state was declared 20 times during July of 2020

Thunder Storm Alerts

9 Thunder Storm Alerts were declared for the month of July for a total of 45.33 hours

Reserve Activations

ON 10 OCCASIONS RESERVES WERE ACTIVATED DURING THE MONTH:

- 2 LOSS OF NEW YORK CONTROL AREA GENERATORS
- 0 MAINTENANCE OF SYNCHRONIZED RESERVES
- 2 SIMULTANEOUS ACTIVATION OF RESERVES
 - 1 FOR ISO-NE
 - 0 FOR IESO
 - 0 FOR PJM
 - 1 FOR NYISO
 - 0 FOR NB
- 7 LARGE CONTROL ERRORS (ABOVE 200MW)
 - 0 LOAD PICKUP
 - 0 SCHEDULE CHANGE & LOAD PICKUP
 - 2 SCHEDULE CHANGE
 - 0 SCHEDULE CHANGE DUE TO TLR
 - 5 OTHER (FIXED GEN CHANGES / COMPUTER PROBLEMS)

- 0 OF THESE RESERVE ACTIVATION'S DID NOT RESULT IN THE ACE-CROSSING ZERO
- 0 OF THE NON-ZERO CROSSINGS REQUIRED ANOTHER RESERVE PICKUP TO BE INITIATED
- 0 NON-ZERO CROSSINGS WERE ASSOCIATED WITH A UNIT LOSS

ON 20 OCCASIONS RESERVES WERE ACTIVATED DURING THE MONTH OF July 2020
15 OF THESE PICKUPS WERE FOR ACE.

Emergency Actions

Special Case Resources: None
Emergency Demand Response Program: None
Purchases: None
Sales: None

TLR 3 Declared

0 TLR Level 3's were declared for the month of July for a total of 0 hours

Inadvertent Accumulations for June-2021

	Monthly <u>Accumulation</u>		End of Month <u>Balance</u>	
On-Peak:	-1,351	MWh	-1,636	MWh
Off-Peak:	229	MWh	-24,212	MWh

NERC Control Performance

CPS1: 152.14 %
BAAL Violations: 0

NERC/NPCC Reportable DCS Events

On 07/08/2021 a SAR was initiated at 17:04 for the loss of Astoria Energy CC1 and CC2 loaded at 532 MW. ACE

crossed zero and SAR was terminated at 17:20.