# NYISO OPERATIONS REPORT FOR the Month of January 2021

## **Peak Load**

The peak load for the month was 22,500 MW, which occurred on Friday , January 29, 2021 , for hour beginning 18:00 . At that time the Operating Reserve requirement was 1,965 MW. This resulted in a minimum total Operating Capacity requirement of 24,465 MW for that hour.

### Reserve Requirements:

Reserve	10 sync	Non sync	30 min
Requirement	655	1,310	1,965
For Hour	1,296	1,814	3,516
DSASP Cont.	54	0	54

The NYCA all time winter peak load of 25,738 MW, which occurred on Tuesday, January 7, 2014 for hour beginning 18:00 .

## **Major Emergencies**

None

The Major Emergency state was declared 0 times during January of 2020

## **Alert States**

ON 8 OCCASIONS AN ALERT STATE WAS DECLARED:

- 0 SYSTEM FREQUENCY 0 LOW 0 HIGH
- 0 ACE GREATER THAN (+OR-) 500MW
- 1 SHORTAGE OF 10 MIN SYNCHRONIZED RESERVE
- 1 SHORTAGE OF 10 MIN TOTAL RESERVE
- 0 ACTUAL FLOW EXCEEDING LTE FOR LESS THAN 5 MIN
- 0 ACTUAL VOLTAGE BELOW PRE-CONTIGENCY LOW LIMIT
- 5 EXCEEDING CENTRAL EAST VOLTAGE CONTINGENCY LIMIT
- 0 EXCEEDING TRANSIENT STABILITY LIMIT
- 0 NYISO COMPUTER PROBLEM
- 0 NEIGHBORING SYSTEM 5% VOLTAGE REDUCTION
- 1 EMERGENCY TRANSFER DECLARED
- 0 GIC (SMD) ACTIVITY
- 0 SEVERE WEATHER
- OTHER

The Alert state was declared 15 times during January of 2020

## **Thunder Storm Alerts**

0 Thunder Storm Alerts were declared for the month of January for a total of

### **Reserve Activations**

- ON 9 OCCASIONS RESERVES WERE ACTIVATED DURING THE MONTH:
  - 3 LOSS OF NEW YORK CONTROL AREA GENERATORS
  - 1 MAINTENANCE OF SYNCHRONIZED RESERVES
  - 2 SIMULTANEOUS ACTIVATION OF RESERVES
    - 1 FOR ISO-NE
    - O FOR IESO
    - O FOR PJM
    - O FOR NYISO
    - 1 FOR NB
  - 3 LARGE CONTROL ERRORS (ABOVE 200MW)
    - 0 LOAD PICKUP
    - 0 SCHEDULE CHANGE & LOAD PICKUP
    - 0 SCHEDULE CHANGE
    - 0 SCHEDULE CHANGE DUE TO TLR
    - 3 OTHER (FIXED GEN CHANGES / COMPUTER PROBLEMS
- OF THESE RESERVE ACTIVATION'S DID NOT RESULT IN THE ACE-CROSSING ZERO
- 0 OF THE NON-ZERO CROSSINGS REQUIRED ANOTHER RESERVE PICKUP TO BE INITIATED.
- 0 NON-ZERO CROSSINGS WERE ASSOCIATED WITH A UNIT LOSS
- ON 6 OCCASIONS RESERVES WERE ACTIVATED DURING THE MONTH OF January 2020 2 OF THESE PICKUPS WHERE FOR ACE.

### **Emergency Actions**

Special Case Resources:

Emergency Demand Response Program:

Purchases:

None
Sales:

None

### **TLR 3 Declared**

0 TLR Level 3's were declared for the month of January for a total of 0 hours.

#### Inadvertent Accumulations for December-2020

Monthly End of Month
<u>Accumulation</u> <u>Balance</u>

On-Peak: -14,305 MWh -2,651 MWh Off-Peak: -7,783 MWh -12,790 MWh

## **NERC Control Performance**

CPS1: 161.01 % BAAL Violations: 0

## **NERC/NPCC Reportable DCS Events**

None.