NYISO OPERATIONS REPORT FOR the Month of November 2022

Peak Load

The peak load for the month was 20,358 MW, which occurred on Monday , November 21, 2022 , for hour beginning 17:00 . At that time the Operating Reserve requirement was 1,965 MW. This resulted in a minimum total Operating Capacity requirement of 22,323 MW for that hour.

Reserve Requirements:

Reserve	10 sync	Non sync	30 min
Requirement	655	1,310	1,965
For Hour	1,032	2,355	3,606
DSASP Cont.	218	3	221

The NYCA all time winter peak load of 25,738 MW, which occurred on Tuesday, January 7, 2014 for hour beginning 18:00 .

Major Emergencies

None

The Major Emergency state was declared 0 times during November of 2021

Alert States

ON 5 OCCASIONS AN ALERT STATE WAS DECLARED:

- 2 SYSTEM FREQUENCY 2 LOW 0 HIGH
- 1 ACE GREATER THAN (+OR-) 500MW
- 0 SHORTAGE OF 10 MIN SYNCHRONIZED RESERVE
- 0 SHORTAGE OF 10 MIN TOTAL RESERVE
- 0 ACTUAL FLOW EXCEEDING LTE FOR LESS THAN 5 MIN
- 0 ACTUAL VOLTAGE BELOW PRE-CONTIGENCY LOW LIMIT
- 1 EXCEEDING CENTRAL EAST VOLTAGE CONTINGENCY LIMIT
- 0 EXCEEDING TRANSIENT STABILITY LIMIT
- 0 NYISO COMPUTER PROBLEM
- NEIGHBORING SYSTEM 5% VOLTAGE REDUCTION
- 1 EMERGENCY TRANSFER DECLARED
- **0** GIC (SMD) ACTIVITY
- 0 SEVERE WEATHER
- 0 OTHER

The Alert state was declared 11 times during November of 2021

Thunder Storm Alerts

0 Thunder Storm Alerts were declared for the month of November for a total of 0.00 hours

Reserve Activations

ON 5 OCCASIONS RESERVES WERE ACTIVATED DURING THE MONTH:

- 2 LOSS OF NEW YORK CONTROL AREA GENERATORS
- MAINTENANCE OF SYNCHRONIZED RESERVES
- 3 SIMULTANEOUS ACTIVATION OF RESERVES
 - **0** FOR ISO-NE
 - 1 FOR IESO
 - O FOR PJM
 - 1 FOR NYISO
 - 1 FOR NB
- 1 LARGE CONTROL ERRORS (ABOVE 200MW)
 - 0 LOAD PICKUP
 - 0 SCHEDULE CHANGE & LOAD PICKUP
 - 0 SCHEDULE CHANGE
 - 0 SCHEDULE CHANGE DUE TO TLR
 - 1 OTHER (FIXED GEN CHANGES / COMPUTER PROBLEMS
- OF THESE RESERVE ACTIVATION'S DID NOT RESULT IN THE ACE-CROSSING ZERO
- OF THE NON-ZERO CROSSINGS REQUIRED ANOTHER RESERVE PICKUP TO BE INITIATED
- NON-ZERO CROSSINGS WERE ASSOCIATED WITH A UNIT LOSS

ON 3 OCCASIONS RESERVES WERE ACTIVATED DURING THE MONTH OF November 2021 1 OF THESE PICKUPS WHERE FOR ACE.

Emergency Actions

Special Case Resources:

Emergency Demand Response Program:

Purchases:

None
Sales:

None

TLR 3 Declared

0 TLR Level 3's were declared for the month of November for a total of **0.00** hours

<u>Inadvertent Accumulations for</u> <u>October-2022</u>

Monthly End of Month <u>Accumulation</u> <u>Balance</u>

On-Peak: 10,635 MWh 4,856 MWh Off-Peak: -4,815 MWh -14,447 MWh

NERC Control Performance

CPS1: 158.45 % CPS2: 96.67 %

NERC/NPCC Reportable DCS Events