

NYISO OPERATIONS REPORT FOR the Month of September 2020

Peak Load

The peak load for the month was 24,237 MW, which occurred on Thursday , September 10, 2020 , for hour beginning 16:00 . At that time the Operating Reserve requirement was 1,965 MW. This resulted in a minimum total Operating Capacity requirement of 26,202 MW for that hour.

Reserve Requirements:

Reserve	10 sync	Non sync	30 min
Requirement	655	1,310	1,965
For Hour	1,678	2,634	4,818
DSASP Cont.	59	0	59

The NYCA all time summer peak load of 33,956 MW, which occurred on Friday, July 19, 2013 for hour beginning 16:00 .

Major Emergencies

None

The Major Emergency state was declared 1 times during September of 2019

Alert States

ON 2 OCCASIONS AN ALERT STATE WAS DECLARED:

0 SYSTEM FREQUENCY 0 LOW 0 HIGH
 0 ACE GREATER THAN (+OR-) 500MW
 0 SHORTAGE OF 10 MIN SYNCHRONIZED RESERVE
 0 SHORTAGE OF 10 MIN TOTAL RESERVE
 0 ACTUAL FLOW EXCEEDING LTE FOR LESS THAN 5 MIN
 0 EXCEEDING SYSTEM VOLTAGE LIMIT
 0 EXCEEDING CENTRAL EAST VOLTAGE CONTINGENCY LIMIT
 0 EXCEEDING TRANSIENT STABILITY LIMIT
 0 NYISO COMPUTER PROBLEM
 0 NEIGHBORING SYSTEM 5% VOLTAGE REDUCTION
 2 EMERGENCY TRANSFER DECLARED
 0 GIC (SMD) ACTIVITY
 0 SEVERE WEATHER
 0 OTHER

The Alert state was declared 10 times during September of 2019

Thunder Storm Alerts

0 Thunder Storm Alerts were declared for the month of September for a total of 0:00 hours

Reserve Activations

ON 4 OCCASIONS RESERVES WERE ACTIVATED DURING THE MONTH:

- 1 LOSS OF NEW YORK CONTROL AREA GENERATORS
- 0 MAINTENANCE OF SYNCHRONIZED RESERVES
- 2 SIMULTANEOUS ACTIVATION OF RESERVES
 - 0 FOR ISO-NE
 - 2 FOR IESO
 - 0 FOR PJM
 - 0 FOR NYISO
 - 0 FOR NB
- 1 LARGE CONTROL ERRORS (ABOVE 200MW)
 - 0 LOAD PICKUP
 - 0 SCHEDULE CHANGE & LOAD PICKUP
 - 1 SCHEDULE CHANGE
 - 0 SCHEDULE CHANGE DUE TO TLR
 - 0 OTHER (FIXED GEN CHANGES / COMPUTER PROBLEMS)

- 0 OF THESE RESERVE ACTIVATION'S DID NOT RESULT IN THE ACE-CROSSING ZERO
- 0 OF THE NON-ZERO CROSSINGS REQUIRED ANOTHER RESERVE PICKUP TO BE INITIATED
- 0 NON-ZERO CROSSINGS WERE ASSOCIATED WITH A UNIT LOSS

ON 8 OCCASIONS RESERVES WERE ACTIVATED DURING THE MONTH OF September 2019
4 OF THESE PICKUPS WERE FOR ACE.

Emergency Actions

Special Case Resources: None
 Emergency Demand Response Program: None
 Purchases: None
 Sales: None

TLR 3 Declared

0 TLR Level 3's were declared for the month of September for a total of 0:00 hours

Inadvertent Accumulations for August-2020

	<u>Monthly Accumulation</u>		<u>End of Month Balance</u>	
On-Peak:	32,209	MWh	29,997	MWh
Off-Peak:	16,614	MWh	12,860	MWh

NERC Control Performance

CPS1: 177.02 %
 BAAL Violations: 0

NERC/NPCC Reportable DCS Events

None.