

NYISO Self-Certification

Description:

NYSRC Reliability Rule Reference (No. and Name)

C.3: Outage Coordination

NYSRC Requirement(s) for which compliance is being self-certified

- R1.** Scheduled outages of facilities that affect the *reliability* of the *NYS Bulk Power System* shall be coordinated sufficiently in advance of the outage to permit the affected systems to maintain *reliability*.
- R2.** The adjacent systems shall be notified of scheduled or forced outages of any facility that may impact the neighboring *control areas' reliability* and of any other abnormal transmission configuration, which may impact the *reliability* of the *NYS Bulk Power System*.
- R3.** A list of facilities that must be secured by the *NYISO* and require coordination shall be maintained including any other abnormal transmission configuration which may impact the *reliability* of the *NYS Bulk Power System*.
- R4.** Appropriate adjustments shall be made to *NYCA* operations to accommodate the impact of *protection group* outages.
 - R4.1.** For typical periods of forced or maintenance outage of a *protection group*, it can be assumed, unless there are indications to the contrary that the remaining *protection* will function as designed.
 - R4.2** If the *protection group* will be out of service for an extended period of time (as defined in NPCC criteria), additional adjustments to operations may be appropriate considering other system conditions and the consequences of possible failure of a remaining *protection group*.
- R5.** The *NYISO* shall maintain procedures and systems which ensure that outages of transmission facilities are coordinated in such a manner to ensure *reliability*. The procedures shall include a requirement that Transmission Owners expedite, to the extent practicable, maintenance of facilities which impact the reliability of the power system. The *NYISO* must notify the *NYSRC* of any changes to these procedures and systems.

Compliance Monitoring Process

Compliance Monitoring Responsibility:

- M1: RCMS

Compliance Documentation Reporting Frequency:

- M1: In accordance with *NYSRC* Compliance Monitoring Program schedules.

Compliance Reporting Requirements:

- M1: Self-Certification

Measure No.

<input checked="" type="checkbox"/> Full Compliance	M1. The <i>NYISO</i> maintained transmission outage coordination procedures and systems in accordance with R1 to R6. Any revisions to these procedures and systems were reported to the <i>NYSRC</i> .
---	--

Levels of Non-Compliance

<input type="checkbox"/> Level 1	M1. Revisions to existing procedures or systems were not reported to the <i>NYSRC</i> .
<input type="checkbox"/> Level 2	M1. <i>NYISO</i> procedures and systems for coordination of transmission facility outages were incomplete in one or more areas.
<input type="checkbox"/> Level 3	M1. Not applicable.
<input type="checkbox"/> Level 4	M1. <i>NYISO</i> procedures and systems for coordination of transmission facility outages were not provided.

Notes: The *NYISO* maintains procedures and systems which ensure that outages of transmission facilities are coordinated in such a manner to ensure reliability as per the Outage Scheduling Manual Sections 2.2, 2.3, and 4.

Certified by: A. Markham

Title: Manager, Grid Operations

Date: March 05, 2020