

NYISO Self-Certification

Description:

NYSRC Reliability Rule Reference (No. and Name)

D.1: Mitigation of Major Emergencies

NYSRC Requirement(s) for which compliance is being self-certified

R8 The NYISO shall maintain procedures and systems that ensure that appropriate actions are taken when frequency, reserves, thermal, voltage, and/or stability limits are violated in accordance with R1 through R7. The NYISO must notify the NYSRC of any changes to these procedures and systems.

Compliance Monitoring Process

Compliance Monitoring Responsibility:

- M1: RCMS

Compliance Documentation Reporting Frequency:

- M1: In accordance with *NYSRC* Compliance Monitoring Program schedule.

Compliance Reporting Requirements:

- M1: *NYISO* Self-Certification. This may be supplemented, if determined by the *NYSRC*, by audits or other information specified by the *NYSRC* Compliance Monitoring Program, or other requirements determined by the *NYSRC*.

Measure No.

<input checked="" type="checkbox"/> Full Compliance	M1. The <i>NYISO</i> maintained procedures and systems in accordance with R8 that ensures all <i>Market Participants</i> will respond correctly when frequency, <i>reserves</i> and thermal, voltage and/or <i>stability limits</i> are violated.
---	---

Levels of Non-Compliance

___ Level 1	M1. Not applicable.
___ Level 2	M1. <i>NYISO</i> procedures were provided, but were incomplete in one or more areas.
___ Level 3	M1. Not applicable.
___ Level 4	M1. Procedures were not provided by the <i>NYISO</i> .

Notes: The NYISO Emergency Operations Manual section 4 - Monitored Conditions – contains the NYISO actions taken when frequency, reserves, thermal, voltage, and/or stability limits are exceedance.

R1- (Transmission Thermal Overloads) is referenced in the Emergency Operations Manual (EOM) in Section 4.1

R2- (Post Contingency STE Rating Exceedances) is referenced in the EOM in Section 4.1.2, 3.3

R3- (High or Low Voltage) is referenced in the EOM in Section 4.2 ,3.3

R4- (Post Contingency Voltage IROL Exceedances) is referenced in the EOM in Section 4.3, 3.3

R5- (Operating Reserve Deficiency) is referenced in the EOM in Section 4.4, 3.3

R6- (IROL Stability Limit Violations) is referenced in the EOM in Section 4.5, 3.3

R7- (High/Low Frequency) is referenced in the EOM in Section 4.6., 3.3

Certified by: A. Markham

Title: Director, Grid Operations

Date: April 25, 2019