

**From:** DePugh, Kevin S. [<mailto:KDePugh@nyiso.com>] **Sent:** Monday, April 04, 2016 10:21 AM **To:** Pfleiderer, Roy; Clayton Roger; Grant, James **Cc:** Hochberg, Larry; Altenburger, Peter F. **Subject:** RE: EXT || Proposed Revisions to Reliability Rules Exceptions

Proposal:

Modify the application of NYSRC RR&CM Exceptions #5, #6, #10, #11, #12, #13, and #23 to the Reliability Rules

As it is, the NYSRC RR&CM Exceptions #5, #6, #10, #11, #12, #13, and #23 to the Reliability Rules are exempt from C.1 ONLY. Section C sets forth Reliability Rules for establishing operating transmission capabilities, post contingency operation, outage coordination, and other aspects of transmission operation. Using the Exceptions also as Planning Exceptions would not negatively impact reliability in the planning horizon and provides additional system capability, the proposal is to change the table cell that links the exception to the NYSRC reliability rule so it reads: B.1 and C.1.

Advantages:

This proposal gains additional system capability by allowing the applicability of NYSRC RR&CM Exceptions #5, #6, #10, #11, #12, #13, and #23 to the Reliability Rule.

Kevin S. DePugh, PE  
Manager  
Transmission Studies  
NYISO  
(518)356-6144