Date: March 4, 2020 at 1:38 PM

To: Roger Clayton roger.clayton@electricpowerresources.com

Here's our response to the Exception removal request.

Jim Grant

Senior Reliability Engineer NYISO 518.356.6128

From: Grant, James

Sent: Wednesday, March 4, 2020 1:33 PM

To: 'Puran Vijay (DPS)' <Vijay.Puran@dps.ny.gov>; 'Wentlent Chris' <cwentlent@gmail.com>; 'Hochberg Larry' <larry.hochberg@nypa.gov>; 'Gordon Brian' <BTGordon@nyseg.com>; Capano, Mark <MCapano@nyiso.com>; 'Gari Abhilash Massana' <Abhilash.Gari@nypa.gov>; 'Gjonaj Leka' <Leka.Gjonaj@dps.ny.gov>; Grant, James <JGrant@nyiso.com>; 'Shanahan Brian' <Brian.Shanahan@nationalgrid.com>; 'Kabir Humi' <Humayun.Kabir@dps.ny.gov>; Smith, Zach <ZSmith@nyiso.com>; 'Sasson Mayer (ConEd)' <SASSONM@coned.com>; 'Rodriguez Zoraini' <Zoraini.Rodriguez@pseg.com>; 'Gioia, Esq. Paul' <PGioia@woh.com>; 'Davidson Peggy' <Peggy.Davidson@nyserda.ny.gov>; 'Brust Kathleen' <Kathleen.Brust@nyserda.ny.gov>; Sharp, Christopher R <csharp@nyiso.com>; 'Paszek Martin' <PASZEKM@coned.com>; DePugh, Kevin S. <KDePugh@nyiso.com>; 'Pandit Rahul' <Rahul.Pandit@PSEG.COM>; 'Roszkowski Michael' <ROSZKOWSKIM@coned.com>; 'Hastings John' <john.hastings2@nationalgrid.com>; 'Ridolfino Michael' <mridolfino@cenhud.com>; 'Spagnolo Salvatore' <salvatore.spagnolo@nypa.gov>; Campoli, Gregory <GCampoli@nyiso.com>; 'Head Daniel T' <HeadD@coned.com>; 'Barrios Erick' <Erick.Barrios@nypa.gov>; 'Schrayshuen Herb' <herb@poweradvisorsllc.com>; 'Adamson Al' <alanadamson6@gmail.com>; 'Becker Melissa' <mbecker0326@gmail.com>

Subject: Removal of NYSRC Exceptions 17 and 18

Dear RRS,

Consolidated Edison has notified the NYSRC Executive Committee of Consolidated Edison's desire to remove Rule Exceptions 17 and 18, upon the removal from service of Indian Point Unit 2 on April 30, 2020. The NYISO's System & Resource Planning and Operations Departments have conducted a review to determine the impact of removing the exceptions. The NYISO has not identified any reliability criteria violations associated with removing the exceptions on May 1, 2020¹, as requested by Consolidated Edison.

¹ If for any reason Indian Point Unit 2 is not removed from service on April 30, 2020, as expected, the Exceptions should remain in place until Unit 2 is removed from service.

Jim Grant

Senior Reliability Engineer NYISO

GJ

518.356.6128

The information in this email is confidential and may be legally privileged against disclosure other than to the intended recipient. It is intended solely for the addressee. Access to this email by anyone else is unauthorized. If you are not the intended recipient, any disclosure, copying, distribution or any action taken or omitted to be taken in reliance on it, is prohibited and may be unlawful. Please immediately delete this message and inform the sender of this error.