# FOR the Month of January 2019

#### **Peak Load**

The peak load for the month was 24,728 MW, which occurred on Monday , January 21, 2019 , for hour beginning 18:00 . At that time the Operating Reserve requirement was 1,965 MW. This resulted in a minimum total Operating Capacity requirement of 26,693 MW for that hour.

#### Reserve Requirements:

Reserve	10 sync	Non sync	30 min
Requirement	655	1,310	1,965
For Hour	939	2,697	5,183
DSASP Cont.	54	0	54

The NYCA all time winter peak load of 25,738 MW, which occurred on Tuesday, January 7, 2014 for hour beginning 18:00 .

# **Major Emergencies**

None

The Major Emergency state was declared **0** times during January of 2018

#### **Alert States**

ON 22 OCCASIONS AN ALERT STATE WAS DECLARED:

- 0 SYSTEM FREQUENCY 0 LOW 0 HIGH
- **0** ACE GREATER THAN (+OR-) 500MW
- 1 SHORTAGE OF 10 MIN SYNCHRONIZED RESERVE
- 0 SHORTAGE OF 10 MIN TOTAL RESERVE
- 0 ACTUAL FLOW EXCEEDING LTE FOR LESS THAN 5 MIN
- 0 ACTUAL VOLTAGE BELOW PRE-CONTIGENCY LOW LIMIT
- 6 EXCEEDING CENTRAL EAST VOLTAGE CONTINGENCY LIMIT
- 0 EXCEEDING TRANSIENT STABILITY LIMIT
- 0 NYISO COMPUTER PROBLEM
- 0 NEIGHBORING SYSTEM 5% VOLTAGE REDUCTION
- 15 EMERGENCY TRANSFER DECLARED
- 0 GIC (SMD) ACTIVITY
- 0 SEVERE WEATHER
- 0 OTHER

The Alert state was declared 12 times during January of 2018

### **Thunder Storm Alerts**

**0** Thunder Storm Alerts were declared for the month of January for a total of

#### **Reserve Activations**

- ON 9 OCCASIONS RESERVES WERE ACTIVATED DURING THE MONTH:
  - 2 LOSS OF NEW YORK CONTROL AREA GENERATORS
  - 1 MAINTENANCE OF SYNCHRONIZED RESERVES
  - 0 SIMULTANEOUS ACTIVATION OF RESERVES
    - O FOR ISO-NE
    - O FOR IESO
    - O FOR PJM
    - O FOR NYISO
    - O FOR NB
  - 6 LARGE CONTROL ERRORS (ABOVE 200MW)
    - 0 LOAD PICKUP
    - 0 SCHEDULE CHANGE & LOAD PICKUP
    - 1 SCHEDULE CHANGE
    - 0 SCHEDULE CHANGE DUE TO TLR
    - 5 OTHER (FIXED GEN CHANGES / COMPUTER PROBLEMS
- 1 OF THESE RESERVE ACTIVATION'S DID NOT RESULT IN THE ACE-CROSSING ZERO
- 0 OF THE NON-ZERO CROSSINGS REQUIRED ANOTHER RESERVE PICKUP TO BE INITIATED.
- NON-ZERO CROSSINGS WERE ASSOCIATED WITH A UNIT LOSS

ON 11 OCCASIONS RESERVES WERE ACTIVATED DURING THE MONTH OF January 2018 3 OF THESE PICKUPS WHERE FOR ACE.

## **Emergency Actions**

Special Case Resources:

Emergency Demand Response Program:

Purchases:

None
Sales:

None

## **TLR 3 Declared**

5 TLR Level 3's were declared for the month of January for a total of 36.23 hours.

## Inadvertent Accumulations for December-2018

Monthly End of Month

<u>Accumulation</u> <u>Balance</u>

On-Peak: 3,519 MWh 18,366 MWh Off-Peak: 5,867 MWh -8,904 MWh

#### **NERC Control Performance**

CPS1: 176.15 % BAAL Violations None

# **NERC/NPCC Reportable DCS Events**

None.