

# NYISO Major Emergency Report

At 1310 on 10/08/2017 a Major Emergency was declared by the NYISO Shift Supervisor when the power flow on Central East VC exceeded its Transient Stability Limit by more than 105%

This was caused by: Loss of 7040/MSU-1 loaded at 650MW

To correct this the NYISO Shift Supervisor: Curtailed transactions, Started 2 Gilboa units, moved Phase Angle Regulators (PAR), and redispatched generation.

Load relief was not required.

The Major Emergency was terminated at 1321 on 10/08/2017