

## Attachment C Load Relief Capability

- Table C-1 tabulates the Load Relief available from Voltage Reduction and load curtailment.
- Table C-2 allocates New York Control Area wide load reduction among the Transmission Owners (TOs).
- Table C-3 allocates load reduction among the TOs on a geographic basis.

**Note:** The above attachments do not require committee approval and are subject to change at the NYISO's direction.

**Table C- 1: Summer 2022 Load Relief Measures**

Remote TO-->		VOLTAGE REDUCTION CAPABILITY PERIOD																		SUMMER 2022						TOTAL (NYISO)					
		LI			CE			OR			CH			PA			NG		NY			RG		NT							
ZONE		3%	5%	8%	3%	5%	8%	3%	5%	8%	3%	5%	8%	3%	5%	8%	3%	5%	8%	3%	5%	8%	3%	5%	8%	3%	5%	8%			
A																	39	39									0	39	39		
B																	6	6					9	9				0	15	15	
C																	37	37			6	6						0	43	43	
D																												0	0	0	
E																	23	23										0	23	23	
F																	60	60										0	60	60	
G								8	8		16	16																0	24	24	
H					1	2																						0	1	2	
I					9	14																						0	9	14	
J					206	305																						0	206	305	
K		23	33	33																								23	33	33	
TOTAL (TO)		23	33	33	0	216	321	0	8	8	0	16	16	0	0	0	0	165	165	0	6	6	0	9	9	0	0	0	23	453	558

MANUAL TO-->		VOLTAGE REDUCTION CAPABILITY PERIOD																		SUMMER 2022						TOTAL (NYISO)			
		LI			CE			OR			CH			PA			NG		NY			RG		NT					
ZONE		3%	5%	8%	3%	5%	8%	3%	5%	8%	3%	5%	8%	3%	5%	8%	3%	5%	8%	3%	5%	8%	3%	5%	8%	3%	5%	8%	
A											5	8					3										5	11	0
B											1	2															1	2	0
C											6	10					5										6	15	0
D											6	9															6	9	0
E											3	5					2										3	7	0
F											0	0					2										0	2	0
G																											0	0	0
H					6	8																					0	9	8
I					15	23																					0	15	23
J					11	16																					0	11	16
K											2	4															2	4	0
TOTAL (TO)		0	0	0	32	47	0	0	0	0	23	38	0	0	0	15	0	0	0	0	0	0	0	0	0	0	23	85	47