NYISO OPERATIONS REPORT FOR the Month of November 2021

Peak Load

The peak load for the month was20,690MW, which occurred onTuesday ,November 30, 2021, for hour beginningHB17. At that time the Operating Reserverequirement was1,965MW. This resulted in a minimum total Operating Capacityrequirement of22,654MW for that hour.

Reserve Requirements:

| Reserve | 10 sync | Non sync | 30 min |
|-------------|---------|----------|--------|
| Requirement | 655 | 1,310 | 1,965 |
| For Hour | 1,342 | 3,820 | 4,011 |
| DSASP Cont. | 152 | 0 | 152 |

The NYCA all time winter peak load of 25,738 MW, which occurred on Tuesday, January 7, 2014 for hour beginning 18:00.

Major Emergencies

None

The Major Emergency state was declared **0** times during November of 2020

Alert States

ON **11** OCCASIONS AN ALERT STATE WAS DECLARED:

- 0 SYSTEM FREQUENCY 0 LOW 0 HIGH
- 1 ACE GREATER THAN (+OR-) 500MW
- 0 SHORTAGE OF 10 MIN SYNCHRONIZED RESERVE
- 0 SHORTAGE OF 10 MIN TOTAL RESERVE
- 0 ACTUAL FLOW EXCEEDING LTE FOR LESS THAN 5 MIN
- 0 ACTUAL VOLTAGE BELOW PRE-CONTIGENCY LOW LIMIT
- 2 EXCEEDING CENTRAL EAST VOLTAGE CONTINGENCY LIMIT
- 3 EXCEEDING TRANSIENT STABILITY LIMIT
- 0 NYISO COMPUTER PROBLEM
- 0 NEIGHBORING SYSTEM 5% VOLTAGE REDUCTION
- 5 EMERGENCY TRANSFER DECLARED
- 0 GIC (SMD) ACTIVITY
- 0 SEVERE WEATHER
- 0 OTHER

The Alert state was declared **4** times during November of 2020

Thunder Storm Alerts

1 Thunder Storm Alerts were declared for the month of November for a total of 3.35 hours

Reserve Activations

ON 3 OCCASIONS RESERVES WERE ACTIVATED DURING THE MONTH:

- 1 LOSS OF NEW YORK CONTROL AREA GENERATORS
- 0 MAINTENANCE OF SYNCHRONIZED RESERVES
- 1 SIMULTANEOUS ACTIVATION OF RESERVES
 - 0 FOR ISO-NE
 - 1 FOR IESO
 - **0** FOR PJM
 - 0 FOR NYISO
 - 0 FOR NB
- 1 LARGE CONTROL ERRORS (ABOVE 200MW)
 - 0 LOAD PICKUP
 - 0 SCHEDULE CHANGE & LOAD PICKUP
 - 1 SCHEDULE CHANGE
 - **0** SCHEDULE CHANGE DUE TO TLR
 - 0 OTHER (FIXED GEN CHANGES / COMPUTER PROBLEMS
- 0 OF THESE RESERVE ACTIVATION'S DID NOT RESULT IN THE ACE-CROSSING ZERO
- 0 OF THE NON-ZERO CROSSINGS REQUIRED ANOTHER RESERVE PICKUP TO BE INITIATED
- 0 NON-ZERO CROSSINGS WERE ASSOCIATED WITH A UNIT LOSS

ON 6 OCCASIONS RESERVES WERE ACTIVATED DURING THE MONTH OF November 2020 5 OF THESE PICKUPS WHERE FOR ACE.

Emergency Actions

| Special Case Resources: | None |
|------------------------------------|------|
| Emergency Demand Response Program: | None |
| Purchases: | None |
| Sales: | None |

TLR 3 Declared

0 TLR Level 3's were declared for the month of November for a total of 0 hours

Inadvertent Accumulations for October-2021

| | Monthly | | End of Month | |
|-----------|--------------|-----|----------------|-----|
| | Accumulation | on | Balance | |
| On-Peak: | 6,402 | MWh | 11,575 | MWh |
| Off-Peak: | 11,178 | MWh | 15,587 | MWh |

NERC Control Performance

| CPS1: | 160.47 | % |
|------------------|--------|---|
| BAAL Violations: | 0 | |

NERC/NPCC Reportable DCS Events

None.