

Request to Develop or Modify Reliability Rules and Requirements (NYSRC Policy No. 1-7)

Submit request to raymond40@aol.com via the NYSRC site www.nysrc.org

Item	Information
1. PRR No. & Title of Reliability Rule or Requirement change	PRR 128 Definition of <i>New York State Bulk Power System (NYS Bulk Power System)</i>
2. Rule Change Requester Information	
Name	Martin Paszek
Organization	Con Edison
3. New rule or revision to existing rule?	Revision of the existing Glossary term: <i>New York State Bulk Power System (NYS Bulk Power System)</i> .
4. Need for rule change, including advantages and disadvantages	<p>The existing legacy definition of the <i>New York State Bulk Power System (NYS Bulk Power System)</i> requires an update. The existing definition of the <i>New York State Bulk Power System (NYS Bulk Power System)</i> includes wording, such as “[...] generally comprising units 300 MW and larger, and generally comprising transmission facilities 230 kV and above [...]” that is subject to various interpretation and may lead to situations where some facilities that should be subjected to the NYSRC Reliability Rules are not, and vice versa. The NYSRC Reliability Rules apply to the NYSRC BPS facilities. In addition, the existing legacy definition should be updated and aligned with the recent NERC BES and NPCC BPS definition updates.</p> <p>On March 20, 2014 FERC approved the revised BES definition. The BES definition includes “Bright-Line” core criteria (100 kV and above) with various inclusions and exclusions. All BES elements are subject to compliance with the NERC Standards. The BES definition was revised to improve clarity, to reduce ambiguity and to establish consistency across all Regions. NERC works with eight Regional Entities to improve the reliability of the BES. NPCC is one of the Regions.</p> <p>NPCC Document A-10 “Classification of Bulk Power System Elements” provides the methodology to identify the Bulk Power System (BPS) Elements, or parts thereof, of the interconnected NPCC Region. NPCC Criteria and Directories, which establish more stringent requirements than the NERC Standards, are applicable to BPS. New York is part of the NPCC Region. NPCC Document A-10 is a “Performance-Based” methodology.</p> <p>After an extensive NYSRC Executive Committee discussion it was agreed that in developing a revised <i>New York State Bulk Power System (NYS Bulk Power System)</i> definition, the starting point should be the NPCC “Performance-Based” Document A-10 criterion with the additions / modifications as deemed appropriate for New York State.</p> <p>This PRR was tabled in 2015 due to on-going revision of the NPCC Document A-10. After few years of a review NPCC Full Member Committee approved the revised NPCC Document A-10 effective March 27, 2020</p>

	<p>***</p> <p>Advantage: Clarification of the NYSRC definition of the <i>New York State Bulk Power System (NYS Bulk Power System)</i> that would not be subject to various interpretations thus causing unnecessary confusion.</p> <p>Disadvantage: None</p>
5. Related NYSRC rules	<p>This is a change to an existing Glossary Term: <i>New York State Bulk Power System (NYS Bulk Power System)</i>, which is quoted throughout the RR&C Manual (Introduction, Rule Group B, C, D, F, G and I).</p> <p>Section 1.2.4 of the Introduction section is specific to this Glossary Term thus the proposed language will be changed in section 1.2.4 (Introduction) and in the Glossary section of the RR&C Manual.</p> <p><u>Existing definition of the <i>New York State Bulk Power System (NYS Bulk Power System)</i>:</u> The portion of the Bulk Power System within the New York Control Area, generally comprising generating units 300 MW and larger, and generally comprising transmission facilities 230 kV and above. However, smaller generating units and lower voltage transmission facilities on which faults and disturbances can have a significant adverse impact outside of the local area are also part of the NYS Bulk Power System.</p> <p><u>New definition of the <i>New York State Bulk Power System (NYS Bulk Power System)</i>:</u> The portion of the New York Transmission System identified as the NYS Bulk Power System (NYS BPS) pursuant to the NPCC Document A-10 <i>Classification of Bulk Power System Elements</i>.</p>
6. Section A – Reliability Rule Elements	
1. Reliability Rule	No change
2. Associated NERC & NPCC Standards and Criteria	No change
3. Applicability	No change
7. Section B – Requirements	
Requirements	No change
8. Section C – Compliance Elements	
1. Measures	No change
2. Levels of Non-Compliance	No change
3. Compliance Monitoring Process (See Policy 4):	No change
3.1 Compliance Monitoring Responsibility	No change

3.2 Reporting Frequency	No change
3.3 Compliance Reporting Requirements	No change
9. Implementation Plan	The NYISO shall revise appropriate procedures within 90 days of Executive Committee approval of PRR 128.
10. Comments	None
11. Date Rule Adopted	
12. PRR Revision Dates	1/5/15, 6/5/15, 8/28/15, 4/27/2020