

## Request to Develop or Modify Reliability Rules and Requirements (NYSRC Policy No. 1-7)

Submit request to [raymond40@aol.com](mailto:raymond40@aol.com) via the NYSRC site [www.nysrc.org](http://www.nysrc.org)

Item	Information
<b>1. PRR No. &amp; Title of Reliability Rule or Requirement change</b>	130 C.1: Establishing Operating Transfer Capabilities
<b>2. Rule Change Requester Information</b>	
Name	James Grant
Organization	NYISO
<b>3. New rule or revision to existing rule?</b>	Revision
<b>4. Need for rule change, including advantages and disadvantages</b>	The existing Rule is not explicit in requiring the NYISO to define in its procedures when it is appropriate to invoke Emergency Transfer Criteria (ETC).
<b>5. Related NYSRC rules</b>	
<b>6. Section A – Reliability Rule Elements</b>	
1. Reliability Rule	Normal and emergency operating transfer capabilities shall be established in order to operate the NYS Bulk Power System to a level of reliability that will not result in the loss or separation of a major portion of the system.
2. Associated NERC & NPCC Standards and Criteria	NERC: FAC-011 NPCC: Directory 1
3. Applicability	NYISO
<b>7. Section B – Requirements</b>	
Requirements	R2. The NYISO shall maintain procedures and systems that ensure that appropriate actions are taken when thermal, voltage, and/or stability limits are exceeded. <u>These procedures shall identify system states that warrant the NYISO to invoke emergency transfer criteria.</u> The NYISO must notify the NYSRC of any changes to these procedures and systems.
<b>8. Section C – Compliance Elements</b>	
1. Measures	The NYISO maintained procedures and systems in accordance with R1 and R2 which identify appropriate actions to be taken whenever the bulk power transmission system's thermal, voltage, and <i>stability limits</i> are exceeded. <u>The procedures identified system conditions-states that warrant the NYISO to invoke emergency transfer criteria.</u> Any revisions to these procedures or systems were reported to the NYSRC.
2. Levels of Non-Compliance	No change needed.
3. Compliance Monitoring Process (See Policy 4):	No change needed.
3.1 Compliance Monitoring Responsibility	No change needed.
3.2 Reporting Frequency	No change needed.
3.3 Compliance Reporting	No change needed.

Requirements	
<b>9. Implementation Plan</b>	<u>NYISO procedures are to be updated no later than 90 days following Rule approval.</u>
<b>10. Comments</b>	
<b>11. Date Rule Adopted</b>	
<b>12. PRR Revision Dates</b>	<u>3/24/16</u>