

**Request to Develop or Modify Reliability Rules and Requirements (NYSRC Policy No. 1-7)**

Submit request to [raymond40@aol.com](mailto:raymond40@aol.com) via the NYSRC site [www.nysrc.org](http://www.nysrc.org)

Item	Information
<b>1. PRR No. &amp; Title of Reliability Rule or Requirement change</b>	<b>PRR 133</b> Revision of System Restoration Plan, F.1, and Retirement of System Restoration Training and Simulation Programs, F.2
<b>2. Rule Change Requester Information</b>	
Name	RRS
Organization	
<b>3. New rule or revision to existing rule?</b>	Revision
<b>4. Need for rule change, including advantages and disadvantages</b>	NYSRC rules are more stringent or specific than NERC and NPCC standards and criteria. A recent RRS review indicates that NERC training requirements are more stringent than virtually all NYSRC system restoration training requirements associated with Reliability Rule F.2. Therefore, this PRR retires Reliability Rule F.2 and related requirements while maintaining a more stringent system restoration training requirement in F.1(R1.14).
<b>5. Related NYSRC rules</b>	
<b>6. Section A – Reliability Rule Elements</b>	
1. Reliability Rule	<b>F.1</b> A NYCA System Restoration Plan (NYCA SRP) shall be maintained to restore the NYCA system to a normal operating state in a safe and orderly manner and as promptly as reasonably possible following a major or total blackout. The NYCA SRP shall be composed of a NYISO system restoration plan and <i>Transmission Owner</i> system restoration plans.
2. Associated NERC & NPCC Standards and Criteria	
3. Applicability	
<b>7. Section B – Requirements</b>	
Requirements	<p><b>R1.</b> The NYISO shall develop and maintain a NYCA SRP that provides assurance that the NYCA system will be restored in a safe and orderly manner and as promptly as reasonable possible following a major or total blackout.</p> <p>The NYCA SRP shall include system restoration at two integrated levels: restoration of the NYCA backbone system in accordance with a NYISO System Restoration Plan (NYISO SRP) and restoration of local areas in accordance with <i>Transmission Owner</i> system restoration plans (TO SRPs).</p> <p><u>The NYISO shall develop and maintain an SRP that meets NERC and NPCC requirements. In addition, the NYCA SRP shall include the following more stringent and more specific minimum requirements:</u></p> <p><b>R1.1 – R1.13</b> (no changes)</p> <p><u>R1.14 Procedures for training NYISO and Market Participant operating personnel for the effective implementation of the NYCA SRP. The NYISO</u></p>

Formatted: Font: 10 pt

Formatted: Font: 10 pt

Formatted: Indent: Left: 0.31", Line spacing: single

Formatted: Font: 10 pt

Formatted: Font: 10 pt

Formatted: Font: 10 pt

Formatted: Font: 10 pt, Bold

Formatted: Indent: Left: 0.5", First line: 0", Line spacing: single

Formatted: Font: 10 pt

	<p><u>shall maintain program records showing that operating personnel have been trained in the implementation of the NYCA SRP and participated in restoration exercises. These records shall be provided to the NYSRC upon request.</u></p> <p>▲</p> <p><b>R2 and R3</b> (no changes)</p>
	<b><u>Retire System Restoration Training Reliability Rule F.2 and associated Requirements.</u></b>
<b>8. Section C – Compliance Elements</b>	No changes.
1. Measures	
2. Levels of Non-Compliance	
3. Compliance Monitoring Process (See Policy 4):	
3.1 Compliance Monitoring Responsibility	
3.2 Reporting Frequency	
3.3 Compliance Reporting Requirements	
<b>9. Implementation Plan</b>	
<b>10. Comments</b>	
<b>11. Date Rule Adopted</b>	
<b>12. PRR Revision Dates</b>	5/25/16

Formatted: Font: 10 pt

Formatted: Font: 10 pt