

**Request to Develop or Modify Reliability Rules and Requirements (NYSRC Policy No. 1-79)**

Submit request to [raymond40@aol.com](mailto:raymond40@aol.com) via the NYSRC site [www.nysrc.org](http://www.nysrc.org)

Item	Information
<b>1. PRR No. &amp; Title of Reliability Rule or Requirement change</b>	<b>PRR 134</b> Retirement of Rule I.5 – Disturbance Recording
<b>2. Rule Change Requester Information</b>	
Name	RRS
Organization	NYSRC
<b>3. New rule or revision to existing rule?</b>	Revision - Retirement
<b>4. Need for rule change, including advantages and disadvantages</b>	Retirement of Reliability Rule I.5 is consistent with NYSRC policy that NYSRC Reliability Rules shall be more stringent or more specific than related NERC and NPCC Standards and criteria. Although I.5 is consistent with NERC and NPCC requirements, a review of the rule concluded that it is not more stringent or specific than related NERC and NPCC Standards and criteria.
<b>5. Related NYSRC rules</b>	None
<b>6. Section A – Reliability Rule Elements</b>	
1. Reliability Rule	I.5 Disturbance Reporting  Disturbance recording devices shall be installed to ensure data is available to assist in the analysis of NYCA performance during system disturbances.
2. Associated NERC & NPCC Standards and Criteria	NPCC: Directory 1 NERC: PRC-002, PRC-018
3. Applicability	NYISO/MPs
<b>7. Section B – Requirements</b>	
Requirements	Retire I.5 R1 and I.5 R2
<b>8. Section C – Compliance Elements</b>	Retire all associated compliance elements
1. Measures	
2. Levels of Non-Compliance	
3. Compliance Monitoring Process (See Policy 4):	
3.1 Compliance Monitoring Responsibility	
3.2 Reporting Frequency	

Formatted Table

3.3 Compliance Reporting Requirements	
<b>9. Implementation Plan</b>	
<b>10. Comments</b>	
<b>11. Date Rule Adopted</b>	
<b>12. PRR Revision Dates</b>	8/24/2016