

Request to Develop or Modify Reliability Rules and Requirements (NYSRC Policy No. 1-9)

Submit request to raymond40@aol.com via the NYSRC site www.nysrc.org

Deleted: 7

Item	Information
1. PRR No. & Title of Reliability Rule or Requirement change	PRR 134 Retirement of Rule I.5 – Disturbance Recording
2. Rule Change Requester Information	
Name	RRS
Organization	NYSRC
3. New rule or revision to existing rule?	Revision - Retirement
4. Need for rule change, including advantages and disadvantages	Retirement of Reliability Rule I.5 is consistent with NYSRC policy that NYSRC Reliability Rules shall be more stringent or more specific than related NERC and NPCC Standards and criteria. Although I.5 is consistent with NERC and NPCC requirements, a review of the rule concluded that <u>all of the requirements in I.5 are not more stringent or specific than related NERC and NPCC Standards and criteria.</u>
5. Related NYSRC rules	None
6. Section A – Reliability Rule Elements	
1. Reliability Rule	I.5 Disturbance Reporting Disturbance recording devices shall be installed to ensure data is available to assist in the analysis of NYCA performance during system disturbances.
2. Associated NERC & NPCC Standards and Criteria	NPCC: Directory 1 NERC: PRC-002, PRC-018
3. Applicability	NYISO/MPs
7. Section B – Requirements	
Requirements	R1—The NYISO shall develop requirements and procedures for the installation of disturbance recording devices and the reporting of data to assist in the analysis of NYCA performance during system disturbances. The NYISO shall maintain a database of all NYCA disturbance recording device installations. R2—Market Participants shall install disturbance monitoring devices and report data in accordance with NYISO requirements and procedures.
8. Section C – Compliance Elements	Retire all associated compliance elements
1. Measures	
2. Levels of Non-Compliance	
3. Compliance Monitoring Process (See Policy 4):	
3.1 Compliance	

Deleted: it is

Formatted: Font color: Red, Strikethrough

Formatted: Font color: Red, Strikethrough

Formatted: Font color: Red, Strikethrough

Formatted: Font color: Red, Strikethrough

Formatted: Right: 0.25"

Monitoring Responsibility	
3.2 Reporting Frequency	
3.3 Compliance Reporting Requirements	
9. Implementation Plan	
10. Comments	
11. Date Rule Adopted	
12. PRR Revision Dates	8/24/2016, <u>9/2/16</u>

2-

Formatted: Right: 0.25"