NEW YORK STATE RELIABILITY COUNCIL RRS #217 Status Report for EC #221 - Friday September 8, 2017

• PRRs under development

- o PRR 128 Definition of Bulk Power System
 - Discussed treatment of radial elements
 - Action: Tabled pending NPCC A-10 revision
- o PRR 138 G.3 (R1, R2) Loss of Long Island Gas Supply
 - Clarification of LIPA & NYISO's reporting requirements
 - **Action**: Under development

PRRs Posted for Comment

o None

• PRRs for Final Approval

- o PRR 137 D.2 (R1, R2, R3) Under-Frequency Load Shedding
 - Revision to conform with NERC & NPCC
 - Recommend retirement since NERC & NPCC are more stringent/specific
 - EC approved posting for comments on 7/17/17, no comments received
 - **Action**: RRS recommends EC final approval

Other RRS matters

- RR&C Manual V41 revision to include:
 - PRR 137 (assuming EC approval)
 - Revision of radial definition to conform with NPCC/NERC
 - Revision of NERC/NPCC references
 - **Action**: In preparation