


**2016 IRM Study
Summer Maintenance Assumption
2015 Summer Maintenance Analysis**

**John Adams
NYSRC Consultant
8/3/2016**




2015 Summer Maintenance Analysis

- Daily MW on maintenance for daily summer peak loads greater than 28,000 MW was developed from data provided by the NYISO.
- The data included 2015 hourly loads and unit planned and maintenance outage events including derates.
- There were 18 daily peak loads which were 28,000 MW or higher.
- The summer peak load was .93 per unit of the forecasted summer peak (PUFSP).
- 14 of the observations were at least .85 PUFSP or higher while 5 were at least .90 PUFSP or higher.
- The summer peak for 2014 was 29,782 or .885 PUFSP.


2015 Summer Maintenance Analysis Continued

- The summer maintenance calculation recommended for last year maintained the value at 50 MW.
- Significantly more maintenance outages were observed than in prior years.
- Many were D4 which is a maintenance derating.
- However, many of the D4s were for the overnight hours but repeated day after day for the same units.
- After review by the NYISO it was decided to remove these D4s from the reported maintenance totals.
- Plots of MW on maintenance VS daily peak loads was prepared for all daily peaks of 28,000 MW or more and all peaks .90 PUSPF or greater for all reported maintenance and maintenance minus the reported nighttime D4s.


2015 Daily Summer Maintenance MW VS Daily Peak Loads
for Loads > 28,000 MW for all MW reported




2015 Daily Summer Maintenance MW VS Daily Peak Loads
for Loads > .90 PU of the Forecasted Peak



2015 Daily Summer Maintenance MW VS Daily Peak Loads
for Loads > 28,000 MW adjusted for overnight D4s



2015 Daily Summer Maintenance MW VS Daily Peak Loads
for Loads > .90 PU of the Forecasted Peak adjuted for D4s




Findings and Recommendations

- After adjusting for overnight D4s, the plot of MW on maintenance is consistent with prior years observations except for September 8.
- The average of MW on maintenance for loads greater than .90 PUFSP including 2 planned outages scheduled for early September was 100 MW.
- If not for the 2 planned outages, one starting on 9/1 and the other that started on 9/8 at 0700, the average would have been approx. 47 MW.
- Recommend maintaining the summer maintenance at 50 MW.
- However, based on what has been observed in the data, I recommend that all of it should be in Zones J&K – 25 MW in each Zone.

Appendix

Maintenance MW VS. Daily Peak Load For 2013 and 2014

2013 Maintenance VS Loads > 28,000 MW



2014 Summer Maintenance VS Daily Peak Loads Loads > than .85 PU of Expected Summer Peak

