2018-2019 NYCA IRM Requirement Study

IRM Base Case Model Assumptions

Assumption Matrix

May 3, 2017

Draft V<u>1.0</u>

Load Parameters

#	Parameter	2017 Model Assumptions	2018 Model Assumptions	Basis for Recommendation	Model Change	Est. IRM Impact*
1	Peak Load Forecast (Preliminary Base Case – Parametric & Sensitivities)	2016 Gold Book NYCA: 33,363 MW NYC: 11,795 MW LI: 5,422 MW G-J: 16,313 MW	2017 Gold Book NYCA: 33,078 MW NYC: 11,707 MW LI: 5,305 MW G-J: 16,070 MW	Gold Book Forecast is used for Preliminary Base Case parametric study and sensitivity cases	N	
2	Peak Load Forecast (Final Base Case)	October 2016 October 2017 NYCA: 33273 MW NYCA: xxxxx MW Forecast based on examination of 2017 weather normalized NYC: 11670 MW NYC: yyyyy MW		N		
3	Load Shape (Multiple Load Shape)	Bin 1: 2006 Bin 2: 2002 Bins 3-7: 2007	Bin 1: 2006 Bin 2: 2002 Bins 3-7: 2007	ICS Recommendation	N	None
4	Load Forecast Uncertainty	Zonal Model to reflect current data with input from Con Ed and LIPA. (Attachment A)	Zonal Model to reflect current data with input from Con Ed and LIPA. (Attachment A)	Based on TO and NYISO data and analyses.	N	

^{*(-)} indicates a reduction in IRM while (+) indicates an increase. Range: Low < 0.5%, Medium 0.5% - 1%, High > 1%

Generation Parameters

#	Parameter	2017 Model Assumptions	2018 Model Assumptions	Basis for Recommendation	Model Change	Est. IRM Impact
1	Existing Generating Unit Capacities	2016 Gold Book values. Use min (DMNC vs. CRIS) capacity value	2017 Gold Book values. Use min (DMNC vs. CRIS) capacity value	2017 Gold Book publication	N	
2	Proposed New Units (Non- Renewable) and re-ratings	0 MW of new non- wind resources. 66.9 MW of project related re- ratings. (Attachment B1)	802.9 MW of new non- wind resources. 78.1 MW of project related re-ratings. (Attachment B1)	2017 Gold Book publication, NYISO interconnection queue, and generator notifications	N	
3	Retirements, Mothballed units, and ICAP ineligible units	260.7MW retirements or mothballs reported or Units in IIFO and IR (Attachment B2)	136.9 MW retirements or mothballs reported or Units in IIFO and IR ¹ (Attachment B2)	2017 Gold Book publication and generator notifications	N	
4	Forced and Partial Outage Rates	Five-year (2011-2015) GADS data for each unit represented. Those units with less than five years – use representative data. (Attachments C and C1)	Five-year (2012-2016) GADS data for each unit represented. Those units with less than five years – use representative data. (Attachments C and C1)	Transition Rates representing the Equivalent Forced Outage Rates (EFORd) during demand periods over the most recent five-year period (2012-2016)	N	
5	Planned Outages	Based on schedules received by the NYISO and adjusted for history	Based on schedules received by the NYISO and adjusted for history	Updated schedules	N	
6	Summer Maintenance	Nominal 50 MWs – divided equally between zones J and K	Nominal xx MWs – divided equally between zones J and K	Review of most recent data	N	

Formatted: Space After: 0 pt, Line spacing: single

¹ ICAP Ineligible Forced Outage (IIFO) and inactive Reserve (IR)

Draft - For Discussion Purposes Only

Diu	Draft - For Discussion Purposes Only							
#	Parameter	2017 Model Assumptions	2018 Model Assumptions	Basis for Recommendation	Model Change	Est. IRM Impact		
7	Combustion Turbine Derates	Derate based on temperature correction curves provided	Derate based on temperature correction curves provided	Operational history indicates the derates are in-line with manufacturer's curves	N			
8	Existing and Proposed New Wind Units	221.1 MW of Wind Capacity additions totaling 1676.2 MW of qualifying wind (Attachment B3)	157.6 MW of Wind Capacity additions totaling 1813.38 MW of qualifying wind (Attachment B3)	Renewable units based on RPS agreements, interconnection queue, and ICS input.	N			
9	Wind Shape	Actual hourly plant output over the period 2011-2015. New units will use zonal hourly averages or nearby units.	Actual hourly plant output over the period 2012-2016. New units will use zonal hourly averages or nearby units.	Program randomly selects a wind shape of hourly production over the years 2012-2016 for each model iteration.	N			
10	Solar Resources (Grid connected)	31.5 MW Solar Capacity. Model chooses from 4 years of production data covering the period 2012-2015.	31.5 MW Solar Capacity. Model chooses from 4-5 years of production data covering the period 2012-2016. (Attachment B3)	Concepts referenced in wind paper apply to solar modeling. GE MARS program will randomly select a solar shape from multiple years of production data.	N			
11	BTM- NG Pgm	N/A	Model these units at their full CRIS adjusted output value (Attachment B5)	Former load modifiers to sell capacity into the ICAP market. Subsequently, the Load forecast will be increased	Y			
12	Small Hydro Resources	Derate by 46%	Actual hourly plant output over the period 2012-2016.	Program randomly selects a Hydro shape of hourly production over the years 2012-2016 for each model iteration.	Y			

<u>Draft</u> - For Discussion Purposes Only

#	Parameter	2017 Model Assumptions	2018 Model Assumptions	Basis for Recommendation	Model Change	Est. IRM Impact
13	Large Hydro	Probabilistic Model based on 5 years of GADS data	Probabilistic Model based on 5 years of GADS data	Transition Rates representing the Equivalent Forced Outage Rates (EFORd) during demand periods over the most recent five-year period (2012-2016)	N	

Transactions – Imports and Exports

#	Parameter	2017 Model Assumptions	2018 Model Assumptions	Basis for Recommendation	Model Change	Est. IRM Impact
1	Capacity Purchases	Grandfathered amounts: PJM – 1080 MW HQ – 1090 MW HQ TO 1110 MW assuming awarded CRIS rights All contracts model as equivalent contracts	Existing Rights: PJM – 1080 MW HQ – 1110 MW All contracts model as equivalent contracts	Grandfathered Rights, ETCNL, and other awarded long-term rights.	N	
2	Capacity Sales	Long Term firm sales Summer 284.9 MW	Long Term firm sales Summer 283.8 MW	These are long term federal contracts.	N	
3	FCM Sales	No Sales within study period	No Sales within study period	White Paper	N	
4			No new UDR projects	Existing UDR elections are made by August 1 st and will be incorporated into the model.	N	

Topology

#	Parameter	2017 Model Assumptions	2018 Model Assumptions	Basis for Recommendation	Model Change	Est. IRM Impact
1	Interface Limits	All changes reviewed and commented on by TPAS (Attachment E)	All changes reviewed and commented on by TPAS (Attachment E)	Based on the most recent NYISO studies and processes, such as Operating Study, Operations Engineering Voltage Studies, Comprehensive System Planning Process, and additional analysis including interregional planning initiatives.	N	
2	New Transmission	None Identified	None Identified	Based on TO provided models and NYISO's review.	N	
3	AC Cable Forced Outage Rates	All existing Cable EFORs updated for NYC and LI to reflect most recent five-year history	DRs updated for and LI to reflect for NYC and LI to reflect trecent five-year reflect most recent re		N	
4	LIDR Forced Outage		Based on NYISO analysis NYISO Review.	N		

Emergency Operating Procedures

#	Parameter	2017 Model Assumptions	2018 Model Assumptions	Basis for Recommendation	Model Change	Est. IRM Impact
1	Special Case Resources	July 2016 –1192MW based on registrations and modeled as 841 MW of effective capacity. Monthly variation based on historical experience*	July 2017 –ddd MW based on registrations and modeled as eee MW of effective capacity. Monthly variation based on historical experience*	SCRs sold for the program discounted to historic availability. Summer values calculated from July 2017 registrations. Performance calculation updated per ICS presentations on SCR performance. (Attachment F)	N	
2	EDRP Resources	July 2016 75 MW registered model as 13 MW in July and proportional to monthly peak load in other months. Limit to five calls per month	July 2017 ff MW registered modeled as gg MW in July and proportional to monthly peak load in other months. Limit to five calls per month	Those sold for the program discounted to historic availability. Summer values calculated from July 2017 registrations and forecast growth.	N	
3	Other EOPs	665 MW of non- SCR/non-EDRP resources	hhh MW of non- SCR/non-EDRP resources (Attachment D)	Based on TO information, measured data, and NYISO forecasts.	N	

^{*} The number of SCR calls is limited to 5/month when calculating LOLE based on all 8,760 hours.

External Control Areas

#	Parameter	2017 Model Assumptions	2018 Model Assumptions	Basis for Recommendation	Model Change	Est. IRM Impact
1	PJM	Load and Capacity data provided by PJM/NPCC CP-8 Data may be adjusted per NYSRC Policy 5 (Attachment E)	Load and Capacity data provided by PJM/NPCC CP-8 Data may be adjusted per NYSRC Policy 5 (Attachment E)	Initial review performed by the NPCC CP-8 WG prior to Policy 5 changes. White paper on external EOPs.	See topology section aboveN	
2	ISONE	Load and Capacity data provided by ISONE/NPCC CP-8 Data may be adjusted per NYSRC Policy 5 (Attachment E)	Load and Capacity data provided by ISONE/NPCC CP-8 Data may be adjusted per NYSRC Policy 5 (Attachment E)	Initial review performed by the NPCC CP-8 WG prior to Policy 5 changes.	N	
3	HQ	Load and Capacity data provided by HQ/NPCC CP-8 Data may be adjusted per NYSRC Policy 5 (Attachment E)	Load and Capacity data provided by HQ/NPCC CP-8 Data may be adjusted per NYSRC Policy 5 (Attachment E)	Initial review performed by the NPCC CP-8 WG prior to Policy 5 changes.	N	
4	IESO	Load and Capacity data provided by IESO/NPCC CP-8 Data may be adjusted per NYSRC Policy 5 (Attachment E)	Load and Capacity data provided by IESO/NPCC CP-8 Data may be adjusted per NYSRC Policy 5 (Attachment E)	Initial review performed by the NPCC CP-8 WG prior to Policy 5 changes.	N	
5	Reserve Sharing	All NPCC Control Areas indicate that they will	All NPCC Control Areas indicate that they will	Per NPCC CP-8 WG.	N	

<u>Draft</u> - For Discussion Purposes Only

#	Parameter	2017 Model Assumptions	2018 Model Assumptions	Basis for Recommendation	Model Change	Est. IRM Impact
		share reserves equally among all members	initially share reserves equally among all members and then among non-members			

<u>Draft</u> - For Discussion Purposes Only


Miscellaneous


#	Parameter	2017 Model Assumptions	2018 Model Assumptions	Basis for Recommendation	Model Change	Est. IRM Impact
1	MARS Model Version	Version 3.20	Version 3.21 Per benchmark testing and ICS recommendation.		N	
2	Environmental based on review of existing rules and retirement trends		No estimated impacts based on review of existing rules and retirement trends	Review of existing regulations and rules.	N	

NYCA Load Forecast Uncertainty Model

2017 and 2018 LFU Models

	2017 Load Forecast Uncertainty Models								
Step	Multiplier	Zones A-E	Zones F&G	Zones H&I	Con Ed (J)	LIPA (K)			
1	0.0062	0.8399	0.7997	0.7992	0.8543	0.7874			
2	0.0606	0.8892	0.8670	0.8598	0.9002	0.8396			
3	0.2417	0.9434	0.9347	0.9197	0.9440	0.9198			
4	0.3830	1.0000	1.0000	0.9768	0.9842	1.0000			
5	0.2417	1.0559	1.0602	1.0291	1.0192	1.0802			
6	0.0606	1.1073	1.1124	1.0746	1.0475	1.1123			
7	0.0062	1.1494	1.1539	1.1113	1.0676	1.1400			





New Non-Wind Units and Unit Re-ratings²

B1 - Pr	oposed N	Ion-wind Units a	nd Unit Re-rating	gs (summer ratings)				
Project or Generator Name	Zone	2017 MARS Model (MW)	2018 Gold Book (MW)	New or Incremental (MW)	2018 MARS Model (MW)			
New Units								
Greenidge 4	С	0	0	106.3	106.3			
Taylor Biomass	G	0	0	19.0	19.0			
Competitive Power Ventures (CPV)	G	0	0	677.6	677.6			
Total New Units		0		802.9	802.9			
		Existing U	nit Re-ratings					
Bethlehem Energy Center	F	756.9	760.5	78.1	835.0			
					·			
Total New Units + Re-rates				881.0				

 $^{^{2}}$ Unit re-ratings are for generation facilities that have undergone uprate projects.

Retiring and Ineligible Generating Units

Attachment B2 -Announced Unit Retirements and ICAP Ineligible Forced Outage (IIFO)								
Generator Name Zone CRIS (MW) CRIS adusted value from 2017 Gold Book (MW)								
Retirements								
Shoreham GT 3	K	45.40	45.50					
Shoreham GT 4	K	43.90	43.90					
Freeport CT1	K	48.30	47.50					
ICAP Ineligible	ICAP Ineligible 0.00 0.00							
Total Retirements		137.60	136.90					

Existing and New Wind Resources

B3 - Wind Resources								
Wind Resouce	Zone	CRIS (MW) Summer Capability (MW)		CRIS adusted value from 2017 Gold Book (MW)				
ICAP Participating Wind Units								
Altona Wind Power	D	97.5	97.5	97.5				
Bliss Wind Power	Α	100.5	100.5	100.5				
Canandaigua Wind Power	С	125.0	125.0	125.0				
Chateaugay Wind Power	D	106.5	106.5	106.5				
Clinton Wind Power	D	100.5	100.5	100.5				
Ellenburg Wind Power	D	81.0	81.0	81.0				
Hardscrabble Wind	E	74.0	74.0	74.0				
High Sheldon Wind Farm	С	112.5	118.1	112.5				
Howard Wind	С	57.4	55.4	55.4				
Madison Wind Power	Е	11.5	11.6	11.5				
Maple Ridge Wind 1	E	231.0	231.0	231.0				
Maple Ridge Wind 2	E	90.7	90.8	90.7				
Munnsville Wind Power	E	34.5	34.5	34.5				
Orangeville Wind Farm	С	94.4	93.9	93.9				
Wethersfield Wind Power	С	126.0	126.0	126.0				
Marble River	D	215.2	215.5	215.2				
		1658.2	1661.8	1655.7				

New and Proposed IRM Study Wind Units							
Jericho Rise D 77.7 77.7 77.7							
Copenhagen Wind	Е	79.9	79.9	79.9			
157.6 157.6 157.6							

Non - ICAP Participating Wind Units								
	Zone	CRIS (MW)	CRIS adusted value from 2017 Gold Book (MW)					
Erie Wind	Α	0.0	15.0	0.0				
Fenner Wind Farm	С	0.0	30.0	0.0				
Steel Wind	Α	0.0	20.0	0.0				
Western NY Wind Power	С	0.0	6.6	0.0				
		0.0	71.6	0.0				
Total Wind Resources		1815.8	1891.0	1813.3				

Existing and New Solar Resources

B4 - Solar Resources							
Wind Resouce Zone		CRIS (MW)	Summer Capability (MW)	CRIS adusted value from 2017 Gold Book (MW)			
		ICAP Part	icipating Solar Units				
Long Island Solar	K	31.50	31.50	31.50			
		31.50	31.50	31.50			
		Proposed I	IRM Study Solar Units				
		0.00	0.00	0.00			
Total Solar Resources		31.50	31.50	31.50			

Resources Modeled the Behind the Meter Net Generation Program (BTM-NG)

Attachment B5 -Rources Modeled in the Behind the Meter Net Generation Program								
Generator Name	me Zone '				CRIS adusted value from 2017 Gold Book (MW)			
Total BTM program Gen		0.0	0.0	0.0	0.0			

Attachment C TBD

Attachment C1 <u>TBD</u>

Emergency Operating Procedures

			2017	2018
Step	Procedure	Effect	MW Value	MW Value
1	Special Case Resources	Load relief	1,192 MW Enrolled/ 841 MW modeled	kkkk MW Enrolled/ III MW modeled
2	Emergency Demand Response Program	Load relief	75 MW Enrolled/13 MW Modeled	mm MW Enrolled/nn MW Modeled
3	5% manual voltage Reduction	Load relief	66 MW	oo MW
4	Thirty-minute reserve to zero	Allow operating reserve to decrease to largest unit capacity (10-minute reserve)	655 MW	655 MW
5	5% remote voltage reduction	Load relief	386 MW	ppp MW
6	Voluntary industrial curtailment	Load relief	125.5 MW	qqq MW
7	General public appeals	Load relief	88 MW	rr MW
8	Emergency Purchases	Increase capacity	Varies	Varies
9	Ten-minute reserve to zero	Allow 10-minute reserve to decrease to zero	1,310 MW	1,310 MW
10	Customer disconnections	Load relief	As needed	As needed

Attachment E TBD

Attachment E1 TBD

Attachment F SCR Determinations

TBD

Assumption Matrix History

Date	Ver	Preliminary Base Case	Ver	Final Base Case	
2/1/17	V00	Preliminary assumptions without attachments.			
3/1/17	V0.1	BTM solar changed to BTM-NG program – see Page 4			
4/2/47	1/4 0	Added draft attachments A and B. Updated Gold			Formatted: Font: +Headings (Cambria), 11 pt
4/3/17	<u>V1.0</u>	<u>B</u> book load forecasts.			Formatted: Font: +Headings (Cambria), 11 pt
					Formatted: Space After: 0 pt, Line spacing: single
					Formatted: Font: +Headings (Cambria), 11 pt
					Formatted: Font: +Headings (Cambria), 11 pt
				Y	Formatted: Font: +Headings (Cambria), 11 pt
					Formatted: Font: +Headings (Cambria), 11 pt
					1
					-