2019-2020 NYCA IRM Requirement Study

Preliminary Base Case (PBC) Model Assumptions

Assumption Matrix

Draft V0

#	Parameter	2018 Model Assumptions	2019 Model Assumptions	Basis for Recommendation	Model Change	Est. IRM Impact*
1	Peak Load Forecast (Preliminary Base Case – Parametric & Sensitivities)	2017 Gold Book NYCA: 33,078 MW NYC: 11,707 MW LI: 5,305 MW G-J: 16,070 MW	2018 Gold Book NYCA: xx,xxx MW NYC: yy,yyy MW LI: z,zzz MW G-J: ww,www MW	Most recent Gold Book Forecast is used for Preliminary Base Case parametric study and sensitivity cases	Ν	
2	Peak Load Forecast (Final Base Case)	October 2017 Fcst. NYCA: 32,868 MW NYC: 11,541 MW LI: 5,445 MW G-J: 15,890 MW	October 2018 Fcst. NYCA: xx,xxx MW NYC: yy,yyy MW LI: z,zzz MW G-J: ww,www MW	Forecast based on examination of 2018 weather normalized peaks. Top three external Area peak days aligned with NYCA	Ν	
3	Load Shape (Multiple Load Shape)	Bin 1: 2006 Bin 2: 2002 Bins 3-7: 2007	Bin 1: 20aa Bin 2: 20bb Bins 3-7: 20cc	ICS Recommendation	N	
4	Load Forecast Uncertainty	Zonal Model to reflect current data with input from Con Ed and LIPA. (Attachment A)	Zonal Model to reflect current data with input from Con Ed and LIPA. (Attachment A)	Based on TO and NYISO data and analyses.	Ν	

Load Parameters

#	Parameter	2018 Model Assumptions	2019 Model Assumptions	Basis for Recommendation	Model Change	Est. IRM Impact*
1	Existing Generating Unit Capacities	2017 Gold Book values. Use min (DMNC vs. CRIS) capacity value	2018 Gold Book values. Use min (DMNC vs. CRIS) capacity value	vs. Latest Gold Book publication		
2	Proposed New Units (Non- Renewable) and re-ratings	784 MW of new non- wind resources, plus 52 MW of project related re-ratings. (Attachment B1)	ddd MW of new non- wind resources, plus ee MW of project related re-ratings. (Attachment B1)	ddd MW of new non- wind resources, plus ee MW of project related e-ratings. (Attachment generator notifications		
3	Retirements, Mothballed units, and ICAP ineligible units	0 MW retirements or mothballs reported or Units in IIFO and IR (Attachment B2)	vv MW retirements or mothballs reported or Units in IIFO and IR ¹ (Attachment B2)	Latest Gold Book publication and generator notifications	Ν	
4	Forced and Partial Outage Rates	Five-year (2012-2016) GADS data for each unit represented. Those units with less than five years – use representative data. (Attachments C and C1)	Five-year (2013-2017) GADS data for each unit represented. Those units with less than five years – use representative data. (Attachments C and C1)	Transition Rates representing the Equivalent Forced Outage Rates (EFORd) during demand periods over the most recent five-year period	Ν	
5	Planned Outages	Based on schedules received by the NYISO and adjusted for history	Based on schedules received by the NYISO and adjusted for history	Updated schedules	Ν	
6	Summer Maintenance	Nominal 50 MWs – divided equally between zones J and K		Review of most recent data	Ν	

Generation Parameters

¹ ICAP Ineligible Forced Outage (IIFO) and inactive Reserve (IR)

²⁰¹⁹ IRM Assumption Matrix Preliminary Base Case V0

#	Parameter	2018 Model Assumptions	2019 Model Assumptions	Basis for Recommendation	Model Change	Est. IRM Impact*
7	Combustion Turbine Derates	Derate based on temperature correction curves provided	Derate based on temperature correction curves provided	Operational history indicates the derates are in-line with manufacturer's curves	Ν	
8	Existing and Proposed New Wind Units	77.7 MW of Wind Capacity additions totaling 1733.4 MW of qualifying wind (Attachment B3)	ggg MW of Wind Capacity additions totaling hhhh MW of qualifying wind (Attachment B3)	Renewable units based on RPS agreements, interconnection queue, and ICS input.	Ν	
9	Wind Shape	Actual hourly plant output over the period 2012-2016. New units will use zonal hourly averages or nearby units.	Actual hourly plant output over the period 2013-2017. New units will use zonal hourly averages or nearby units.	Program randomly selects a wind shape of hourly production from the most recent five-year period for each model iteration.	N	
10	Solar Resources (Grid connected)	Total of 31.5 MW of qualifying Solar Capacity. (Attachment B3)	Total of hh MW of qualifying Solar Capacity. (Attachment B3)	ICAP Resources connected to Bulk Electric System	N	
11	Solar Shape	Actual hourly plant output over the period 2012-2016. New units will use zonal hourly averages or nearby units.	Actual hourly plant output over the period 2013-2017. New units will use zonal hourly averages or nearby units.	Program randomly selects a solar shape of hourly production from the most recent five-year period for each model iteration.	N	
	·					

#	Parameter	2018 Model Assumptions	2019 Model Assumptions	Basis for Recommendation	Model Change	Est. IRM Impact*
12	BTM- NG Program	Change Stony Brook to its full 47 MW output (formerly modeled at 9.6 MW net of host load). Forecast Load adjusted to account for exposure of host load. (Attachment B5)		Both the generation of the participating resource and the full (former) host load is modeled.	Ν	
13	Small Hydro Resources	Derate by 46%	Actual hourly plant output over the period 2013-2017.	Program randomly selects a Hydro shape of hourly production from the most recent five-year period for each model iteration.	N	
14	Large Hydro	Probabilistic Model based on 5 years of GADS data	Probabilistic Model based on 5 years of GADS data (2013-2017)	Transition Rates representing the Equivalent Forced Outage Rates (EFORd) during demand periods over the most recent five-year period	Ν	

#	Parameter	2018 Model Assumptions	2019 Model Assumptions	Basis for Recommendation	Model Change	Est. IRM Impact*
1	Capacity Purchases	Existing Rights: PJM – 1080 MW HQ – 1110 MW All contracts model as equivalent contracts	Existing Rights: PJM – 1080 MW HQ – yyyy MW Cedars – yy MW(?) All contracts model as equivalent contracts	Grandfathered Rights, ETCNL, and other awarded long-term rights.	Ν	
2	Capacity Sales Long Term firm sales Lo		Long Term firm sales Summer xxx MW	These are long term federal contracts.	Ν	
3	FCM Sales	No Sales within study period		White Paper, NYISO recommendation, and ICS discussions	Ν	
4	New UDRs	No new UDR projects	No new UDR projects	Existing UDR elections are made by August 1 st and will be incorporated into the model.	Ν	

Transactions – Imports and Exports

#	Parameter		2019 Model Assumptions	Basis for Recommendation	Model Change	Est. IRM Impact*
1	Interface Limits	All changes reviewed and commented on by TPAS	All changes reviewed and commented on by TPAS (Attachment E)	Based on the most recent NYISO studies and processes, such as Operating Study, Operations Engineering Voltage Studies, Comprehensive System Planning Process, and additional analysis including interregional planning initiatives.	Ν	
2	New Transmission	None Identified	None Identified	Based on TO provided models and NYISO's review.	Ν	
3	AC Cable Forced Outage Rates AC Cable Forced Integrates All existing Cable EFORs updated for NYC and LI to reflect Integration five-year history (2012-2016) All existing Cable EFORs will be updated for NYC and LI to reflect recent five-year history (2013-2017)		TO provided transition rates with NYISO review.	Ν		
4	UDR Line Unavailability	Five year history of forced outages(2012- 2016)	Five year history of forced outages (2013- 2017)	NYISO/TO review.	N	

Topology

#	Parameter	2018 Model Assumptions	2019 Model Assumptions	Basis for Recommendation	Model Change	Est. IRM Impact*
1	Special Case Resources	July 2017 –1219 MW based on registrations and modeled as 868 MW of effective capacity. Monthly variation based on historical experience*	July 2018 –yyyy MW based on registrations and modeled as zzz MW of effective capacity. Monthly variation based on historical experience*	SCRs sold for the program discounted to historic availability. Summer values calculated from July 2018 registrations. Performance calculation updated per ICS presentations on SCR performance. (Attachment F)	Ν	
2	EDRP Resources	July 2017 16 MW registered modeled as 3 MW in July and proportional to monthly peak load in other months. Limit to five calls per month	July 2018 aa MW registered modeled as b MW in July and proportional to monthly peak load in other months. Limit to five calls per month	Those sold for the program discounted to historic availability. Summer values calculated from July registrations and forecast growth.	Ν	
3	Tive calls per month Tive calls per month Other EOPs 609.6 MW of non- SCR/non-EDRP resources Ccc MW of non- SCR/non-EDRP resources (Attachment D)		Based on TO information, measured data, and NYISO forecasts.	Ν		

Emergency Operating Procedures

* The number of SCR calls is limited to 5/month when calculating LOLE based on all 8,760 hours.

#	Parameter	er 2018 Model 2019 Model Assumptions Assumptions		Basis for Recommendation	Model Change	Est. IRM Impact*
1	PJM	Load and Capacity data provided by PJM/NPCC CP-8 Data may be adjusted per NYSRC Policy 5	Load and Capacity data provided by PJM/NPCC CP-8 Data may be adjusted per NYSRC Policy 5 (Attachment E)	Initial review performed by the NPCC CP-8 WG prior to Policy 5 changes.	Ν	
2	ISONE, Quebec, IESO	bec, Load and Capacity data provided by ISONE/NPCC CP-8 Load and Capacity data provided by ISONE/NPCC CP-8 Data may be adjusted		Initial review performed by the NPCC CP-8 WG prior to Policy 5 changes.	Ν	
5	Reserve Sharing	All NPCC Control Areas indicate that they will share reserves equally among all members and then among non- members	All NPCC Control Areas indicate that they will initially share reserves equally among all members and then among non-members	Per NPCC CP-8 WG.	Ζ	
6	Emergency Assistance	Statewide Limit of 3,500 MW of emergency assistance allowed from neighbors.	Statewide Limit of 3,500 MW of emergency assistance allowed from neighbors.	White paper on Modelling of Emergency Assistance for NYCA in IRM studies	Ν	

External Control Areas

Miscellaneous

#	Parameter2018 Model Assumptions2019 Model Assumptions		Basis for Recommendation	Model Change	Est. IRM Impact*	
1	MARS Model Version	Version 3.21.9	Version d.e.f	Per benchmark testing and ICS recommendation.	Ν	
2	Environmental Initiatives	No estimated impacts based on review of existing rules and retirement trends		Review of existing regulations and rules.	Ν	

Attachment A

NYCA Load Forecast Uncertainty Model

Attachment B1

New Non-Wind Units and Unit Re-ratings²

Attachment B2

Retiring and Ineligible Generating Units

Attachment B3

Existing and New Wind Resources

Attachment B4

Existing and New Solar Resources

Attachment B5

Resources and Peak Load Adjustment Modeled in the Behind the Meter Net Generation Program (BTM-NG)

² Unit re-ratings are for generation facilities that have undergone uprate projects.

Attachment C NYCA Annual EFORds

Attachment C1

NYCA Five Year EFORds

Attachment D Emergency Operating Procedures

> Attachment E IRM Topology

> Attachment F SCR Determinations

Assumption Matrix History

Date	Ver	Preliminary Base Case	Date	Ver	Final Base Case
1/30/18	V00	Preliminary assumptions without attachments.			