

Study Results of Maintaining Operating Reserve at Load Shedding

Yvonne Huang ICAP Market Operations

ICS Meeting # 259

March 29, 2022

Background

- For the 2023 IRM study, the NYISO is evaluating whether to maintain operating reserves ("OR") during load shedding events
 - Specifically, the NYISO is evaluating whether to maintain some level of 10-minute OR which is capable of accommodating system volatility during load shedding
- The topic was discussed at the past two ICS meetings, and NYISO provided preliminary parametric results with three levels of withheld OR and three allocation methods
 - The current IRM model includes 1,310 MW of 10-minute OR in Zones F, G, J, and K
- At the 3/2 meeting, the ICS agreed to conduct the Tan45 and optimized LCR process on withholding 500 MW OR with proportional distribution based on the current OR allocation
 - The NYISO conducted the Tan45 process for all three levels of the maintained OR, with the distribution based on the current allocation of 10-minute OR

2/2 ICS Discussion: https://www.nysrc.org/PDF/MeetingMaterial/ICSMeetingMaterial/ICS%20Agenda%20257/A.I.4.1%20-%20LoadShedding-and-Reserves_final[2557].pdf 3/2 ICS Discussion:

https://www.nysrc.org/PDF/MeetingMaterial/ICSMeetingMaterial/ICS%20Agenda%20258/AI-9.1%200perating_Reserve_at%20LoadShedding_ICS%2003022022[3113].pdf https://www.nysrc.org/PDF/MeetingMaterial/ICSMeetingMaterial/ICS%20Agenda%20258/AI-9.2%20Preliminary_Results_Operating_Reserve_ICS03032022[3114].pdf



Recap of Modeling Methodology

- Currently 10-minute OR is modeled as Emergency Operating Procedure ("EOP") step 8 in the IRM, which MARS will count on to address system shortages.
- The current 10-minute OR distribution and the allocation of the maintained OR at three different MW levels are shown as below:

Current 10-Minute OR EOP 8			Maintain <u>327.5 MW</u> OR at	Maintain <u>500 MW</u> OR at	Maintain <u>655 MW</u> OR at
Zone		MW (%)	Load Shedding	Load Shedding	Load Shedding
Upstate	NY_F	518 (40%)	129.5	197.7	259.0
	NY_G	314 (24%)	78.5	119.8	157.0
Downstate	NY_J	358 (37%)	89.5	136.6	179.0
	NY_K	120 (9%)	30.0	45.8	60.0
<u>TOTAL</u>		<u>1310</u>	<u>327.5</u>	<u>500</u>	<u>655</u>

Tan45 Results

Tan45 Results	2022 FBC with Neptune Outage	Maintain <u>327.5 MW</u> OR at Load Shedding	Maintain <u>500 MW</u> OR at Load Shedding	Maintain <u>655 MW</u> OR at Load Shedding
IRM	19.6%	20.7%	21.5%	22.2%
J_LCR	80.7%	81.9%	82.4%	82.8%
K_LCR	99.8%	101.0%	101.4%	101.8%
NYBA EOP	38.4	37.9	37.5	37.2

The Tan45 results are generally consistent with the parametric results.

- IRM and the preliminary LCRs would increase proportionally to the MW level of the maintained OR
- Impacts on the EOP activations are minimal as the Tan45 process shifted the MW requirement towards downstate and the EOP are mainly driven by upstate.
- The NYISO is working on the optimized LCR process with the above configurations. The Tan45 results demonstrate the IRM impact of maintaining OR at load shedding.

Next Step

- NYISO to propose the MW level of maintaining OR for load shedding, and allocation method to be included in the IRM study
- If the recommendation is accepted, for the 2023-2024 IRM
 - Model no withholding of OR in the Preliminary Base Case (historic modeling)
 - Conduct a sensitivity case with maintaining OR based on the accepted recommendation
 - Consider modeling the withholding of OR in the Final Base Case
- Beyond the 2023-2024 IRM, evaluate the effect of maintaining OR for load shedding in the IRM study and determine whether the modeling configuration needs to be changed for future studies



Questions?



Our Mission & Vision

 \checkmark

Mission

Ensure power system reliability and competitive markets for New York in a clean energy future



Vision

Working together with stakeholders to build the cleanest, most reliable electric system in the nation

