

Data Scrub

A.13 GE IRM Model Data Scrub

Item	Description	Disposition	Data Change	Post PBC* Affect
1	Unit name changes between 2018 and 2019 study were identified	Name changes were reviewed and accepted	No	N/A
2	Three units added with 0 MW of capacity	Capacities were checked and were correct.	No	N/A
3	Rockville Center (Charles Keller) unit 8 not in list of deactivated units	Unit retired and will be added to assumptions matrix. Retirement correctly captured in model.	No	N/A
4	Stony Book rating not documented in assumptions matrix	Added unit back to assumptions matrix for FBC	No	N/A
5	Several units modeled as single unit versus two units last year	Reviewed. Unit modeling is consistent with GADs reporting	No	N/A
6	Six units identified with large EFORD change	One unit retired and the other five went through a second review and were found correct in the model	No	N/A
7	Energy, even though not an explicit IRM assumption, appears higher in model than gold book forecast	A known effect of growing historical load shapes to meet future peaks. Initiative underway to study alternatives.	No	N/A

*Preliminary Base Case