

Alternative LCR Method Update and

Informational LCR Results

Nathaniel Gilbraith NYISO Market Operations

NYSRC – ICS Meeting #213

October 30, 2018 NYISO, Rensselaer, NY

DRAFT – FOR DISCUSSION PURPOSES ONLY



©COPYRIGHT NYISO 2018. ALL RIGHTS RESERVED

This presentation re-posts the presentation given to the NYISO ICAP Working Group on 10/18/2018



DRAFT – FOR DISCUSSION PURPOSES ONLY

©COPYRIGHT NYISO 2018. ALL RIGHTS RESERVED

Background

- On June 5, 2018, the NYISO filed with FERC tariff revisions that would put in place an updated method to of calculate LCRs
- On October 5, 2018, FERC issued an Order accepting revisions to the NYISO's Market Services Tariff that became effective October 9, 2018 (this has been referred to as "the Alternative LCR Method")



Agenda & Schedule

This presentation provides:

- A description of the NYISO process for the remainder of 2018 to implement the new methodology described in Section 5.11.4 of the Market Services Tariff
- Illustrative LCR results using a preliminary IRM case

Schedule

- The NYISO plans to present informational LCRs based on the final IRM case as presented to the New York State Reliability Council
- The NYISO intends to post a revised LCR Calculation Procedure that describes the annual process to determine LCRs for the 2019 Capability Year and going
 - This will replace the existing posted G-J Locality LCR procedure
- The NYISO will calculate final LCRs for the 2019-20 Capability Year using the NYSRC- approved IRM and present these to the Operating Committee in January 2019



2019-2020 Capability Year LCR process

- The NYISO will produce informational LCRs for certain IRM cases to inform stakeholders as it develops the LCRs under the newly accepted method. All such results will be informational only and presented as they become available
- NYISO will update necessary parameters and documentation in order to calculate final 2019-2020 LCRs in January 2019
 - MARS database
 - The final LCR database will start with the IRM Final Base Case, incorporate the December load forecast, and update for any material changes as described in the 2018 LCR process

2019-2020 Capability Year LCR process (con't)

- Net CONE Curves
 - 2019-2020 Net CONE Curves used to calculate final LCRs will be updated from the 2018 market design cost curves using the 2019-2020 Capability Year updated ICAP Demand Curve reference points
 - 2019-2020 updated reference points (the starting point for 2019-2020 Net CONE Curves) will be available by November 30, 2018
- Transmission Security Limits
 - 2019-2020 Transmission Security Limits will be calculated from final peak Load, EFORd, and N-1-1 transmission study results
 - Final peak Load data will be based on the December Load Forecast
 - Final EFORd data will be from the final MARS database
 - N-1-1 transmission study results are shown in the TSL report posted with this presentation



Inputs used to develop LCRs in this presentation

NYISO LCR production software

- The results presented were produced using software to implement the tariff methodology
- A preliminary IRM MARS database (*i.e.*, Master Input File MIF)
 - The cases below use several MIFs, as described in subsequent slides

Net CONE Curves

 All LCR results in this presentation use the 2018 cost curves as previously presented to stakeholders including at the time of the BIC vote on the market design. See the appendix to this presentation, which is Slide 17 of the presentation at the following web link: http://www.nyiso.com/public/webdocs/markets_operations/committees/bic_icapwg/meeting_materials/2018-02-

06/ICAPWG_2-06-18_AlternativeMethodsforLCRs_Final.pdf

Transmission Security Limits ("TSLs")

- All LCR results in this presentation use updated values from previously calculated limits, as shown on the next slide
- Previously calculated limits from the 2018 market design were previously presented to stakeholders including at the time of the BIC vote on the market design. See the appendix to this presentation, which is Slide 18 of the presentation at the following web link:

http://www.nyiso.com/public/webdocs/markets_operations/committees/bic_icapwg/meeting_materials/2018-02-06/ICAPWG_2-06-18_AlternativeMethodsforLCRs_Final.pdf



Updated TSL details

Preliminary Base Case TSL calculations

Transmission Security Requirements	Formula	GHIJ	NYC	LI	Source
Load Forecast (MW)	[A] = Given	15,815	11,474	5,323	2019 load from 2018 GB
Transmission Security Limit (MW)	[B] = Given	3,000	3,175	350	2018 transfer limits
Minimum UCAP Needed (MW)	[C] = [A]-[B]	12,815	8,299	4,973	
UCAP Needed Percent	[D] = [C]/[A]	81.03%	72.33%	93.42%	
5 Year EFORd	[E] = Given	9.63%	9.67%	9.79%	8/21 PBC EFORd
ICAP Needed (MW)	[F] = [C]/(1-[E])	14,181	9,187	5,513	
ICAP Floor Requirement (TSLs)	[G] = [F]/[A]	<u>89.67%</u>	<u>80.07%</u>	<u>103.56%</u>	2019 PBC TSLs



DRAFT – FOR DISCUSSION PURPOSES ONLY

©COPYRIGHT NYISO 2018. ALL RIGHTS RESERVED

Case 1: LCRs presented to NYSRC on 9/5/2018

Master Input File

IRM Preliminary Base Case (PBC) MIF

Case: 2019 PBC	NYCA	G-J	NYC	LI	LOLE	Total Cost (MM\$)**
TAN 45 LCRs [†]	116.9%	94.9%*	79.2%	100.7%	0.100	\$4,980.1
Alternate LCRs	116.9%	89.7%***	80.1%***	103.6%***	0.100	\$4,973.2
deltas	0.0%	-5.2%	0.9%	2.9%	-	-\$6.9

* As-found condition for the G-J Locality given the PBC IRM and LCRs.

** Total cost as calcuated by the LCR production software, at the level of excess, considering Net CONE Curves.
*** The LCR production software rounds LCRs to the nearst 0.1%. The TSL limit was binding for all locations.
† NYSRC Indicative LCRs



Case 2: LCRs on the PBC with B and C lines out of service

- The New York State Reliability Council has indicated this sensitivity is a likely candidate for inclusion in the final IRM case
- Master Input File
 - IRM Preliminary Base Case (PBC) MIF, removing the B and C lines (from PJM to NYISO Zone J) from service



Case 2: LCR results

Case: 2019 PBC w/o B&C lines	NYCA	G-J	NYC	LI	LOLE	Total Cost (MM\$)**
TAN 45 LCRs ⁺	116.7%	96.8%*	81.8%	101.3%	0.100	\$5,034.0
Alternate LCRs	116.7%	92.7%	82.1%	103.6%	0.100	\$5,020.4
deltas	0.0%	-4.1%	0.3%	2.3%	-	-\$13.6

* As-found condition for the G-J Locality given the IRM and LCRs.

** Total cost as calcuated by the LCR production software, at the level of excess, considering Net CONE Curves.

† NYSRC Indicative LCRs



Informational October 2018 TSL update

TSL calculation using data available as of October 2018

Transmission Security Requirements	Formula	GHIJ	NYC	LI	Source
Load Forecast (MW)	[A] = Given	15,831	11,585	5,346	2019 IRM Load Forecast (9/28 LFTF)
Transmission Security Limit (MW)	[B] = Given	3,200	3,200	350	2019-2020 transfer limits
UCAP Requirement (MW)	[C] = [A]-[B]	12,631	8,385	4,996	
UCAP Requirement Percent	[D] = [C]/[A]	79.79%	72.38%	93.45%	
5 Year EFORd	[E] = Given	9.63%	9.67%	9.79%	8/21 PBC EFORd
ICAP Requirement (MW)	[F] = [C]/(1-[E])	13,977	9,283	5,538	
ICAP Floor Requirement (TSLs)	[G] = [F]/[A]	<u>88.29%</u>	<u>80.13%</u>	<u>103.59%</u>	informational TSLs

- The G-J Locality TSL decreased by more than one percentage point, other Locality TSLs were relatively unchanged
- These TSLs were not available when the preliminary IRM case was presented to the NYS Reliability Council (Case 1) and they were not used in Case 2
 - These TSL values are not expected to be a binding constraint in the optimization



Next steps

- The NYISO will return to ICAPWG in November and present informational LCRs based on the final IRM case, as presented to the New York State Reliability Council
 - NYISO will also present materials to the NYSRC-Installed Capacity Subcommittee
- The NYISO will calculate final LCRs in January 2019
- Final LCRs will be presented to the OC in January 2019



Questions?

Questions or comments can be sent to

deckels@nyiso.com



DRAFT – FOR DISCUSSION PURPOSES ONLY © COPYRIGHT NYISO 2018. ALL RIGHTS RESERVED.

The Mission of the New York Independent System Operator, in collaboration with its stakeholders, is to serve the public interest and provide benefits to consumers by:

- Maintaining and enhancing regional reliability
- Operating open, fair and competitive wholesale electricity markets
- Planning the power system for the future
- Providing factual information to policy makers, stakeholders and investors in the power system



www.nyiso.com




Appendix



DRAFT – FOR DISCUSSION PURPOSES ONLY © COPYRIGHT NYISO 2018. ALL RIGHTS RESERVED.

Net CONE curves from 2/6/18 BIC

2018 Net CONE Curves (Uncollared)



17

Transmission security limits from 2/6/18 BIC

2018 Transmission Security Limits

Transmission Security Requirements	G-J	Zone J	Zone K
Load Forecast (MW)	15,890	11,541	5,445
Transmission Security Import Limit (MW)	3,000	3,175	350
Transmission Security UCAP Requirement (MW)	12,890	8,366	5,095
Transmission Security UCAP Requirement (%)	81.1%	72.5%	93.6%
5 Year EFORd (%)	9.55%	9.05%	9.26%
Transmission Security ICAP Requirement (MW)	14,250	9,198	5,615
Transmission Security LCR Floor (%)	89.7%	79.7%	103.1%

