

2018-2019 NYCA IRM Requirement Study

IRM Final Base Case Model Assumptions

Assumption Matrix

Approved by NYSRC EC on October 13, 2017

Load Parameters

| # | Parameter | 2017 Model Assumptions | 2018 Model Assumptions | Basis for Recommendation | Model Change |
|---|--|---|---|---|--------------|
| 1 | Peak Load Forecast (Preliminary Base Case – Parametric & Sensitivities) | 2016 Gold Book NYCA: 33,363 MW NYC: 11,795 MW LI: 5,422 MW G-J: 16,313 MW | 2017 Gold Book NYCA: 33,078 MW NYC: 11,707 MW LI: 5,305 MW G-J: 16,070 MW | Gold Book Forecast is used for Preliminary Base Case parametric study and sensitivity cases | N |
| 2 | Peak Load Forecast (Final Base Case) | October 2016 NYCA: 33273 MW NYC: 11670 MW LI: 5450 MW G-J: 16073 MW | October 2017 NYCA: 32,868 MW NYC: 11,541 MW LI: 5,445 MW G-J: 15,890 MW | Forecast based on examination of 2017 weather normalized peaks. Top three external Area peak days aligned with NYCA | N |
| 3 | Load Shape (Multiple Load Shape) | Bin 1: 2006 Bin 2: 2002 Bins 3-7: 2007 | Bin 1: 2006 Bin 2: 2002 Bins 3-7: 2007 | ICS Recommendation | N |
| 4 | Load Forecast Uncertainty | Zonal Model to reflect current data with input from Con Ed and LIPA. (Attachment A) | Zonal Model to reflect current data with input from Con Ed and LIPA. (Attachment A) | Based on TO and NYISO data and analyses. | N |

Generation Parameters

| # | Parameter | 2017 Model Assumptions | 2018 Model Assumptions | Basis for Recommendation | Model Change |
|---|--|--|--|--|--------------|
| 1 | Existing Generating Unit Capacities | 2016 Gold Book values. Use min (DMNC vs. CRIS) capacity value | 2017 Gold Book values. Use min (DMNC vs. CRIS) capacity value | 2017 Gold Book publication | N |
| 2 | Proposed New Units (Non-Renewable) and re-ratings | 0 MW of new non- wind resources. 66.9 MW of project related re-ratings. (Attachment B1) | 784 MW of new non-wind resources, plus 52 MW of project related re-ratings. (Attachment B1) | 2017 Gold Book publication, NYISO interconnection queue, and generator notifications | N |
| 3 | Retirements, Mothballed units, and ICAP ineligible units | 260.7MW retirements or mothballs reported or Units in IIFO and IR (Attachment B2) | 0 MW retirements or mothballs reported or Units in IIFO and IR ¹ (Attachment B2) | 2017 Gold Book publication and generator notifications | N |
| 4 | Forced and Partial Outage Rates | Five-year (2011-2015) GADS data for each unit represented. Those units with less than five years – use representative data. (Attachments C and C1) | Five-year (2012-2016) GADS data for each unit represented. Those units with less than five years – use representative data. (Attachments C and C1) | Transition Rates representing the Equivalent Forced Outage Rates (EFORd) during demand periods over the most recent five-year period (2012-2016) | N |
| 5 | Planned Outages | Based on schedules received by the NYISO and adjusted for history | Based on schedules received by the NYISO and adjusted for history | Updated schedules | N |
| 6 | Summer Maintenance | Nominal 50 MWs – divided equally between zones J and K | Nominal 50 MWs – divided equally between zones J and K | Review of most recent data | N |

¹ ICAP Ineligible Forced Outage (IIFO) and inactive Reserve (IR)

| # | Parameter | 2017 Model Assumptions | 2018 Model Assumptions | Basis for Recommendation | Model Change |
|----|--------------------------------------|---|---|--|--------------|
| 7 | Combustion Turbine Derates | Derate based on temperature correction curves provided | Derate based on temperature correction curves provided | Operational history indicates the derates are in-line with manufacturer's curves | N |
| 8 | Existing and Proposed New Wind Units | 221.1 MW of Wind Capacity additions totaling 1676.2 MW of qualifying wind (Attachment B3) | 77.7 MW of Wind Capacity additions totaling 1733.4 MW of qualifying wind (Attachment B3) | Renewable units based on RPS agreements, interconnection queue, and ICS input. | N |
| 9 | Wind Shape | Actual hourly plant output over the period 2011-2015. New units will use zonal hourly averages or nearby units. | Actual hourly plant output over the period 2012-2016. New units will use zonal hourly averages or nearby units. | Program randomly selects a wind shape of hourly production over the years 2012-2016 for each model iteration. | N |
| 10 | Solar Resources (Grid connected) | 31.5 MW Solar Capacity. Model chooses from 4 years of production data covering the period 2012-2015. | Total of 31.5 MW of qualifying Solar Capacity. (Attachment B3) | ICAP Resources connected to Bulk Electric System | N |
| 11 | Solar Shape | Actual hourly plant output over the period 2011-2015. New units will use zonal hourly averages or nearby units. | Actual hourly plant output over the period 2012-2016. New units will use zonal hourly averages or nearby units. | Program randomly selects a solar shape of hourly production over the years 2012-2016 for each model iteration. | N |

| # | Parameter | 2017 Model Assumptions | 2018 Model Assumptions | Basis for Recommendation | Model Change |
|----|-----------------------|---|---|--|--------------|
| 12 | BTM- NG Program | N/A | Change Stony Brook to its full 47 MW output (formerly modeled at 9.6 MW net of host load). Forecast Load adjusted to account for exposure of host load. (Attachment B5) | Both the generation of the participating resource and the full (former) host load is modeled. | Y |
| 13 | Small Hydro Resources | Derate by 46% | Actual hourly plant output over the period 2012-2016. | Program randomly selects a Hydro shape of hourly production over the years 2012-2016 for each model iteration. | Y |
| 14 | Large Hydro | Probabilistic Model based on 5 years of GADS data | Probabilistic Model based on 5 years of GADS data | Transition Rates representing the Equivalent Forced Outage Rates (EFORd) during demand periods over the most recent five-year period (2012-2016) | N |

Transactions – Imports and Exports

| # | Parameter | 2017 Model Assumptions | 2018 Model Assumptions | Basis for Recommendation | Model Change |
|---|--------------------|--|--|--|--------------|
| 1 | Capacity Purchases | Grandfathered amounts: PJM – 1080 MW HQ – 1090 MW HQ TO 1110 MW assuming awarded CRIS rights All contracts model as equivalent contracts | Existing Rights: PJM – 1080 MW HQ – 1110 MW All contracts model as equivalent contracts | Grandfathered Rights, ETCNL, and other awarded long-term rights. | N |
| 2 | Capacity Sales | Long Term firm sales Summer 284.9 MW | Long Term firm sales Summer 283.8 MW | These are long term federal contracts. | N |
| 3 | FCM Sales | No Sales within study period | No Sales within study period | White Paper | N |
| 4 | New UDRs | No new UDR projects | No new UDR projects | Existing UDR elections are made by August 1 st and will be incorporated into the model. | N |

Topology

| # | Parameter | 2017 Model Assumptions | 2018 Model Assumptions | Basis for Recommendation | Model Change |
|---|------------------------------|--|--|---|--------------|
| 1 | Interface Limits | All changes reviewed and commented on by TPAS (Attachment E) | All changes reviewed and commented on by TPAS (Attachment E) | Based on the most recent NYISO studies and processes, such as Operating Study, Operations Engineering Voltage Studies, Comprehensive System Planning Process, and additional analysis including interregional planning initiatives. | N |
| 2 | New Transmission | None Identified | None Identified | Based on TO provided models and NYISO's review. | N |
| 3 | AC Cable Forced Outage Rates | All existing Cable EFORs updated for NYC and LI to reflect most recent five-year history | All existing Cable EFORs will be updated for NYC and LI to reflect most recent five-year history | TO provided transition rates with NYISO review. | N |
| 4 | UDR Line Unavailability | Five year history of forced outages | Five year history of forced outages | NYISO/TO review. | N |

Emergency Operating Procedures

| # | Parameter | 2017 Model Assumptions | 2018 Model Assumptions | Basis for Recommendation | Model Change |
|---|------------------------|---|--|--|--------------|
| 1 | Special Case Resources | July 2016 –1192MW based on registrations and modeled as 841 MW of effective capacity. Monthly variation based on historical experience* | July 2017 –1219 MW based on registrations and modeled as 868 MW of effective capacity. Monthly variation based on historical experience* | SCRs sold for the program discounted to historic availability. Summer values calculated from July 2017 registrations. Performance calculation updated per ICS presentations on SCR performance. (Attachment F) | N |
| 2 | EDRP Resources | July 2016 75 MW registered model as 13 MW in July and proportional to monthly peak load in other months. Limit to five calls per month | July 2017 16 MW registered modeled as 3 MW in July and proportional to monthly peak load in other months. Limit to five calls per month | Those sold for the program discounted to historic availability. Summer values calculated from July 2017 registrations and forecast growth. | N |
| 3 | Other EOPs | 665 MW of non-SCR/non-EDRP resources | 609.6 MW of non-SCR/non-EDRP resources (Attachment D) | Based on TO information, measured data, and NYISO forecasts. | N |

* The number of SCR calls is limited to 5/month when calculating LOLE based on all 8,760 hours.

External Control Areas

| # | Parameter | 2017 Model Assumptions | 2018 Model Assumptions | Basis for Recommendation | Model Change |
|---|-----------|--|--|---|--------------|
| 1 | PJM | Load and Capacity data provided by PJM/NPCC CP-8 Data may be adjusted per NYSRC Policy 5 (Attachment E) | Load and Capacity data provided by PJM/NPCC CP-8 Data may be adjusted per NYSRC Policy 5 (Attachment E) | Initial review performed by the NPCC CP-8 WG prior to Policy 5 changes. | N |
| 2 | ISONE | Load and Capacity data provided by ISONE/NPCC CP-8 Data may be adjusted per NYSRC Policy 5 (Attachment E) | Load and Capacity data provided by ISONE/NPCC CP-8 Data may be adjusted per NYSRC Policy 5 (Attachment E) | Initial review performed by the NPCC CP-8 WG prior to Policy 5 changes. | N |
| 3 | HQ | Load and Capacity data provided by HQ/NPCC CP-8 Data may be adjusted per NYSRC Policy 5 (Attachment E) | Load and Capacity data provided by HQ/NPCC CP-8 Data may be adjusted per NYSRC Policy 5 (Attachment E) | Initial review performed by the NPCC CP-8 WG prior to Policy 5 changes. | N |
| 4 | IESO | Load and Capacity data provided by IESO/NPCC CP-8 Data may be adjusted per NYSRC Policy 5 (Attachment E) | Load and Capacity data provided by IESO/NPCC CP-8 Data may be adjusted per NYSRC Policy 5 (Attachment E) | Initial review performed by the NPCC CP-8 WG prior to Policy 5 changes. | N |

| # | Parameter | 2017 Model Assumptions | 2018 Model Assumptions | Basis for Recommendation | Model Change |
|---|----------------------|---|--|--|--------------|
| 5 | Reserve Sharing | All NPCC Control Areas indicate that they will share reserves equally among all members | All NPCC Control Areas indicate that they will initially share reserves equally among all members and then among non-members | Per NPCC CP-8 WG. | N |
| 6 | Emergency Assistance | No Limit | Statewide Limit of 3,500 MW of emergency assistance allowed from neighbors. | White paper on Modelling of Emergency Assistance for NYCA in IRM studies | Y |

Miscellaneous

| # | Parameter | 2017 Model Assumptions | 2018 Model Assumptions | Basis for Recommendation | Model Change |
|---|---------------------------|--|--|---|--------------|
| 1 | MARS Model Version | Version 3.20 | Version 3.21.9 | Per benchmark testing and ICS recommendation. | N |
| 2 | Environmental Initiatives | No estimated impacts based on review of existing rules and retirement trends | No estimated impacts based on review of existing rules and retirement trends | Review of existing regulations and rules. | N |



Attachment A

NYCA Load Forecast Uncertainty Model

2017 and 2018 LFU Models

| 2017 Load Forecast Uncertainty Models | | | | | | |
|---------------------------------------|------------|-----------|-----------|-----------|------------|----------|
| Step | Multiplier | Zones A-E | Zones F&G | Zones H&I | Con Ed (J) | LIPA (K) |
| 1 | 0.0062 | 0.8399 | 0.7997 | 0.7992 | 0.8543 | 0.7874 |
| 2 | 0.0606 | 0.8892 | 0.8670 | 0.8598 | 0.9002 | 0.8396 |
| 3 | 0.2417 | 0.9434 | 0.9347 | 0.9197 | 0.9440 | 0.9198 |
| 4 | 0.3830 | 1.0000 | 1.0000 | 0.9768 | 0.9842 | 1.0000 |
| 5 | 0.2417 | 1.0559 | 1.0602 | 1.0291 | 1.0192 | 1.0802 |
| 6 | 0.0606 | 1.1073 | 1.1124 | 1.0746 | 1.0475 | 1.1123 |
| 7 | 0.0062 | 1.1494 | 1.1539 | 1.1113 | 1.0676 | 1.1400 |

| 2018 Load Forecast Uncertainty Models | | | | | | |
|---------------------------------------|------------|-----------|-----------|-----------|------------|----------|
| Step | Multiplier | Zones A-E | Zones F&G | Zones H&I | Con Ed (J) | LIPA (K) |
| 1 | 0.0062 | 0.8431 | 0.8067 | 0.7978 | 0.8388 | 0.7659 |
| 2 | 0.0606 | 0.8944 | 0.8674 | 0.8624 | 0.8887 | 0.8351 |
| 3 | 0.2417 | 0.9474 | 0.9303 | 0.9249 | 0.9371 | 0.9175 |
| 4 | 0.3830 | 1.0000 | 0.9933 | 0.9817 | 0.9821 | 1.0000 |
| 5 | 0.2417 | 1.0502 | 1.0541 | 1.0293 | 1.0219 | 1.0695 |
| 6 | 0.0606 | 1.0959 | 1.1107 | 1.0639 | 1.0547 | 1.1206 |
| 7 | 0.0062 | 1.1351 | 1.1608 | 1.0822 | 1.0786 | 1.1586 |



Attachment B1

New Non-Wind Units and Unit Re-ratings²

| B1 - Proposed Non-wind Units and Unit Re-ratings (summer ratings) | | | | | |
|---|--------------|----------------------|---------------------|-------------------------|----------------------|
| Project or Generator Name | Zone | 2017 MARS Model (MW) | 2017 Gold Book (MW) | New or Incremental (MW) | 2018 MARS Model (MW) |
| New Units | | | | | |
| Greenidge 4 | C | 0 | 0 | 106.3 | 106.3 |
| Taylor Biomass* | G | 0 | 0 | 19.0 | 19.0 |
| Competitive Power Ventures (CPV) | G | 0 | 0 | 677.6 | 677.6 |
| Total New Units | | 0 | | 783.9 | 783.9 |
| Existing Unit Re-ratings | | | | | |
| Bethlehem Energy Center | F | 756.9 | 760.5 | 52.0 | 808.9 |
| | | | | | |
| | | | | | |
| | | | | | |
| Total New Units + Re-rates | | | | 835.9 | |

² Unit re-ratings are for generation facilities that have undergone uprate projects.

Attachment B2

Retiring and Ineligible Generating Units

| Attachment B2 -Announced Unit Retirements and ICAP Ineligible Forced Outage (IIFO) | | | |
|---|-------------|-----------------------------|--|
| Generator Name | Zone | CRIS (MW) | CRIS adusted value from 2017 Gold Book (MW) |
| Retirements | | | |
| Shoreham GT 3 | K | Retirement Notice Rescinded | |
| Shoreham GT 4 | K | Retirement Notice Rescinded | |
| Freeport CT1 | K | Retirement Notice Rescinded | |
| | | | |
| | | | |
| ICAP Ineligible | | 0.00 | 0.00 |
| Total Retirements | | 0.00 | 0.00 |

Attachment B3

Existing and New Wind Resources

| B3 - Wind Resources | | | | |
|--|------|---------------|------------------------------|--|
| Wind Resource | Zone | CRIS (MW) | Summer Capability (MW) | CRIS adusted value from 2017 Gold Book (MW) |
| ICAP Participating Wind Units | | | | |
| Altona Wind Power | D | 97.5 | 97.5 | 97.5 |
| Bliss Wind Power | A | 100.5 | 100.5 | 100.5 |
| Canandaigua Wind Power | C | 125.0 | 125.0 | 125.0 |
| Chateaugay Wind Power | D | 106.5 | 106.5 | 106.5 |
| Clinton Wind Power | D | 100.5 | 100.5 | 100.5 |
| Ellenburg Wind Power | D | 81.0 | 81.0 | 81.0 |
| Hardscrabble Wind | E | 74.0 | 74.0 | 74.0 |
| High Sheldon Wind Farm | C | 112.5 | 118.1 | 112.5 |
| Howard Wind | C | 57.4 | 55.4 | 55.4 |
| Madison Wind Power | E | 11.5 | 11.6 | 11.5 |
| Maple Ridge Wind 1 | E | 231.0 | 231.0 | 231.0 |
| Maple Ridge Wind 2 | E | 90.7 | 90.8 | 90.7 |
| Munnsville Wind Power | E | 34.5 | 34.5 | 34.5 |
| Orangeville Wind Farm | C | 94.4 | 93.9 | 93.9 |
| Wethersfield Wind Power | C | 126.0 | 126.0 | 126.0 |
| Marble River | D | 215.2 | 215.5 | 215.2 |
| | | 1658.2 | 1661.8 | 1655.7 |
| New and Proposed IRM Study Wind Units | | | | |
| Jericho Rise | D | 77.7 | 77.7 | 77.7 |
| | | 77.7 | 77.7 | 77.7 |
| Non - ICAP Participating Wind Units | | | | |
| | Zone | CRIS (MW) | Nameplate Capability (MW) | CRIS adusted value from 2017 Gold Book (MW) |
| Erie Wind | A | 0.0 | 15.0 | 0.0 |
| Fenner Wind Farm | C | 0.0 | 30.0 | 0.0 |
| Steel Wind | A | 0.0 | 20.0 | 0.0 |
| Western NY Wind Power | C | 0.0 | 6.6 | 0.0 |
| | | 0.0 | 71.6 | 0.0 |
| Total Wind Resources | | 1735.9 | 1811.1 | 1733.4 |

Attachment B4

Existing and New Solar Resources

| B4 - Solar Resources | | | | |
|---------------------------------------|------|-----------|------------------------|---|
| Wind Resouce | Zone | CRIS (MW) | Summer Capability (MW) | CRIS adusted value from 2017 Gold Book (MW) |
| ICAP Participating Solar Units | | | | |
| Long Island Solar | K | 31.50 | 31.50 | 31.50 |
| | | 31.50 | 31.50 | 31.50 |
| Proposed IRM Study Solar Units | | | | |
| | | 0.00 | 0.00 | 0.00 |
| | | | | |
| Total Solar Resources | | 31.50 | 31.50 | 31.50 |

Attachment B5


Resources and Peak Load Adjustment Modeled in the Behind the Meter Net Generation Program (BTM-NG)

| Attachment B5 -Resources and Peak Load Ajustment Modeled in the Behind the Meter Net Generation Program* | | | |
|---|-------------|--|--|
| Generator Name | Zone | Resource Value (MW)¹ | Peak Load Adjustment (MW)² |
| Stony Brook ³ | K | 47.0 | 39.1 |
| | | | |
| | | | |
| | | | |
| Total BTM program Gen | | 47.0 | 39.1 |


* The IRM study independently models the generation and load components of BTM:NG Resources

1. Based on adjusted DMGC value
2. Based on ACHL
3. Stony Brook formerly modeled at 9.6 MW (net of host load)

Attachment C



Attachment C1



Attachment D


Emergency Operating Procedures

| Step | Procedure | Effect | 2017 MW Value | 2018 MW Value |
|-------------|-----------------------------------|--|---|---|
| 1 | Special Case Resources | Load relief | 1,192 MW Enrolled/ 841 MW modeled | 1,219 MW Enrolled/ 868 MW modeled |
| 2 | Emergency Demand Response Program | Load relief | 75 MW Enrolled/13 MW Modeled | 16 MW Enrolled/3 MW Modeled |
| 3 | 5% manual voltage Reduction | Load relief | 66 MW | 66 MW |
| 4 | Thirty-minute reserve to zero | Allow operating reserve to decrease to largest unit capacity (10-minute reserve) | 655 MW | 655 MW |
| 5 | 5% remote voltage reduction | Load relief | 386 MW | 341 MW |
| 6 | Voluntary industrial curtailment | Load relief | 125.5 MW | 121.8 MW |
| 7 | General public appeals | Load relief | 88 MW | 80.8 MW |
| 8 | Emergency Purchases | Increase capacity | Varies | Varies |
| 9 | Ten-minute reserve to zero | Allow 10-minute reserve to decrease to zero | 1,310 MW | 1,310 MW |
| 10 | Customer disconnections | Load relief | As needed | As needed |

Attachment E

2018 IRM Final Topology (Summer Ratings)

September 28, 2017



- Notes**
1. PJM to NY emergency assistance (EA) assumption for calculating the PJM-G Group and ABC Line Group flow distribution limit: 1500 MW
 2. NYCA EA simultaneous import limit: 3,500 MW
 3. External areas representation received from the NPCC CP-8 WG

Legend

- ↔ Interface
- ↔↔ Interface w/ Dynamic Ratings
- Interface Group
- Interface Group w/ Dynamic Ratings
- Monitoring Interface Group
- - - NYCA EA Interface Group Marker
- xx "Dummy Bubble"

NOTE: An interface is considered to not have a MW limitation if no number is specified

Attachment F

SCR Determinations

| SCR Performance for 2018 IRM Study | | | | | | |
|------------------------------------|--|------------------------------|---------------------------------|----------------------|--------------------------------|--------------|
| Super Zones | Registrations (July 2017) | Forecast (2018) ¹ | Performance Factor ² | UCAP (2018) | Adjustment Factor ³ | Model Value |
| A - F | 696.1 | 696.1 | 0.859 | 597.9 | 0.900 | 538.1 |
| G - I | 82.7 | 82.7 | 0.710 | 58.7 | 0.900 | 52.8 |
| J | 392.2 | 392.2 | 0.701 | 275.1 | 0.900 | 247.6 |
| K | 48.1 | 48.1 | 0.671 | 32.3 | 0.900 | 29.1 |
| Totals | 1219.1 | 1219.1 | | 964.0 | | 867.6 |
| | | | | | | |
| | Notes | | | Overall Performance: | | 71.2% |
| | 1. These values represent no growth from the July 2017 ICAP registrations | | | | | |
| | 2. Performance Factor based on ACL methodology | | | | | |
| | 3. The Adjustment Factor captures two different performance derates; 1) Translation Factor (TF) between ACL and CBL values, (TF=0.90); and 2) the Fatigue Factor (FF), (FF = 1.00) | | | | | |

Assumption Matrix History

| Date | Ver | Preliminary Base Case | Date | Ver | Final Base Case |
|---------|------|--|---------|------|---|
| 2/1/17 | V00 | Preliminary assumptions without attachments. | 8/22/17 | V6.0 | Added a BTM-NG resource, reinstated Shoreham GT 3 & 4, removed Copenhagen Wind, reduced output BEC due to 2 of 3 phases projected to be complete. Added "DRAFT" to each page. |
| 3/1/17 | V0.1 | -BTM solar changed to BTM-NG program – see Page 4. | 9/26/17 | V7.0 | Remove Taylor Biomass from new units. Freeport CT1 rescinded retirement notice (no units scheduled to retire). Typo, page 4. Update attachment B5. |
| 4/3/17 | V1.0 | -Added draft attachments A and B. -Updated Gold Book load forecasts. | 9/29/17 | V7.1 | Update Topology per letter to TPAS. Return LI interfaces due to retaining Freeport CT1. Update diagram to reflect several CP-8 interfaces. These updates were already captured in the database. |
| 5/23/17 | V2.0 | -Added column on impacts. -Added attachments C, C1, and E. | 10/4/17 | V7.2 | Fills in October IRM peak load forecast. Updates MARs version number. |
| 6/27/17 | V2.1 | -Completed Attachments A, E, and F for PBC. -Updated Attachment B4. | | | |
| 7/7/17 | V3.0 | -Incorporated ICS comments. -Completed attachments D and F (F contains preliminary values). -Added EA limit description. | | | |
| 7/10/17 | V4.0 | -Attachment F values finalized. | | | |
| 8/2/17 | V5.0 | -Added Row (page 4) to accommodate solar shape. -Attachment F correction. -Added words indicating EC approved version for PBC. -Removed "DRAFT" watermark from each page. | | | |
| | | | | | |