

# Alternative Methods for Determining LCRs

---

Zachary Stines

Associate Market Design Specialist

Installed Capacity Working Group

October 30, 2017, NYISO



DRAFT – FOR DISCUSSION PURPOSES ONLY

©COPYRIGHT NYISO 2017. ALL RIGHTS RESERVED

# Agenda

- **Transmission Security**
  - N-1-1 Assumptions
  - Stability of Import Limits
  - Timeline of Assumptions
  - Final Results
- **Sensitivity Results**
  - Multiple Changes in Generation
  - Changes in Transmission
  - Net CONE
- **Next Steps**
- **Questions**

# Transmission Security Limits (TSL)

# Overview of Preliminary Analysis

- Analyzed the N-1-1 thermal transfer limits for the NYCA interfaces associated with the G-J, Zone J, and Zone K Localities
- Used the final Summer 2017 Operating base case
  - Rebuilt case to conduct the N-1-1 analysis

# Transmission Security Methodology

- N-1-1 analysis was conducted to determine the transmission security import limits into each Locality
- These import limits were used to determine the minimum available capacity required for each Locality
- To translate this minimum available capacity into a market requirement the methodology needs to account for capacity unavailability
- To account for capacity unavailability, the 5-year zonal EFORd was used to calculate minimum locational capacity requirements

# Example Calculation

Transmission Security Requirements	Formula	Zone X
Load Forecast (MW)	[A] = Given	12,000
Transmission Security Import Limit (MW)	[B] = Given	1,500
Transmission Security UCAP Requirement (MW)	[C] = [A]-[B]	10,500
Transmission Security UCAP Requirement (%)	[D] = [C]/[A]	87.5%
5 Year EFORd (%)	[E] = Given	8.0%
Transmission Security ICAP Requirement (MW)	[F] = [C]/(1-[E])	11,413
Transmission Security LCR Floor (%)	[G] = [F]/[A]	95.1%

# N-1-1 Analysis Assumptions

# N-1-1 Base Case

- **Updated Summer 2017 Operating base case**
  - Inclusion of transmission and generation facility additions and retirements
- **All system elements modeled as in service**
- **All generation represented**



# Boundary Assumptions

- **The analysis calculates the N-1-1 transmission security import limits using the NYCA bulk power transmission facilities (BPTF) into each Locality**
  - Zone J: Dunwoodie South interface
  - Zone K: ConEd-LIPA interface
  - G-J: UPNY-SENY interface
- **The external transmission facilities are not incorporated in the analysis since**
  - Facilities without UDRs cannot meet the Locality capacity requirements
  - Facilities with UDRs are treated as supply side resources

# Boundary Assumptions

- The import capability from Zone K was included within the Dunwoodie South definition as a result of a contractual agreement
- It was not included in the UPNY-SENY definition since the contractual agreement results in a net zero effect

# UPNY-SENY

Name	Line ID	Voltage (kV)
<b>Mohawk (Zone E) – Hudson Valley (Zone G)</b>		
Coopers Corners-Middletown*	CCRT34	345
Coopers Corners-Dolson Ave*	CCDA42	345
West Woodbourne 115/69	T152	115/69
<b>Capital (Zone F) – Hudson Valley (Zone G)</b>		
Athens-Pleasant Valley*	91	345
Leeds-Pleasant Valley*	92	345
*Leeds-Hurley Ave.	301	345
Hudson-Pleasant Valley*	12	115
Blue Stores E-Pleasant Valley*	13-987	115
Blue Stores W-Pleasant Valley*	8	115
*Feura Bush-North Catskill	2	115

\* Indicates the metered end of the circuit

# Dunwoodie South

Name	Line ID	Voltage (kV)
<b>Dunwoodie (Zone I) – NYC (Zone J)</b>		
*Dunwoodie-Mott Haven	71	345
*Dunwoodie-Mott Haven	72	345
Sprain Brook-Tremont*	X28	345
*Sprain Brook-West 49th Street	M51	345
*Sprain Brook-West 49th Street	M52	345
*Sprain Brook-Academy	M29	345
*Dunwoodie-Sherman Creek	99031	138
*Dunwoodie-Sherman Creek	99032	138
*Dunwoodie-East 179th Street	99153	138
<b>Long Island (Zone K) – NYC (Zone J)</b>		
*Lake Success-Jamaica	903	138
*Valley Stream-Jamaica	901L_M	138

\* Indicates the metered end of the circuit


# ConEd – LIPA

Name	Line ID	Voltage (kV)
<b>Dunwoodie (Zone I) – Long Island (Zone K)</b>		
*Dunwoodie-Shore Road	Y50	345
*Sprain Brook-East Garden City	Y49	345
<b>NYC (Zone J) – Long Island (Zone K)</b>		
Jamaica-Valley Stream*	901L_M	138
Jamaica-Lake Success*	903	138

\* Indicates the metered end of the circuit

# Load Forecast

- **Summer Operating Report utilizes the Gold Book load forecast for the appropriate year**
- **The Transmission Security Limit analysis will use an updated load forecast -- the subsequent year's load forecast**
  - This will result in a base case that utilizes the same load forecast assumed in the NYSRC IRM study



# Example: 2018-2019 TSL Analysis

- **May 2017**
  - 2017 Summer Operating Report base case
    - Utilize the 2017 Gold Book load forecast (produced in April 2017)
- **Sept. 2017**
  - Perform the N-1-1 analysis to determine import capabilities into each Locality
    - Update the load forecast in the base case to be the 2018 Gold Book forecast (this is the same load forecast in NYSRC 2018-2019 IRM study)
    - Update expected generation and transmission changes consistent with NYSRC 2018-2019 IRM study
- **Jan. 2018**
  - Calculate TSLs
    - 2018 load forecast produced in December 2017
    - Import capabilities produced in October 2017
    - 5 year EFORd used in NYSRC 2018-2019 IRM study
  - Establish LCRs using optimization methodology
    - 2018 load forecast produced in December 2017
    - TSLs produced in January 2018



# Line Rating Assumptions

- **The G-J Locality and Zone K were calculated assuming Long Term Emergency (LTE) ratings**
  - Consistent with NYISO Normal Operating and planning criteria
- **Zone J was calculated assuming Normal line ratings**
  - Based on NYSRC Local Reliability Rule (G1)

# Treatment of UDRs

- UDRs are treated as supply-side resources and at a level consistent with their elections
- UDRs are not considered as part of the import capability when calculating the N-1-1 import limits

# Outage and Contingency

## ■ In the N-1-1 analysis

- 1<sup>st</sup>
  - Outage of the most limiting single element
- 2<sup>nd</sup>
  - Zone K and G-J: NPCC defined contingency
  - Zone J: Outage of the second most limiting single element<sup>1</sup>

<sup>1</sup> Based on NYSRC Local Reliability Rules (*i.e.* G1)

# Zone J

Outage Applied		Thermal Transfer
Sprain Brook – W. 49 <sup>th</sup> St. (M51) 345 kV Sprain Brook – W. 49 <sup>th</sup> St. (M52) 345 kV		3200 MW (1)
Limiting Element	Rating	Limiting Contingency
(1) Dunwoodie – Mott Haven (71) 345 kV	@NORM 785 MVA	Pre-Contingency Loading

# Zone K

Outage Applied		Thermal Transfer
Sprain Brook – East Garden City (Y49) 345 kV		350 MW (1)
Limiting Element	Rating	Limiting Contingency
(1) Dunwoodie – Shore Rd. (Y50) 345 kV	@NORM 687 MVA <sup>2</sup>	Pre-Contingency Loading

<sup>2</sup> LIPA rating for Y50 circuit is based on 70 % loss factor and rapid oil circulation.

# G-J

Outage Applied		Thermal Transfer
Athens – Pleasant Valley (91) 345 kV		3225 MW (1)
Limiting Element	Rating	Limiting Contingency
(1) Leeds – Pleasant Valley (92) 345 kV	@LTE 1538 MVA L/O	Leeds – Hurly Ave. (301) 345 kV

# Stability of Transmission Security Limits


# Stability with Changes in Generation

- The N-1-1 import limits used in the Transmission Security Limit (TSL) calculation are primarily impacted by changes in transmission
- Generation does not typically have an impact on the N-1-1 import limits
- Generation that impacts the distribution of flows on the interface facilities can have an impact on the N-1-1 import limits




# Timeline of Assumptions

# Current Timeline



# Timeline Additions



# LCR Setting Timeline

- No alterations to the current timeline are needed to accommodate this proposed alternative methodology for determining LCRs
- Transmission security analysis used in the alternative methodology would be conducted and reported prior to October 1<sup>st</sup>
  - This analysis would utilize an updated base case used in the Summer Operating Report

# Final Results

# Transmission Security LCR Floors

Transmission Security Requirements	G-J	Zone J	Zone K
Load Forecast (MW)	16,061	11,670	5,427
Transmission Security Import Limit (MW)	3,225	3200	350
Transmission Security UCAP Requirement (MW)	12,836	8,470	5,077
Transmission Security UCAP Requirement (%)	79.92%	72.58%	93.55%
5 Year EFORd (%)	10.50%	9.99%	10.06%
Transmission Security ICAP Requirement (MW)	14,342	9,410	5,645
<b>Transmission Security LCR Floor (%)</b>	<b>89.30%</b>	<b>80.63%</b>	<b>104.01%</b>

# Transmission Security LCR Floors

	Zone J LCR	G-J LCR	Zone K LCR
Transmission Security LCR Floors	89.30%	80.63%	104.01%

- These values are for the 2016-2017 capability year

# Sensitivity Results



# Multiple Changes in Generation

- +500 MW in Zone G & -500 MW in Zone J
- -500 MW in Zone G & +500 MW in Zone J
- +500 MW in Zone K & -500 MW in Zone J
- -500 MW in Zone K & +500 MW in Zone J


# Market Simulations:

**+/- 500 MW to Zone G and**

**+/-500 MW to Zone J**


# Addition & Removal of Capacity from Zone G & Zone J

## Zone J LCR




# Addition & Removal of Capacity from Zone G & Zone J

## Zone K LCR



# Addition & Removal of Capacity from Zone G & Zone J

## G-J LCR




# Market Simulations:

**+/- 500 MW to Zone K and**

**+/-500 MW to Zone J**


# Addition & Removal of Capacity from Zone K & Zone J

## Zone J LCR



# Addition & Removal of Capacity from Zone K & Zone J


## Zone K LCR





# Addition & Removal of Capacity from Zone K & Zone J

## G-J LCR



■ Optimized Cost (million \$)    
 ■ TSL Cost (million \$)    
 ■ Current LCR Cost (million \$)

■ Optimized G-J LCR    
 ■ TSL G-J LCR (Limit @ 89.12%)    
 ● Tan G-J LCR

# Changes in Transmission

# Changes in Transmission

- **+1000 MW to UPNY-SENY**
  - Transmission Security Limit for G-J was recalculated assuming an additional 1000 MW of import capability

# +1000 MW to UPNY-SENY

Scenario	Zone J LCR	Zone K LCR	G-J LCR	Cost (\$ million)
Current LCR Methodology	79.38%	101.94%	90.18%	\$ 4,398.63
Optimized Methodology without Transmission Security Limits (TSL)	77.71%	107.44%	84.29%	\$4,365.16
Optimized Methodology with Transmission Security Limits (TSL)	80.16%	103.80%	84.96%	\$4,388.00

- G-J import limit was increased by 1000 MW in the TSL calculation resulting in a reduction in the TSL from 89.12% to 82.17%

# +1000 MW to UPNY-SENY

Scenario	Zone J LCR	Zone K LCR	G-J LCR
Current LCR Methodology	9,263 MW	5,532 MW	14,484 MW
Optimized Methodology without Transmission Security Limits (TSL)	9,069 MW	5,831 MW	13,538 MW
<b>Optimized Methodology with Transmission Security Limits (TSL)</b>	<b>9,355 MW</b>	<b>5,633 MW</b>	<b>13,645 MW</b>

# Change from Base Case to +1000 MW UPNY-SENY

Scenario	$\Delta$ Zone J MW	$\Delta$ Zone K MW	$\Delta$ G-J MW	$\Delta$ Total Locality MW
Current LCR Methodology	-232.2	-71.1	-180.5	-483.8
Optimized Methodology without Transmission Security Limits (TSL)	-38.5	117.7	-1159.1	-1079.9
Optimized Methodology with Transmission Security Limits (TSL)	0.0	-19.2	-924.8	-944.1


# Changes in Net CONE

# Changes in Net CONE


- +/- \$25.00 to G-J Net CONE
- +/- \$25.00 to Zone J Net CONE
- +/- \$25.00 to Zone K Net CONE
- +/- \$25.00 to NYCA Net CONE




# G-J Net CONE +/- \$25




# Zone J Net CONE +/- \$25



# Zone K Net CONE +/- \$25



# NYCA Net CONE +/- \$25



# Next Steps

# Other Next Steps

- The NYISO will consider input received during today's ICAP Working Group meeting
- Additional comments sent to [deckels@nyiso.com](mailto:deckels@nyiso.com) will be considered

# Questions?

# The Mission of the New York Independent System Operator, in collaboration with its stakeholders, is to serve the public interest and provide benefits to consumers by:

- Maintaining and enhancing regional reliability
- Operating open, fair and competitive wholesale electricity markets
- Planning the power system for the future
- Providing factual information to policy makers, stakeholders and investors in the power system



[www.nyiso.com](http://www.nyiso.com)