

NYISO Self-Certification

Description:

NYSRC Reliability Rule Reference (No. and Name)

C.1: Establishing Operating Transfer Capabilities

NYSRC Requirement(s) for which compliance is being self-certified

R1. Normal and *emergency* operating transfer capabilities shall be established to meet the respective performance requirements in Table C-1 and supplemental performance requirements in Table C-2, for the *contingency* events specified in Table C-1.

R1.1. The *NYISO* shall consider Local Area Operation Requirements in Reliability Rules G.1, G.2 and G.3 in the establishment of operating limits, assessment of operating adequacy, and operation on the NYS Bulk Power System.

R2. The *NYISO* shall maintain procedures and systems that ensure that appropriate actions are taken when *thermal, voltage, and/or stability limits* are exceeded. These procedures shall identify system states that warrant the *NYISO* to invoke *emergency transfer criteria*. The *NYISO* must notify the *NYSRC* of any changes to these procedures and systems.

Compliance Monitoring Process

Compliance Monitoring Responsibility:

- M1: RCMS

Compliance Documentation Reporting Frequency:

- M1: In accordance with *NYSRC* Compliance Monitoring Program schedules.

Compliance Reporting Requirements:

- M1: *NYISO* Self-Certification

Measure No.

<input checked="" type="checkbox"/> Full Compliance	M1. The <i>NYISO</i> maintained procedures and systems in accordance with R1 and R2 which identify appropriate actions to be taken whenever the bulk power transmission system’s thermal, voltage, and <i>stability limits</i> are exceeded. The procedures identified system states that warrant the <i>NYISO</i> to invoke <i>emergency transfer criteria</i> . Any revisions to these procedures or systems were reported to the <i>NYSRC</i> .
---	---

Levels of Non-Compliance

___ Level 1	M1. Revisions to existing procedures or systems were not reported to the <i>NYSRC</i> .
-------------	---

___ Level 2	M1. Documentation of <i>NYISO</i> procedures and systems for exceedance of thermal, voltage, and <i>stability limits</i> was incomplete in one or more areas.
___ Level 3	M1. Not applicable.
___ Level 4	M1. Documentation of <i>NYISO</i> procedures and systems for exceedance of thermal, voltage, and <i>stability limits</i> was not provided.

R1. SOL methodology established for the NYISO as RC is defined by NYSRC Reliability Rules and Compliance Manual. Section C-1 & C-2. Table C.1 defines the contingencies to be tested and the acceptable system response performance parameters.

That SOLs are established consistent with that methodology is demonstrated by the reports defining those SOLs.

Summer2020_Operating_Study_OC Report establishes thermal SOLs. That the analysis was conducted in accordance with NYSRC Rules is identified in the System Operating Limit (SOL) Methodology section on page 5. The identified limits are consistent with the contingencies studied and the performance requirements established in the methodology. Examples can be found on pages 19-27, identifying pre-contingency flow, single element contingencies, and tower contingencies, as well as the equipment ratings applied.

Northern Export and Cedars Import Stability Limit Report establishes the subset of SOLs that are defined as the stability interface limits (IROLs). That the analysis was conducted in accordance with NYSRC rules is identified in both the Executive Summary and the System Operating Limit (SOL) Methodology sections on page 2 and 7, respectively. The identified limits are consistent with the contingencies studied and the performance requirements established in the methodology. Examples can be found on page 11, identifying single element contingencies, stuck breaker contingencies, and tower contingencies. Examples of system performance can be found on pages 22-28.

Central East Voltage Collapse and Stability Limits for Marcy South Series Capacitors Report establishes both the pre contingency low voltage SOL limits and the subset of SOLs that are defined as the voltage collapse and stability interface limits (IROLs). That the analysis was conducted in accordance with NYSRC rules is identified in the Interface Voltage Collapse Limits and Interface Stability Limits sections on pages 13 and 19, respectively. The identified limits are consistent with the contingencies studied and the performance requirements established in the methodology. Examples can be found on page 14 and 22, identifying pre-contingency flow, single element contingencies, stuck breaker contingencies, and tower contingencies. Examples of system performance can be found on pages 20 and 27.

Central East Voltage Collapse Transfer & Pre-Contingency Low Voltage Limits Report establishes the pre contingency low voltage SOL limits and the subset of SOLs that are defined as the voltage collapse interface limits (IROLs). That the analysis was

conducted in accordance with NYSRC rules is identified in the Study Criteria on page 8. The identified limits are consistent with the contingencies studied and the performance requirements established in the methodology. Examples can be found on page 12, identifying pre-contingency flow, single element contingencies, stuck breaker contingencies, and tower contingencies. Examples of system performance can be found on pages 18-21.

R1.1. G.1 New York City System Operations.

G.2 Loss of Gas Supply – New York City

G.3 Loss of Gas Supply – Long Island

The NYISO Transmission and Dispatching Operations Manual Section 6.7.9 addresses G.1, stating:

“The NYISO may use the SRE process to commit additional resources outside of the SCUC and RTC processes to meet NYISO reliability or local reliability requirements. Transmission Owners (TOs) may request the commitment of additional generators to ensure local reliability in accordance with the local reliability rules. The NYISO will use SREs to fill these requests by TOs.”

The following two motions were approved at the NYISO Operating Committee Meeting, establishing operating limits associated with G.2 and G.3

Motion #3:

The Operating Committee has reviewed Con Edison’s procedures for compliance with Application No. 69 of the NYSRC Rule I-R3, and hereby approves such procedures as presented and discussed at the May 21, 2020 meeting. The motion passed unanimously by show of hands

Motion #4:

The Operating Committee has reviewed PSEG Long Island’s procedures for compliance with Application No. 70 of the NYSRC Rule G.3, and hereby approves such procedures as presented at the May 21, 2020 meeting. The motion passed unanimously by show of hands.

R2. The NYISO Emergency Operations Manual section 4 - Monitored Conditions, describe the procedures for all monitored conditions/actions to be taken when thermal, voltage, and stability limits are exceeded.

Certified by: R. Golen

Title: Manager, Operations Engineering

Date: April 01, 2021