

Case Number	Description	Observed IRM Change	Adjusted IRM Change	NYCA	Zone J	Zone K	Zone J	Zone K
				RM	RM	RM	Δ	Δ
	<b>IRM 2019 Final Base Case</b>			18.2	80.7	103.2		
1	Retirements	0.06	0.1	18.26	79.42	104.15	-1.28	0.95
2	Change Study Year	-0.27	-0.3	17.99	79.23	103.90	-0.19	-0.25
3	MARS 3.22.6	-0.15	-0.1	17.84	79.12	103.76	-0.11	-0.14
4	Use NYBA for LOLE criteria	-0.09	-0.1	17.75	79.06	103.68	-0.06	-0.08
5	New Wind	0.48	0.5	18.23	79.06	103.68	0.00	0.00
6	Gold Book 2019 Load Forecast & Shapes	-0.57	-0.6	17.66	79.10	105.47	0.04	1.78
7	Gold Book DMNCs	0.06	0.1	17.72	79.36	104.27	0.26	-1.20
8	Generator Transition Rates (2013-2017)	-0.59	-0.6	17.14	78.95	103.74	-0.41	-0.53
9	NYCA Topology	0.13	0.1	17.26	79.04	103.86	0.09	0.12
10	New Thermals & Rerates	-0.15	-0.2	17.11	79.71	103.11	0.67	-0.75
11	Run of River Hydro update (2013-2017)							
12	LIPA AC Cable Outage Rates update							
13	NYC AC Cable Outage Rates update							
14	UDR Cable Outage Rates update							
15	Non SCR/EDRP EOPs							
16	Updated SCRs							
17	Update External Control Area Data							