

Options in Adjusting External Area Representations in the 2019 IRM Study - Revised

Greg Drake

NYISO Resource Adequacy Operations

**NYSRC – Installed Capacity Subcommittee
Meeting #212**

October 3, 2018
NYISO, Rensselaer, NY

DRAFT – FOR DISCUSSION PURPOSES ONLY



©COPYRIGHT NYISO 2018. ALL RIGHTS RESERVED

Refresh

- Each year, the NYISO updates the external area representations (Ontario, Quebec, New England, and PJM interconnection) for the IRM study.
 - To start this process, the data is provided by each external control area.
 - This process includes removal of the neighbors EOP steps and then adjustments to the data in accordance with Policy 5 if the neighboring LOLEs are better (lower) than their loss of load criteria.
 - The adjustments are meant to prevent “over reliance” on the NYISO’s neighbors when establishing the IRM study’s calculated Installed Reserve Margin (IRM).
 - A total import limit of 3,500 MW has been placed on the amount of emergency assistance that New York can rely on from all external areas when setting the IRM.

DRAFT – FOR DISCUSSION PURPOSES ONLY



©COPYRIGHT NYISO 2018. ALL RIGHTS RESERVED

Purpose

- During the 9/5/18 ICS meeting, the NYISO made a presentation on External Area Modeling. The purpose of the presentation was to provide additional detail and analysis regarding the impact of applying updates to the external area representations for the 2019/20 IRM.
 - The NYISO explained that updating the External Area Modeling produced a 1.1% decrease in the IRM that was not intuitive. The adjustment applied per policy 5 to ensure that the External Control Areas' LOLE is no better than their criteria, did not meaningfully reduce the reserve margins in certain External Control Areas. As a result, the reserve margins available in the External Control Areas could be delivered as emergency assistance to NYCA, decreasing the IRM.
- The ICS asked the NYISO to evaluate additional adjustments to the external areas that can be applied per Policy 5, and report on its findings.
- The purpose of today's presentation is for the NYISO to share the analysis completed to date and facilitate further discussion on the preferred path forward for the 2019/20 IRM and beyond.

DRAFT – FOR DISCUSSION PURPOSES ONLY



©COPYRIGHT NYISO 2018. ALL RIGHTS RESERVED

Policy 5 Adjustments

- NYSRC Policy 5 Section 3.5.6 External Control Area Load and Capacity Models states in relevant part:
 - “In addition, an external Control Area’s LOLE assumed in the IRM Study cannot be lower than its own LOLE criterion and its reserve margin can be no higher than the external Control Area’s minimum requirement.”
- The NYISO has annually had to adjust several of the External Control Areas, per policy 5, to ensure their LOLE is no better than their criteria.
- Adjustments to reserve margins, however, have not been needed in recent history.

DRAFT – FOR DISCUSSION PURPOSES ONLY



©COPYRIGHT NYISO 2018. ALL RIGHTS RESERVED

Approach

- The NYISO worked with a NYSRC consultant, as requested by the ICS, to determine options for completing the external area replacement for this year.
- Policy 5 does not dictate what method would be used to drive neighbors LOLE to criterion or drive their reserve margin levels to the minimum requirement.
- Discussions with the NYSRC consultant focused on two items.
 - The order of changes to the externals, current practice is; a) remove EOPs, b) add load to get LOLE to criteria, if needed, and c) adjustments to reserve margins, if needed.
 - The current method for adding load to externals to complete items b and c of the previous bullet, is to add load proportional to existing load in each zone.
- Five study cases were developed to test the impacts of the above parameters.

DRAFT – FOR DISCUSSION PURPOSES ONLY



©COPYRIGHT NYISO 2018. ALL RIGHTS RESERVED

Study Cases

1. First, remove EOPs. Load is then scaled proportional to existing load to meet the LOLE criterion and adjust reserve margins if needed to be no higher than the published minimum requirement.
2. Same approach as Case 1. However, this analysis uses the mod-mdmw table to add loads. The mod-mdmw table is necessary to adjust multiple load shapes; which will be needed for the cases below.
3. Change the order of adjustment steps. Load is scaled proportional to existing load to meet the LOLE criterion first, then remove EOPs, lastly adjust reserve margins if needed to be no higher than the published minimum requirement.
4. First, remove EOPs. Load is then scaled proportional to excess capacity in each zone to meet the LOLE criterion and adjust reserve margins if needed to be no higher than the published minimum requirement.
5. Change the order of adjustment steps. Load scaled proportional to excess capacity in each zone to meet the LOLE criterion first, then remove EOPs, lastly adjust reserve margins if needed to be no higher than the published minimum requirement.

DRAFT – FOR DISCUSSION PURPOSES ONLY



©COPYRIGHT NYISO 2018. ALL RIGHTS RESERVED

6

Target Reserve Margins

Control Area	Published Margin ¹	Source
New England ²	17.6%	ISO_NE ICR, LSR, & Capacity Requirement values..., Jan/16
PJM Interconnect	15.9%	2017 PJM Reserve Requirement Study, 10/12/17
Ontario	17.7%	Ontario RM Requirements for 2018-2020, 12/21/17
Quebec	N/A	

1. The NYISO pulled this information as an approximation of minimum reserve margins. These reserve margins reflect the EOPs used by the External Control Areas. Similar to the NYCA IRM process, the reserve margins may also be dependent on locational requirements.
2. New England will publish an update to this Margin in the next few weeks.



DRAFT – FOR DISCUSSION PURPOSES ONLY

©COPYRIGHT NYISO 2018. ALL RIGHTS RESERVED

Study Case Results (full details in Appendix A)

External Control Area LOLEs and Margin Levels										
Year:	2018 FBC		2019 PBC							
Case:	2018 FBC (18.2%)		Starting Case* (15.0%)		Finish Existing - Case 1 (15.6%)		Use Mod-MDMW - Case 2 (15.4%)		α to Excess Cap - Case 4 (16.4%)	
Area	Annual LOLE	Reserve Level	Annual LOLE	Reserve Level	Annual LOLE	Reserve Level	Annual LOLE	Reserve Level	Annual LOLE	Reserve Level
PJM_MA	0.146	116.0%	0.017	124.6%	0.467	115.9%	0.398	115.9%	0.145	115.2%
ISONE	0.108	113.8%	0.000	145.4%	0.135	117.6%	0.108	117.0%	0.109	116.5%
IESO	0.104	134.0%	0.000	143.5%	0.639	117.7%	0.560	117.7%	0.551	117.7%
HQ	0.110	144.1%	0.000	148.0%	0.103	138.3%	0.103	131.7%	0.103	131.7%
HQ (winter)	-	99.9%	-	107.9%	-	100.9%	-	100.5%	-	100.5%

*The starting case is the parametric PBC with externals replaced, but prior to any Policy 5 adjustments.



DRAFT – FOR DISCUSSION PURPOSES ONLY

©COPYRIGHT NYISO 2018. ALL RIGHTS RESERVED

Study Case Results -continued

External Control Area LOLEs and Margin Levels								
Year:	2018 FBC				2019 PBC			
Case:	2018 FBC (18.2%)		Starting Case* (15.0%)		EOPs 2nd, α to load - Case 3 (yy.y%)		EOPs 2nd, α to Excess Cap - Case 5 (yy.y%)	
<u>Area</u>	Annual LOLE	Reserve Level	Annual LOLE	Reserve Level	Annual LOLE	Reserve Level	Annual LOLE	Reserve Level
<u>PJM_MA</u>	0.146	116.0%	0.017	124.6%				
<u>ISONE</u>	0.108	113.8%	0.000	145.4%				
<u>IESO</u>	0.104	134.0%	0.000	143.5%				
<u>HQ</u>	0.110	144.1%	0.000	148.0%				
<u>HQ (winter)</u>	-	99.9%	-	107.9%				

*The starting case is the parametric PBC with externals replaced, but prior to any Policy 5 adjustments

DRAFT – FOR DISCUSSION PURPOSES ONLY



©COPYRIGHT NYISO 2018. ALL RIGHTS RESERVED

Preliminary Findings – Case 1 and 2

- Given the detailed topology models in the external areas, scaling proportional load to meet the LOLE criteria can create localized LOLE violations (for example in Boston) leaving excess reserves available to provide emergency assistance to the NYCA.
- Therefore, with the detailed topology models, significant additional adjustments to the reserve margins were needed to be applied as per policy 5.
- In addition, scaling proportional load to meet LOLE criteria and then adjusting to the reserve margin, may still result in higher levels of reserves from external areas being available to the NYCA as compared to case 4.

DRAFT – FOR DISCUSSION PURPOSES ONLY



©COPYRIGHT NYISO 2018. ALL RIGHTS RESERVED

10

Preliminary Findings – Case 3

- The objective of the case is to evaluate changing the order of the adjustments to first adjust the LOLE, then remove EOPs, and lastly adjust the reserve margins.
- The NYISO is still running this case.
- However, it is expected that the following may be observed. This case is not expected to eliminate the need for the reserve margin adjustment or reduce the magnitude of reserve adjustment.

DRAFT – FOR DISCUSSION PURPOSES ONLY



©COPYRIGHT NYISO 2018. ALL RIGHTS RESERVED

Preliminary Findings – Case 4

- Given the detailed topology models in the external areas, scaling load proportional to excess capacity to meet the LOLE criteria, helps to avoid localized LOLE violations reducing excess reserves available to provide emergency assistance to the NYCA.
- This case eliminated the need for the reserve margin adjustment for some external areas (ISO-NE and PJM) and reduced the magnitude of the reserve adjustment for the other areas.
- In addition, scaling load proportional to excess capacity to meet LOLE criteria and then (if necessary) adjusting to the reserve margin, may result in lower levels of reserves from external areas being available to the NYCA as compared to case 1.

DRAFT – FOR DISCUSSION PURPOSES ONLY



©COPYRIGHT NYISO 2018. ALL RIGHTS RESERVED

12

Preliminary Findings – Case 5

- The NYISO has not been able to complete this case.

DRAFT – FOR DISCUSSION PURPOSES ONLY



©COPYRIGHT NYISO 2018. ALL RIGHTS RESERVED

13

NYISO Recommendation for the IRM FBC

- For the 2019 IRM, the NYISO recommends that the ICS consider either
 - Keeping the 2018 external area representations to allow for further discussion on this matter, or
 - Updating the external area representations, by scaling load proportional to excess capacity as described in Case 4.
- If considered by ICS, the Case 4 methodology represents a change from past practice without the benefit of the ICS's normal review process.
- Regardless of the direction recommended by ICS for the 2019 IRM, the NYISO advises that additional discussion is needed to consider the preferred long term approach used for external Control Area modeling.

DRAFT – FOR DISCUSSION PURPOSES ONLY



©COPYRIGHT NYISO 2018. ALL RIGHTS RESERVED

Appendix A

External Control Area LOLEs with summer capacities, loads and resulting margins

Area	2018 IRM Study Final Base Case					IRM 2019 Draft PBC (pre-Policy 5) (IRM=15.0%)					IRM 2019 Draft PBC (post-Policy 5) (IRM=15.2%)				
	Annual LOLE	Summer Capacity (MW)	Summer Load (MW)	Reserve Level	Reserve Margin (MW)	Annual LOLE	Summer Capacity (MW)	Summer Load (MW)	Reserve Level	Reserve Margin (MW)	Annual LOLE	Summer Capacity (MW)	Adjusted Load (MW)	Reserve Level	Reserve Margin (MW)
PJM MA	0.146	193,267	166,588	116.0%	26,679	0.017	189,205	151,792	124.6%	37,413	0.148	189,205	158,541	119.3%	30,664
ISONE	0.108	32,894	28,913	113.8%	3,981	0.000	37,094	25,511	145.4%	11,583	0.107	37,094	31,934	116.2%	5,160
IESO	0.104	31,870	23,781	134.0%	8,089	0.000	31,588	22,016	143.5%	9,572	0.105	31,588	24,556	128.6%	7,032
HQ	0.110	34,929	24,239	144.1%	10,690	0.000	34,165	23,077	148.0%	11,087	0.106	34,165	24,729	138.2%	9,436
HQ (winter)	-	40,708	40,734	99.9%	-26	-	41,866	38,782	107.9%	3,083	-	41,866	41,557	100.7%	308
PJM Areas															
PJM EAST	0.077	35,065	33,962	103.2%	1,103	0.000	32,608	30,945	105.4%	1,663	0.010	32,608	32,321	100.9%	287
PJM CENT	0.000	34,258	25,570	134.0%	8,688	0.000	36,888	23,299	158.3%	13,589	0.000	36,888	24,335	151.6%	12,553
PJM WEST	0.001	4,946	2,993	165.2%	1,953	0.000	6,102	2,727	223.7%	3,375	0.000	6,102	2,848	214.2%	3,253
PJM SW	0.145	92,108	84,322	109.2%	7,786	0.017	86,345	76,832	112.4%	9,513	0.147	86,345	80,249	107.6%	6,096
DOMVEPC	0.000	26,891	20,360	132.1%	6,531	0.000	27,262	18,551	147.0%	8,711	0.000	27,262	19,376	140.7%	7,886
ISO-NE Areas															
BHE	0.000	1,125	331	339.8%	794	0.000	1,156	292	395.7%	864	0.000	1,156	366	316.1%	790
ME	0.076	926	1,038	89.2%	-112	0.000	1,009	916	110.2%	93	0.098	1,009	1,147	88.0%	-138
SME	0.000	1,544	747	206.5%	796	0.000	1,600	660	242.7%	941	0.001	1,600	826	193.8%	775
NH	0.002	4,291	2,172	197.6%	2,120	0.000	4,401	1,916	229.7%	2,485	0.003	4,401	2,399	183.5%	2,003
VT	0.073	548	1,325	41.3%	-777	0.000	769	1,169	65.8%	-400	0.085	769	1,463	52.5%	-694
BOSTON	0.103	3,107	6,061	51.3%	-2,954	0.000	4,059	5,348	75.9%	-1,288	0.098	4,059	6,694	60.6%	-2,635
CMA NEMA	0.103	581	1,795	32.4%	-1,214	0.000	620	1,584	39.1%	-964	0.098	620	1,983	31.3%	-1,363
WMA	0.007	4,997	2,322	215.2%	2,674	0.000	5,331	2,049	260.2%	3,282	0.020	5,331	2,565	207.8%	2,766
SEMA	0.092	3,616	3,066	117.9%	550	0.000	3,877	2,705	143.3%	1,172	0.105	3,877	3,386	114.5%	491
RI	0.004	3,333	2,702	123.3%	631	0.000	3,522	2,384	147.7%	1,138	0.018	3,522	2,985	118.0%	537
CT	0.015	5,376	3,727	144.3%	1,649	0.000	5,702	3,288	173.4%	2,414	0.027	5,702	4,116	138.5%	1,586
SWCT	0.103	2,447	2,478	98.7%	-31	0.000	3,996	2,186	182.7%	1,809	0.012	3,996	2,737	146.0%	1,259
NOR	0.103	253	1,382	18.3%	-1,128	0.000	301	1,219	24.7%	-918	0.086	301	1,526	19.8%	-1,225
LAKEROAD	0.000	751	0	-	751	0.000	751	0	-	751	0.000	751	0	-	751

Note: Draft ICS work product - for discussion purposes only



DRAFT – FOR DISCUSSION PURPOSES ONLY

©COPYRIGHT NYISO 2018. ALL RIGHTS RESERVED

Appendix A- continued

External Control Area LOLEs with summer capacities, loads and resulting margins															
Area	Policy 5 adjustment method 1 (IRM=15.6%)					Policy 5 adjustment method 2 (IRM=15.4%)					Policy 5 adjustment method 4 (IRM=16.4%)				
	Annual LOLE	Summer Capacity (MW)	Adjusted Load (MW)	Reserve Level	Reserve Margin (MW)	Annual LOLE	Summer Capacity (MW)	Adjusted Load (MW)	Reserve Level	Reserve Margin (MW)	Annual LOLE	Summer Capacity (MW)	Adjusted Load (MW)	Reserve Level	Reserve Margin (MW)
PJM MA	0.467	189,205	163,248	115.9%	25,956	0.398	189,205	163,248	115.9%	25,957	0.145	189,205	164,292	115.2%	24,913
ISONE	0.135	37,094	31,543	117.6%	5,552	0.108	37,094	31,711	117.0%	5,383	0.109	37,094	31,851	116.5%	5,243
IESO	0.639	31,588	26,838	117.7%	4,750	0.560	31,588	26,838	117.7%	4,750	0.551	31,588	26,838	117.7%	4,750
HQ	0.103	34,165	24,700	138.3%	9,464	0.103	34,165	25,942	131.7%	8,222	0.103	34,165	25,942	131.7%	8,222
HQ (winter)	-	41,866	41,510	100.9%	356	-	41,866	41,647	100.5%	218	-	41,866	41,647	100.5%	218
PJM Areas															
PJM EAST	0.029	32,608	33,281	98.0%	-673	0.022	32,608	33,272	98.0%	-664	0.060	32,608	31,509	103.5%	1,099
PJM CENT	0.000	36,888	25,057	147.2%	11,831	0.000	36,888	25,051	147.3%	11,837	0.000	36,888	27,909	132.2%	8,979
PJM WEST	0.000	6,102	2,933	208.0%	3,169	0.000	6,102	2,932	208.1%	3,170	0.001	6,102	3,872	157.6%	2,230
PJM SW	0.463	86,345	82,631	104.5%	3,714	0.396	86,345	82,609	104.5%	3,736	0.142	86,345	80,059	107.9%	6,286
DOMVEPC	0.001	27,262	19,952	136.6%	7,310	0.001	27,262	19,946	136.7%	7,316	0.004	27,262	21,506	126.8%	5,756
ISO-NE Areas															
BHE	0.000	1,156	361	320.0%	795	0.000	1,156	362	319.2%	794	0.000	1,156	658	175.7%	498
ME	0.130	1,009	1,133	89.1%	-124	0.103	1,009	1,137	88.7%	-128	0.108	1,009	955	105.7%	54
SME	0.000	1,600	815	196.3%	785	0.001	1,600	819	195.5%	782	0.004	1,600	1,059	151.2%	542
NH	0.002	4,401	2,369	185.8%	2,032	0.002	4,401	2,378	185.1%	2,023	0.007	4,401	2,970	148.2%	1,431
VT	0.126	769	1,445	53.2%	-676	0.098	769	1,451	53.0%	-682	0.107	769	1,169	65.8%	-400
BOSTON	0.131	4,059	6,612	61.4%	-2,553	0.103	4,059	6,637	61.2%	-2,577	0.108	4,059	5,348	75.9%	-1,288
CMA NEMA	0.130	620	1,958	31.7%	-1,338	0.103	620	1,966	31.5%	-1,346	0.108	620	1,584	39.1%	-964
WMA	0.015	5,331	2,533	210.4%	2,797	0.001	5,331	2,543	209.6%	2,788	0.023	5,331	3,441	154.9%	1,890
SEMA	0.130	3,877	3,344	115.9%	533	0.102	3,877	3,357	115.5%	520	0.097	3,877	3,202	121.1%	675
RI	0.016	3,522	2,948	119.5%	574	0.011	3,522	2,959	119.0%	563	0.005	3,522	2,867	122.8%	655
CT	0.027	5,702	4,066	140.2%	1,636	0.017	5,702	4,081	139.7%	1,621	0.033	5,702	4,312	132.2%	1,390
SWCT	0.011	3,996	2,703	147.8%	1,292	0.007	3,996	2,713	147.3%	1,282	0.016	3,996	2,953	135.3%	1,042
NOR	0.126	301	1,507	20.0%	-1,206	0.098	301	1,513	19.9%	-1,212	0.108	301	1,219	24.7%	-918
LAKEROAD	0.000	751	0	-	751	0.000	751	0	-	751	0.000	751	318	-	433

Note:

Method 1 - adjust load by ratio of **existing load** and keep reserve margins no higher than published requirement (LOD-DATA table)

Method 2 - adjust load by ratio of **existing load** and keep reserve margins no higher than published requirement (MOD-MDMW table)

Method 4 - adjust load by ratio of **excess capacity** and keep reserve margins no higher than published requirement (MOD-MDMW table)



DRAFT - FOR DISCUSSION PURPOSES ONLY

©COPYRIGHT NYISO 2018. ALL RIGHTS RESERVED

Questions?

Questions or comments can be sent to Greg Drake:

gdrake@nyiso.com

The Mission of the New York Independent System Operator, in collaboration with its stakeholders, is to serve the public interest and provide benefits to consumers by:

- Maintaining and enhancing regional reliability
- Operating open, fair and competitive wholesale electricity markets
- Planning the power system for the future
- Providing factual information to policy makers, stakeholders and investors in the power system



www.nyiso.com

DRAFT – FOR DISCUSSION PURPOSES ONLY

©COPYRIGHT NYISO 2018. ALL RIGHTS RESERVED

