

# **High Renewable Resource Modeling White Paper**

New York State Reliability Council –

Installed Capacity Subcommittee

Draft, December 2nd, 2019

## **Introduction**

New York's electricity industry is transforming rapidly, from traditional, controllable fossil fuel generation to non-emitting, weather-dependent intermittent resources and distributed generation. These changes are driven primarily by state policies, but also by technological advancements that are expanding the possibilities of new resources and lowering their costs. New York State programs aim to serve 70% of load with energy generated from renewables by 2030. Our initial assessments of emerging reliability challenges indicates that the primary challenge arises from the variability and unpredictability of wind and solar generation. As the penetration of those technologies increases, the grid will likely need more load-following capability, and possibly more fast-response and flexible resources that provide operating reserves to address expected and unexpected changes in net load. The grid will also need a substantial amount of installed reserve capacity that is available to serve load when wind and/or solar generation output is insufficient for periods that may range from minutes to several days.

Intermittent renewable resources participate in the New York Independent System Operator, Inc. (NYISO)-administered energy and capacity markets. The intermittent nature and low capacity factor characteristics of certain renewable resources compared to conventional resources creates challenges with regard to both the planning and operation of the New York State bulk power system. Because of the future potential of large scale integration of renewable resources, the New York State Reliability Council (NYSRC) is working with the NYISO to ensure reliability, and that tools and methods will be available to accurately model renewable resources for measuring grid reliability.

To obtain an understanding of the reliability impacts of future renewable facilities in terms of resource adequacy, this paper provides the results of a Loss of Load Expectation (LOLE) evaluation to determine the New York Control Area (NYCA) Installed Reserve Margin (IRM) assuming a hypothetical large-scale increase of on-shore wind, off-shore wind, and solar facilities in New York. Results of this analysis will help inform the NYSRC and the NYISO to determine the need for new procedures and reliability rules. The paper provides the methodology and modeling assumptions used in this evaluation.

The NYSRC and the NYISO will together continue to look for ways to integrate intermittent renewable resources into New York's wholesale electricity markets while maintaining reliability and resource adequacy for New York electric consumers.

It is vital to note that the large scale integration of renewable resources will not happen independently of other changes to the bulk grid. In particular, these resources are expected to be

complemented by energy storage resources (ESRs), such as batteries, as they continue to incrementally enter New York's bulk electric system. The ability of these ESRs to offset the variability and nondispatchable nature of renewable resources is being explored by the NYISO and NYSRC.

### **Study Overview**

The study takes the New York system as found, and adds 12,000 MW of renewable capacity to it. The additional capacity does not displace or replace any existing generators. It is the NYISO's understanding that should renewable generation actually replace existing resources, the replaced resources would likely be better performers than the system average (i.e. the resources would have lower individual EFORds than the NYCA system EFORd). If this is the case, then the IRM calculated in this study is thought to be an underestimation. Note, ESRs may mitigate this impact, and in fact the NYSRC and NYISO are exploring methods to incorporate duration limited resources into the IRM study and LCR study.

### **Methodology**

The NYSRC requested the NYISO to conduct the sensitivity analysis described in this white paper. The NYISO began the evaluation using the NYSRC 2020 IRM Study Preliminary Base Case ("PBC") assumptions, which satisfies the LOLE criterion that the probability of an unplanned disconnection of firm load due to resource deficiencies is, on average, no more than 0.1 days per year. For the purpose of this sensitivity analysis, an additional 4,000 MW each of on-shore wind, off-shore wind and in front-of-meter (FTM) solar resources were added to the base case.

#### ***Location***

The location of ICAP placement for both solar PV and on-shore wind units was based on the projections of wind and solar installation represented in the New York State Department of Public Service's Clean Energy Standard Final Supplemental Environmental Impact Statement<sup>1</sup>. These projections were scaled up on a zonal basis to the requisite 4,000 MW for each resource type. The placement of offshore ICAP was split evenly between Zones J and K. The Zonal ICAP values by resource represented in this sensitivity analysis can be found in Table 1. Zones B, H, and I were not included this table because they have neither existing nor projected renewable ICAP.

---

<sup>1</sup> <http://documents.dps.ny.gov/public/Common/ViewDoc.aspx?DocRefId={424F3723-155F-4A75-BF3E-E575E6B0AFDC}>

**Table 1- ICAP added to PBC Assumptions by Resource Type (MW)**

Zone	Solar	On-Shore	Off-Shore	Total
A	874	1,030		<b>1,904</b>
C	406	994		<b>1,400</b>
D		894		<b>894</b>
E		1,082		<b>1,082</b>
F	1,884			<b>1,884</b>
G	448			<b>448</b>
J			2,000	<b>2,000</b>
K	388		2,000	<b>2,388</b>
<b>Total</b>	<b>4,000</b>	<b>4,000</b>	<b>4,000</b>	<b>12,000</b>

These additions are made to the renewable ICAP present in the 2020 PBC, seen in Table 2. There is currently minimal FTM solar ICAP resources and no off-shore wind resources. Zones B, H, and I were not included this table because they have neither existing nor projected renewable ICAP.

**Table 2- Renewable ICAP in PBC by Resource Type(MW)**

Zone	Solar	On-Shore	Off-Shore	Total
A	0	179	0	<b>179</b>
C	0	513	0	<b>513</b>
D	0	678	0	<b>678</b>
E	0	522	0	<b>522</b>
F	0	0	0	<b>0</b>
G	0	0	0	<b>0</b>
J	0	0	0	<b>0</b>
K	57	0	0	<b>57</b>
<b>Total</b>	<b>57</b>	<b>1,892</b>	<b>0</b>	<b>1,949</b>

**Data Preparation**

For the data utilized for this study, the NYISO leveraged a host of sources for each resource. In order to prepare on-shore wind data, the NYISO used five years of billing-quality meter data (January 1<sup>st</sup>, 2014 to December 31<sup>st</sup>, 2018), and utilized data from wind facilities that had CRIS rights. This is the data and process used to prepare the PBC. The NYISO then scaled up production curves to model 4,000 MW of incremental on-shore wind.

For solar data, the NYISO used normalized CARIS 2019 solar PV profiles, and scaled up the MW by zone. CARIS data was used because there is limited wholesale data in

NYISO. This data is based on NREL's *Solar Power Data for Integration Studies*<sup>2</sup>. See the NYISO's *2019 CARIS 1 70x30 Scenario Development*<sup>3</sup> presentation for more information.

Off-shore wind data were prepared in conjunction with NREL and GE. The data used in this study was derived from metrics such as meteorological conditions (*i.e.*, wind speed, temperature pressure) and power production modeled at three locations (NY Harbor in Zone J, and LI Shore and LI East End in Zone K), over the period 2007 to 2012. For more information, see the *2020 IRM High Renewable Sensitivity Assumptions*<sup>4</sup> presented to NYSRC.

Note: Due to the variety of sources and years of data, coincident performance of technology was not considered in this study.

### ***Performance Data and Unforced Capacity Ratings***

Projected performance data of each resource were derived from the data discussed above, and used to determine the market based reliability value of the resources. Monthly capacity factors for these resources were calculated in accordance with guidelines set forth in section 4.5 of the NYISO Installed Capacity Manual<sup>5</sup>. These values can be seen in the Figures 1 through 3 below.

---


<sup>2</sup> <https://www.nrel.gov/grid/solar-power-data.html>

<sup>3</sup> [https://www.nyiso.com/documents/20142/8263756/07%20CARIS1\\_70x30ScenarioDevelopment.pdf/ab02dbff-69b0-0b2f-04da-8e9d0bd74b76](https://www.nyiso.com/documents/20142/8263756/07%20CARIS1_70x30ScenarioDevelopment.pdf/ab02dbff-69b0-0b2f-04da-8e9d0bd74b76)


<sup>4</sup> <http://nysrc.org/pdf/MeetingMaterial/ICSMaterial/ICS%20Agenda%20223/AI%205'%20-%20windsolar-v04.pdf>

<sup>5</sup> [https://www.nyiso.com/documents/20142/2923301/icap\\_mnl.pdf/234db95c-9a91-66fe-7306-2900ef905338?t=1569860506857](https://www.nyiso.com/documents/20142/2923301/icap_mnl.pdf/234db95c-9a91-66fe-7306-2900ef905338?t=1569860506857)


**Figure 1- Onshore Wind Capacity Factor from 2PM to 6PM**



**Figure 2- Solar PV Capacity Factor from 2PM to 6PM**



**Figure 3- Offshore Wind Capacity Factor from 2PM to 6PM**



The corresponding zonal EFORds and UCAP ratings for these resources were calculated in accordance with guidelines set forth in section 4.5 of the NYISO Installed Capacity Manual. Zones B, H, and I were not included this table because they have neither existing nor projected renewable ICAP.

**Table 3- Zonal Production Factors of by Resource Type**

Zone	Solar	On-Shore	Off-Shore
A-C	31%	15%	
D		14%	
E		17%	
F	28%		
G	28%		
J			29%
K	30%		34%
<b>NYCA</b>	<b>29%</b>	<b>16%</b>	<b>32%</b>

**Table 4- UCAP added to PBC Assumptions by Resource Type(MW)**

Zone	Solar	On-Shore	Off-Shore	Total UCAP
A	401	312		<b>713</b>
D		123		<b>123</b>
E		186		<b>186</b>
F	525			<b>525</b>
G	123			<b>123</b>
J			588	<b>588</b>
K	113		673	<b>788</b>
<b>Total</b>	<b>1,164</b>	<b>621</b>	<b>1,261</b>	<b>3,046</b>

Table 5 below illustrates the effect that the addition of intermittent resources has on zonal and system-wide EFORds.

**Table 5- System Zonal EFORDs by Study**

Area	PBC EFORDs	High Renewable EFORDs
A	5%	28%
B	7%	7%
C	11%	24%
D	34%	50%
E	55%	69%
F	8%	37%
G	15%	23%
H	4%	4%
I	0%	0%
J	10%	21%
K	10%	27%
<b>NYCA</b>	<b>12%</b>	<b>26%</b>

**Results**

The high renewable case Tan45 analysis yielded an Installed Reserve Margin (IRM) of 42.9%, with corresponding margins in Zones J and K of 97.9% and 131.6%, respectively.

**Table 6- High Renewable Case Tan45 Summary Results**

IRM (%)	URM (%)	J LCR (%)	K LCR (%)
<b>42.9</b>	<b>5.1</b>	<b>97.9</b>	<b>131.6</b>

Included in this analysis is a metric called the Unforced Capacity Reserve Margin, or URM. This value is the IRM translated to an unforced capacity basis considering the NYCA-wide forced outage ratings, based on the average of all capacity suppliers' forced outage ratings. The URM reported above uses forced outage rates consistent with the IRM study. For example, the forced outage rate is based off five-year performance data. The URM relates to the IRM through the following equation:

$$URM \text{ Requirement } (\%) = \left[ \left( 1 + \frac{IRM \text{ Requirement } (\%)}{100} \right) \times \left( 1 - \frac{System \text{ EFORD } (\%)}{100} \right) - 1 \right] \times 100$$

$$URM (\%) = [(1 + 0.429) \times (1 - 0.264) - 1] \times 100$$

$$URM (\%) = 5.1$$



In comparison to the PBC’s results, the High Renewable study yields a significantly higher IRM, in addition to significantly higher corresponding locational margins. One metric that did not change significantly is the URM. Detailed comparison of the results of the two studies can be seen in Table 7.

**Table 7- Comparison to PBC Results**

Summary	PBC	High Ren
IRM	18.6%	42.9%
URM	4.7%	5.1%
J LCR	83.9%	97.9%
K LCR	102.3%	131.6%

**Figure 4- High Renewable Tan45 Curves**




Figure 4 displays the Tan45 curves for both Zones J and K. The flatness of both curves suggests that, in this scenario, certain minimum levels of downstate capacity will be required (e.g., >130% of peak load in Long Island and >95% of peak load in New York City) regardless of the NYCA-wide reserve margin. These minimum capacity levels are substantially higher than historic Locational Minimum Installed Capacity Requirements for each Locality. At the same time, minimum capacity levels required in downstate are likely to depend on the resources added to

NYC and LI (2,000 MW of offshore wind was assumed to interconnect into each LI and NYC for this analysis).

Additional metrics to gauge the reliability value changes in this scenario can be found in Table 8.

**Table 8- Changes from PBC to High Renewable Case**

	Preliminary Base Case	High Renewable Sensitivity	Deltas
<b>As Found ICAP (MW)</b>	42,465	54,465	+12,000
<b>ICAP @ LOLE =0.1 (MW)</b>	38,251	46,088	+7,837
<b>ICAP Removed (MW)</b>	4,213	8,376	+4,163
<b>UCAP Removed (MW)</b>	3,482	5,776	+2,294

This data shows that, for this scenario, adding 12,000 MW of intermittent renewables allows the approximate removal of an additional 4,200 MW of ICAP and 2,300 MW of UCAP.