

# Alternative Methods for Determining LCRs

---

Zachary Stines

Associate Market Design Specialist

**New York State Reliability Council – Installed Capacity Subcommittee**

June 28, 2017, NYISO



**DRAFT – FOR DISCUSSION PURPOSES ONLY**

©COPYRIGHT NYISO 2017. ALL RIGHTS RESERVED

# Agenda

- **Phase 1: Proof of Concept**
- **Phase 2: Refining Methodology**
  - Phase 1 Follow-up
  - Cost curves
  - Transmission Security
- **Next Steps**
- **Questions**

# Phase 1: Proof of Concept

# Optimized Base Case

Scenario	Zone J LCR (%)	Zone K LCR (%)	G-J LCR (%)	Cost (million)
Optimized Base Case (Updated)	77.5	107.0	91.0	\$4,366.4
Base Case (Current LCR)	81.4	103.2	91.3	\$4,407.7

- The NYISO final 2017-2018 Capability Year LCR base case was solved to a LOLE of 0.1 days/year with the NYSRC approved IRM of 18.0%
- The resulting base case will be used in order to compare the optimized methodology and the simplified version of the current LCR methodology

# Initial Sensitivities

- **Entry/exit of Capacity**
  - Capacity addition/subtraction in Zone GHIJ
  - Capacity addition/subtraction in Zone J
  - Capacity addition/subtraction in Zone K
  - Capacity addition/subtraction in Rest of State
  - Capacity addition/subtraction in G with Lower Bound on Zone J
- **Changes in Net CONE**
  - Increase and decrease GHIJ Net CONE
  - Increase and decrease Zone J Net CONE
  - Increase and decrease Zone K Net CONE
  - Increase and decrease NYCA Net CONE
  - Increase in all Locality Net CONE
- **Changes in Transmission Capability**
  - Increase UPNY-SENY

# Changes in Capacity: Conclusions

- The optimized methodology reduces volatility in comparison to the current LCR methodology when there are changes in capacity
- Secondary effects observed in the optimization will be investigated in Phase 2

# Changes in Transmission: Conclusions of Simple Analysis

- There are limitations to this simple analysis since changes in UPNY-SENY transmission would likely result in a change in the IRM
- The conclusions based on the simple analysis presently are:
  - UPNY-SENY reduces amount of optimal capacity required in GHJ, but does not impact the amount for Zone J
  - The Zone J LCR is minimized to its optimal level in the Base Case (as a result of constraints south of UPNY-SENY)
  - Future sensitivity will seek to confirm that the optimal Zone J LCR is dependent on the downstream constraints by increasing Dunwoodie South limit to observe if the optimal Zone J LCR decreases

# Changes in Net CONE: Conclusions

- The sensitivities tested extreme changes (i.e., between 30% and 55% change in Net CONE)
- The optimized LCR responded intuitively to the changes in Net CONE (i.e., increase in Net CONE in most instances causes a reduction in LCR)
- The Net CONE can have an impact on the final optimized LCRs
- This places an emphasis on developing robust methodology for determining the cost curves



# Phase 1: Conclusions and Next Steps

- Perform sensitivities to assist in the understanding of any secondary effects observed in changes in generation sensitivities
- Work to potentially refine methodology to address these secondary effects
- Develop a robust methodology for determining cost curves that minimizes volatility
- Run a full Tan45 process for a few specific sensitivities to increase the understanding of how the current process and optimization responds
- While cost savings are only 1-2%, the process has numerous other benefits
  - Stability, more robust, intuitive, etc.

# Phase 2: Refining the Methodology

# Phase 2: Refining Methodology

- **Follow-up on Phase 1**
  - Seek to analyze and understand questions raised in Phase 1 and not yet addressed
- **Cost curves**
  - Seek to evaluate and understand how the cost curve shape impacts the optimization
  - Identify candidate cost curve methods and shapes
- **Transmission Security**
  - Incorporate transmission security limits into the optimization

# Phase 1 Follow-up

# Phase 1 Follow-up

- **Following the May 11<sup>th</sup> ICAPWG, GE:**
  - Finished remaining Phase 1 sensitivities
  - Reran specific cases in which the results had appeared to be potentially anomalous
  - Performed new sensitivities aimed at answering certain questions raised in Phase 1 (e.g., increase in transmission capability of Dunwoodie South)
  - Perform a complete Tan45 on select sensitivities

# Increase in Transmission Capability

- Phase 1 sensitivity showed that increasing the transmission capability of UPNY-SENY reduced the optimal amount of capacity required in GHJ, yet minimally impacted Zone J
- It was hypothesized that Zone J LCR is minimized to its optimal level as a result of constraints south of UPNY-SENY
- Two new sensitivities sought to test this:
  - Dunwoodie South +1000 MW
  - UPNY-SENY +1000MW & Dunwoodie South +1000MW

# Changes in Transmission Sensitivities

## Conclusions

- The optimization limits Zone J capacity requirement subject to the constraints south of UPNY-SENY
- Transmission changes can have an impact on the tradeoffs between capacity within each Locality
  - Increase in Dunwoody South capability results in the optimal requirements for Zone K to increase while Zone J decreases

# Cost Curves



# Cost Curves

- **Phase 1 simple sensitivities only investigated how the magnitude of the cost curves impact the optimization**
- **Phase 2 will perform analysis and sensitivities to:**
  - Investigate the impact of cost curves' shape on optimization
  - Develop a robust methodology for generating the curves
  - Seek to reduce any unnecessary volatility from cost curves

# Transmission Security

**DRAFT – FOR DISCUSSION PURPOSES ONLY**

© COPYRIGHT NYISO 2017. ALL RIGHTS RESERVED.



# Transmission Security

- The NYISO continues to work to develop values for the lower bounds
- Sensitivities were performed to show how the optimization could incorporate lower bounds
  - Incorporated an arbitrary lower bound for Zone J of 80%

# Lower Bound Conclusions

- The optimization with a lower bound still results in a lower cost when compared to the current methodology
- The optimization still reduces volatility when a lower bound is incorporated

# Next Steps

# Complete Tan45

- Based upon stakeholder input, the following sensitivities were initialized using a complete Tan45
  - Changes in capacity within G-J locality
  - Increase in the transmission capability of UPNY-SENY

# Phase 3: Market Simulations

- **Goal: Simulate additional market situations to demonstrate performance of methodology**
  - Perform sensitivities with multiple changes to the system
  - Evaluate how the process would be performed with full Tan45 followed by optimization

# Consumer Impact

- Consumer impact analysis will be provided for this project
- Methodology of the analysis will be provided and presented this summer
- Final analysis will be presented in the fall



# Other Next Steps

- The NYISO will consider input received during today's ICAP Working Group meeting
- Additional comments sent to [deckels@nyiso.com](mailto:deckels@nyiso.com) will be considered
- The NYISO will return to a future ICAPWG meeting to discuss its progress and adjustments to the plan after considering comments or results

# 2017 Project Development

<u>Stage</u>	<u>Objective</u>	<u>Specific Topics:</u>
<b>Proof of Concept</b>	Demonstrate alternative methodology in relation to guiding principles ( <i>i.e.</i> , least cost, stability, robust, predictability)	Generation +/- Unit net CONE +/- Transmission +/-
<b>Refine Methodology</b>	Modify the alternative method to ensure that all aspects have a purpose and are being performed as a result of sound market and engineering principles	Unit net CONE curves Potential Bounds Modeling methodology
<b>Market Simulations</b>	Simulate realistic market situations to demonstrate performance of methodology	Changes in resources Topological changes Locality configurations
<b>Defining Process</b>	Develop a process for the methodology that ensures guiding principles are being achieved over time	Develop process of method Process timeline Transition methods
<b>Demonstrating Market Benefits</b>	Demonstrate the methodology results in market benefits and resolve any issues that arise from its implementation	LOLE Criterion Consumer impact Multiyear simulation Cost allocation
<b>Final Market Design</b>	Summarize all findings and develop a final market design for implementation	Develop final market design

# Questions?

# The Mission of the New York Independent System Operator, in collaboration with its stakeholders, is to serve the public interest and provide benefits to consumers by:

- Maintaining and enhancing regional reliability
- Operating open, fair and competitive wholesale electricity markets
- Planning the power system for the future
- Providing factual information to policy makers, stakeholders and investors in the power system



[www.nyiso.com](http://www.nyiso.com)

# Appendix

# ICAPWG Presentations

- **May 11, 2017**

[http://www.nyiso.com/public/webdocs/markets\\_operations/committees/bic\\_icapwg/meeting\\_materials/2017-05-11/ICAPWG\\_5-11-17\\_AlternativeMethodsforLCRs\\_vFinal.pdf](http://www.nyiso.com/public/webdocs/markets_operations/committees/bic_icapwg/meeting_materials/2017-05-11/ICAPWG_5-11-17_AlternativeMethodsforLCRs_vFinal.pdf)

- **June 1, 2017**

[http://www.nyiso.com/public/webdocs/markets\\_operations/committees/bic\\_icapwg/meeting\\_materials/2017-06-01/ICAPWG\\_6-1-17\\_AlternativeMethodsforLCRs\\_Final.pdf](http://www.nyiso.com/public/webdocs/markets_operations/committees/bic_icapwg/meeting_materials/2017-06-01/ICAPWG_6-1-17_AlternativeMethodsforLCRs_Final.pdf)